

DAILY REPORT

Reporting Date : 27-Jan-08

Till now the maximum generation is :-

4130.0 MW at

20:00 on

17-Sep-07

The Summary of Yesterday's (26-Jan-08) Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand		
Day Peak Generation :	2958.0	MW	Hour :	10:00	Min Gen. at 4:00	1955 MW
Evening Peak Generation :	3479.6	MW	Hour :	19:00	Max Generation :	3515 MW
E.P. Demand (at gen end) :	3750.0	MW	Hour :	19:00	Max Demand :	3850 MW
Maximum Generation :	3480.6	MW	Hour :	19:30	Shortage :	335 MW
Total Gen. (MKWH) :	64.42	System L/ Factor :	77.12%	Load Shed :		295 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from Ghorasal to Ishurdi :-	Maximum	324	MW	at 8:00	Energy	5560500	KWHR.
Import from Ishurdi to Ghorasal:-	Maximum	-	MW	at -	Energy	-	KWHR.

Water Level of Kaptai Lake at 6:00 A M of

27-Jan-08

Actual :	97.56	Ft.(MSL) ,	Rule curve :	98.00	Ft.(MSL)		
Gas Consumed :	PDB	446.25	MMCFt.	Oil Consumed :	PDB	SKO :	0
	WMPL	20.30	MMCFt.			HSD :	181742
	RPCL	28.77	MMCFt.			FO :	405458
	NEPC	13.91	MMCFt.				Liter
	CDC (H+M)	57.24	MMCFt.				Liter
	Total	566.47	MMCFt.				

Cost of the Consumed Fuel (PDB) : Gas : Tk32,982,260 Oil : Tk9,465,377 Total : Tk42,447,636

Load Shedding & Other Information

Area	Yesterday		Today		
	Actual Shedding (s/s end), MW		Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	from 17:30	to 20:42			
Dhaka	-		1400	35	3%
Chittagong Area	50		380	50	13%
Khulna Area	45		360	48	13%
Rajshahi Area	35		360	47	13%
Comilla Area	30		285	37	13%
Mymensing Area	30		210	27	13%
Sylhet Area	15		130	17	13%
Barisal Area	13		70	9	13%
Rangpur Area	20		190	25	13%
Total	238	(19:00)	3385	295	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Meghnaghat GT-1,2 & st - (06/01/08)	1) Haripur SBU GT-3 (25/05/05)
2) Rangpur GT-(28/12/07)	2) Sahjibazar GT-8(29/07/06)
3) Khulna 60 MW (05/07/06)	3) Khulna BMPP -1 (27/08/07)
	4) Ashuganj CCPP St-(20/10/07)
	5) Khulna BMPP -2 (03/12/07)
	6) Raozan unit -2 (24/01/08)
	7) Shahjibazar-4 (14/01/08)
	8) Ashuganj CCPP GT-1(24/01/08)
	9) Ashuganj -5(24/01/08)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 238 MW (19:00) of load shed was imposed over the whole area (except DESA) of the National grid.
b) After maintenance, Tongi GT (80 MW) was synchronized at 15:03.	
c) Kaptai unit -1 tripped at 17:31 due to guide bearing temperature high and was synchronized at 19:10.	
d) Ullon 132/33 KV T3 transformer was under shut down from 09:42 to 11:28 due to maintenance work at 33 KV bus by DESA.	
e) Madanganj 132/33 KV GT2 transformer was under shut down from 10:30 to 16:58 due to annual maintenance by DESA.	
f) Ghorasal - Ashuganj 230 KV line -1 was shut down at 15:06 due to maintenance of 230 KV breaker at Ashuganj S/S end.	

Deputy / Asstt. Manager
Load Despatch DivisionManager
Load Despatch DivisionDeputy General Manager
Load Despatch Circle