

DAILY REPORT

Till now the maximum generation is :-		4130.0 MW	at	20:00	on	17-Sep-07	Reporting Date : 24-Feb-08
The Summary of Yesterday's (23-Feb-08) Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand		
Day Peak Generation :	2983.0	MW	Hour :	11:00	Min Gen. at	4:00	2253 MW
Evening Peak Generation :	3726.1	MW	Hour :	20:00	Max Generation :		3840 MW
E.P. Demand (at gen end) :	3850.0	MW	Hour :	20:00	Max Demand :		3900 MW
Maximum Generation :	3726.1	MW	Hour :	20:00	Shortage :		60 MW
Total Gen. (MKWH) :	67.60	System L/ Factor :		75.59%	Load Shed :		54 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from Ghorasal to Ishurdi :-	Maximum	330 MW	at	6:00	Energy	6286500 KWHR.
Import from Ishurdi to Ghorasal:-	Maximum	-	MW	at	-	Energy - KWHR.

Water Level of Kaptai Lake at 6:00 A M of

Actual :	92.69	Ft.(MSL) ,	Rule curve :	93.75	Ft.(MSL)
Gas Consumed : : PDB	409.44	MMCFt.	Oil Consumed :	PDB	
WMPL	20.94	MMCFt.	SKO :	0	Liter
RPCL	28.81	MMCFt.	HSD :	284883	Liter
NEPC	9.79	MMCFt.	FO :	412254	Liter
CDC (H+M)	96.95	MMCFt.			
Total	565.93	MMCFt.			

Cost of the Consumed Fuel (PDB) : Gas :	Tk30,261,924	Oil :	Tk12,157,422	Total :	Tk42,419,347
---	--------------	-------	--------------	---------	--------------

Load Shedding & Other Information

Area	Yesterday		Today		
	Actual Shedding (s/s end), MW		Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	from 18:30	to 21:05			
Dhaka	20		1389	26	2%
Chittagong Area	22		425	4	1%
Khulna Area	24		373	6	2%
Rajshahi Area	7		355	5	1%
Comilla Area	5		285	6	2%
Mymensing Area	5		214	2	1%
Sylhet Area	13		160	2	1%
Barisal Area	9		68	1	1%
Rangpur Area	5		200	2	1%
Total	110	(20:00)	3469	54	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Rangpur GT-(28/12/07)	1) Haripur SBU GT-3 (25/05/05)
2) Khulna 60 MW (05/07/06)	2) Khulna BMPP -1 (27/08/07)
3) Siddhirganj 210 MW(14/02/08)	3) Ashuganj CCPP St-(20/10/07)
	4) Khulna BMPP -2 (03/12/07)
	5) Raozan unit -1 (19/02/08)
	6) Sikaibaha st-(04/02/08)
	7) Ashuganj -5 (22/02/08)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 110 MW (20:00) of load shed was imposed over the whole area of the National grid.
b) Due to gas limitation, Raozan -2 (210 MW) and RPCL units (210 MW) were limited to 110 MW and 175 MW respectively .	
c) Haripur Power Ltd. Steam tripped at 09:45 due to drum level high and was synchronized at 10:51.	
d) After maintenance, Ghorasal unit -4 was synchronized at 19:01.	
e) Madanhat - Kulshi 132 KV line -2 and Dohazari - Cox's Bazar 132 KV line -2 were under annual maintenance from 09:10 to 10:35 and 09:20 to 17:20 respectively.	
f) Haripur (on DIST. Z, AN) - Maniknagar (DIST. B-phase) 132 KV line -1 tripped at 09:05 from both sides and was switched on at 09:30.	
g) After dead line checking, Sylhet - Chatak 132 KV line -1 was switched on at 16:05. Again it is under shut down since 08:05 (24/02/08) due to the same reason.	
h) Haripur 230/132 KV TR2 transformer is under annual maintenance since 06:59 (24/02/08).	
i) Dohazari - Cox's Bazar 132 KV line -1 and Ashuganj - Shahjibazar 132 KV line -1 are under shut down since 08:10 (24/02/08) and 09:24 respectively.	

Deputy / Asstt. Manager
Load Despatch Division

Manager
Load Despatch Division

Deputy General Manager
Load Despatch Circle