

QF-LDC-08
Page -1

Reporting Date : 4-Jan-11
Hrs on 20-Aug-10

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Water Level of Kaptai Lake at 6:00 A M of

4-Jan-11

Oil Consumed (PDB) :

Cost of the Consumed Fuel (PDB) :	Gas	:	Tk43,938,756	Oil	:	Tk74,985,658	Total	:	Tk118,924,414
-----------------------------------	-----	---	--------------	-----	---	--------------	-------	---	---------------

Area	Yesterday		Today		
			Estimated Demand (s/s end) from tð/W	Estimated Shedding (s/s end) MW	Rates of Shedding (On Estimated Demand)
	MW				
Dhaka	100	(17:10-22:00 gen. shortage)	1522	132	9%
Chittagong Area	30	(17:10-21:55 gen. shortage)	427	57	13%
Khulna Area	30	(17:10-21:50 gen. shortage)	391	52	13%
Rajshahi Area	30	(17:10-21:50 gen. shortage)	321	43	13%
Comilla Area	32	(17:10-21:55 gen. shortage)	254	34	13%
Mymensing Area	16	(17:10-21:50 gen. shortage)	163	22	13%
Sylhet Area	16	(17:10-21:50 gen. shortage)	194	13	7%
Barisal Area	9	(17:10-21:50 gen. shortage)	76	10	13%
Rangpur Area	17	(17:10-21:50 gen. shortage)	180	24	13%
Total	280	20:00	3528	387	

Information of the Generating machines under shut down.

Planned Shut- Down		Forced Shut- Down	
1) Haripur SBU GT-3 (18/06/09)	9) Kaptai #3 (1/12/10)	1) Ghorasal 6(18/07/10)	
2) Ghorasal 2(26/04/10)	10) Barapukuria-2(20/12/10)	2) Ashuganj-1(09/11/10)	
3) Siddirganj GT-1 (18/06/10)		3) Sikalbaha 60MW(19/11/10)	
4) Ashuganj-4(12/09/10)		4) Haripur SBU GT-1(26/12/10)	
5) Raozan-1 (03/10/10)		5) Ashuganj-2(31/12/10)	
6) Sikalbaha GT (24/10/10)		6) Khulna-110 MW(31/12/10)	
7) Raozan-2 (21/10/10)			
8) Kaptai #5 (02/11/10)			

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas	
a) There was generation shortage in the evening peak hour yesterday. b) Due to low gas pressure RPCL (210 MW) was limited to 77 MW. c) After maintenance Barapukuria #1 was synchronized at 16:35 and again tripped at 02:12 (04/01/11) due to generator fault and was synchronized at 05:03(04/01/11) d) After maintenance Shahjibazar #9 was synchronized at 16:03. e) Siddirganj-210 MW tripped at 06:08(04/01/11) due to auxiliary supply failure. f) Madanhat-Sikalbaha 132kV line-1 was under shut down from 08:39 to 17:07 due to annual maint. g) Bogra-Barapukuria 230kV line-2 was under shut down from 10:40 to 15:15 due to annual maint. h) Shahjibazar-Srimongal 132kV line-1 was under shut down from 09:38 to 14:40 due to annual maint. i) Goalpara-Bagherhat 132kV line was under shut down from 08:57 to 15:50 due to annual maint. j) Haripur-Comilla 132kV line-1 was under shut down from 09:28 to 16:37 due to annual maint. k) Ishurdi-Natore 132 kV line-1 was under shut down from 08:59 to 15:50 due to annual maint. l) Joydevpur 132/33 kV T1 transformer was under shut down from 09:16 to 16:32 due to annual maint. m) Mirpur 132/33 kV T1 transformer was shut down at 09:20 due to breaker oil leakage.	<p>So about 280 MW (20:00) load shed was imposed over the whole areas of the national grid .</p> <p>Due to generation shortage, about 85 MW (09:00) of load shed has been running since morning (04/01/11) over the whole area</p>	
Deputy / Asstt. Manager Network Operation Division	Manager Network Operation Division	Deputy General Manager Load Despatch Circle