

DAILY REPORT

Till now the maximum generation is :-		4130.0 MW	at	20:00	on	Reporting Date : 3-Jun-08 17-Sep-07
The Summary of Yesterday's (2-Jun-08)		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand		
Day Peak Generation :	3151.0	MW	Hour :	9:00	Min Gen. at 6:00	2572 MW
Evening Peak Generation :	3378.7	MW	Hour :	20:00	Max Generation :	3500 MW
E.P. Demand (at gen end) :	4350.0	MW	Hour :	20:00	Max Demand :	4400 MW
Maximum Generation :	3378.7	MW	Hour :	20:00	Shortage :	900 MW
Total Gen. (MKWH) :	73.82	System L/ Factor :		91.04%	Load Shed :	780 MW

EXPORT /IMPORT THROUGH EAST-WEST INTERCONNECTOR					
Export from Ghorasal to Ishurdi :-	Maximum	222 MW	at 24:00	Energy	4290000 KWHR.
Import from Ishurdi to Ghorasal:-	Maximum	-	MW at -	Energy	- KWHR.
Water Level of Kaptai Lake at 6:00 A M of 3-Jun-08					
Actual :	70.42	Ft.(MSL) ,	Rule curve :	76.52	Ft.(MSL)

Oil Consumed :			
PDB	SKO	:	0 Liter
	HSD	:	308569 Liter
	FO	:	407723 Liter

Gas Consumed : Total	611.36	MMCFt.				
Cost of the Consumed Fuel (PDB) : Gas	:		Tk35,013,424	Oil	:	Tk12,702,550
			Total		:	Tk47,715,974

Load Shedding & Other Information

Area	Yesterday				Today			
	Actual Shedding (s/s end), MW				Estimated Demand(s/s end)		Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	from	18:30	to	0:45				
Dhaka		230				1590	270	17%
Chittagong Area		190				500	131	26%
Khulna Area		134				412	96	23%
Rajshahi Area		84				360	74	21%
Comilla Area		50				286	67	23%
Mymensing Area		18				205	37	18%
Sylhet Area		43				175	44	25%
Barisal Area		32				72	18	25%
Rangpur Area		61				215	43	20%
Total		842	(20:00)	3815	780	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	8) Sikalbaha St -(08/05/08) 9) Ashuganj -3 (13/05/08) 10) Tongi GT (21/05/08) 11) RPCL -1 (22/05/08) 12) Ghorsal 3 (30/05/08) 13) Ashuganj -4 (30/05/08) 14) Ashuganj CCPP GT-1(01/06/08)
	1) Haripur SBU GT-3 (25/05/05) 2) Ashuganj CCPP St-(20/10/07) 3) Shahjibazar -2 (19/05/08) 4) Kaptai unit-3 (19/04/08) 5) Bheramara -2 (18/04/08) 6) 4 units of KPCL 7) Raozan 2 -(18/05/08)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 842 MW (20:00) of load shed was imposed over the whole area of the national grid.
b) Due to gas limitation, Raozan (180 MW), RPCL (210 MW) and Siddhirganj (190 MW) were limited to 110 MW, 160 MW, 180 MW respectively	
c) Due to gas limitation, Raozan -2, Sikalbaha Steam & Barge and Shahjibazar - 2 were under shut down.	
d) After maintenance Ashuganj CCPP GT-1 was synchronized at 13:08 again it tripped at 06:42 (03/06/08) due to Combustion abnormal, it may be synchronized before evening peak hour today.	
e) Westmont unit-1 & 2 tripped at 13:55 due to auxiliary fail and were synchronized at 17:32 & 17:52 respectively.	
f) Baghabari (no relay) - Ishurdi (CAR, CD, CS-2, CS-3) - Pabna (21 A-đ, 79CB1, A/R-đ) - Shahjadpur line tripped at 13:55 and was switched on at 15:05.	power interruption occurred (10 MW) under Pabna S/S area from 13:55 to 15:05.
g) Ullon - siddhirgonj 132 KV line-1 tripped at 15:12 showing dist Z ₁ ,Z ₂ ,Z ₃ . and was switched on at 15:23.	
	Due to generation shortage, about 100 MW of load shed has been running since morning (03/06/08) over the whole area of the national grid.

Deputy / Asstt. Manager
Load Despatch Division

Manager
Load Despatch Division

Deputy General Manager
Load Despatch Circle