

**DAILY REPORT**

Till now the maximum generation is :-		4130.0 MW	at	20:00	on	Reporting Date : 5-Jun-08 17-Sep-07
<b>The Summary of Yesterday's ( 4-Jun-08 ) Generation &amp; Demand</b>		<b>Today's Actual Min Gen. &amp; Probable Gen. &amp; Demand</b>				
Day Peak Generation :	3275.0	MW	Hour :	10:00	Min Gen. at 6:00	2498 MW
Evening Peak Generation :	3450.7	MW	Hour :	19:30	Max Generation :	3460 MW
E.P. Demand (at gen end) :	4400.0	MW	Hour :	19:30	Max Demand :	4300 MW
Maximum Generation :	3450.7	MW	Hour :	19:30	Shortage :	840 MW
Total Gen. (MKWH) :	76.57	System L/ Factor :		92.46%	Load Shed :	727 MW
<b>EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR</b>						
Export from Ghorasal to Ishurdi :- Maximum		282 MW	at	4:00	Energy	5956500 KWHR.
Import from Ishurdi to Ghorasal:- Maximum		-	MW	at -	Energy	- KWHR.
Water Level of Kaptai Lake at 6:00 A M of				5-Jun-08		
Actual :	70.17	Ft.(MSL) ,	Rule curve :	77.04	Ft.( MSL )	
Oil Consumed :						
		PDB	SKO :	0	Liter	
			HSD :	260434	Liter	
			FO :	409989	Liter	
<b>Gas Consumed : Total 635.32 MMCFt.</b>						
Cost of the Consumed Fuel (PDB) : Gas :		Tk36,737,732	Oil :	Tk11,511,448	Total :	Tk48,249,180

**Load Shedding & Other Information**

Area	Yesterday				Today				
	Actual Shedding (s/s end), MW				Estimated Demand(s/s end)	MW	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)	
	from	18:30	to	00:00					
Dhaka		212				1560		256	16%
Chittagong Area		157				500		136	27%
Khulna Area		115				405		94	23%
Rajshahi Area		69				350		68	19%
Comilla Area		67				280		64	23%
Mymensing Area		71				200		34	17%
Sylhet Area		51				165		36	22%
Barisal Area		10				72		19	26%
Rangpur Area		70				190		20	11%
Total		822	(	19:30	)	3722		727	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	8) Sikalbaha St -(08/05/08) 9) Ashuganj -3 (13/05/08) 10) Tongi GT ( 21/05/08) 11) RPCL -1 (22/05/08) 12) Ghorsal 3 (30/05/08)
	1) Haripur SBU GT-3 (25/05/05) 2) Ashuganj CCPP St-(20/10/07) 3) Shahjibazar -2 (19/05/08) 4) Kaptai unit-3 (19/04/08) 5) Bheramara -2 (18/04/08) 6) 4 units of KPCL 7) Raozan 2 -(18/05/08)

**Additional Information of Machines, lines, Interruption / Forced Load shed etc.**

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 822 MW (19:30) of load shed was imposed over the whole area of the national grid.
b) Due to gas limitation, Raozan (180 MW ), RPCL ( 210 MW ) and Siddhirganj (190 MW ) were limited to 100 MW, 145 MW, 115 MW respectively	
c) Due to gas limitation, Raozan -2, Sikalbaha Steam & Barge and Shahjibazar - 2 were under shut down	
d) Ashugonj -Shahjibazar 132 KV line-1 was under shut down from 10:35 to 17:33 due to annual maintenance.	
e) Siddhirganj 132/33 KV T2 transformers was under shut down from 14:00 to 19:40 due to 33 KV cable maintenance carried by DESA .	
f) Chatak 132/33 KV T2 transformers tripped at 03:15 (05/06/08) showing over current due to 33 KV REB feeder fault and was switched on at 03:25 (05/06/08).	

Deputy / Asstt. Manager  
Load Despatch Division

Manager  
Load Despatch Division

Deputy General Manager  
Load Despatch Circle