

Reporting Date : 7-Jun-08  
17-Sep-07

on

| EXPORT /IMPORT THROUGH EAST-WEST INTERCONNECTOR |       |            |              |       |            |                      |
|---|-------|------------|--------------|-------|------------|----------------------|
| Export from Ghorasal to Ishurdi :- Maximum      |       |            | 282 MW       | at    | 20:00      | Energy 5676000 KWHR. |
| Import from Ishurdi to Ghorasal:- Maximum       |       |            | -            | MW    | at -       | Energy - KWHR.       |
| Water Level of Kaptai Lake at 6:00 A M of       |       |            | 7-Jun-08     |       |            |                      |
| Actual :  | 70.37 | Ft.(MSL) , | Rule curve : | 77.56 | Ft.( MSL ) |                      |

|          |  |       |            |              |       |            |
|----------|--|-------|------------|--------------|-------|------------|
| Actual : |  | 70.37 | Ft.(MSL) , | Rule curve : | 77.56 | Ft.( MSL ) |
|----------|--|-------|------------|--------------|-------|------------|

|                                       |        |        |              |     |         |              |
|---------------------------------------|--------|--------|--------------|-----|---------|--------------|
| Gas Consumed : Total                  | 637.81 | MMCFt. |              |     |         |              |
| Cost of the Consumed Fuel (PDB) : Gas | :      |        | Tk36,993,557 | Oil | :       | Tk15,395,732 |
|                                       |        |        |              |     | Total : | Tk52,389,289 |

| Area            | Yesterday                     |            |           |      | Today                     |            |                              |  |
|-----------------|-------------------------------|------------|-----------|------|---------------------------|------------|------------------------------|--|
|                 | Actual Shedding (s/s end), MW |            |           |      | Estimated Demand(s/s end) | MW         | Estimated Shedding (s/s end) | Rates of Shedding<br>(On Estimated Demand) |
|                 | from                          | 18:30      | to        | 1:30 |                           |            |                              |  |
| Dhaka           |                               | 110        |           |      | 1510                      | 215        | 14%                          |  |
| Chittagong Area |                               | 85         |           |      | 440                       | 79         | 18%                          |  |
| Khulna Area     |                               | 45         |           |      | 380                       | 71         | 19%                          |  |
| Rajshahi Area   |                               | 45         |           |      | 345                       | 65         | 19%                          |  |
| Comilla Area    |                               | 30         |           |      | 263                       | 49         | 19%                          |  |
| Mymensing Area  |                               | 30         |           |      | 202                       | 37         | 18%                          |  |
| Sylhet Area     |                               | 26         |           |      | 157                       | 29         | 18%                          |  |
| Barisal Area    |                               | 12         |           |      | 65                        | 12         | 18%                          |  |
| Rangpur Area    |                               | 40         |           |      | 202                       | 33         | 16%                          |  |
| <b>Total</b>    |                               | <b>423</b> | ( 20:00 ) |      | <b>3564</b>               | <b>590</b> |                              |  |

| Planned Shut- Down             | Forced Shut- Down             |
|--------------------------------|-------------------------------|
| 1) Khulna 60 MW (05/07/06)     | 9) Ghorsal 3 (30/05/08)       |
|                                | 10) Haripur SBU GT1(05/06/08) |
|                                | 11) Haripur SBU GT2(03/06/08) |
| 2) Ashuganj CCPP St-(20/10/07) |                               |
| 3) Shahjibazar -2 (19/05/08)   |                               |
| 4) Kaptai unit-3 (19/04/08)    |                               |
| 5) 4 units of KPCL             |                               |
| 6) Raozan1 -(06/06/08)         |                               |
| 7) Sikalbaha St -(08/05/08)    |                               |
| 8) Ashuganj -3 (13/05/08)      |                               |
| 9) RPCL -1 (22/05/08)          |                               |

| Description  | Forced load shaded / Interrupted Areas  |
|--|---|
| a) There was generation shortage in the evening peak hour yesterday .  | So about 423 MW (20:00) of load shed was imposed over the whole area (except Barisal) of the national grid. |
| b) Due to gas limitation, Raozan (180 MW ), RPCL ( 210 MW ) and Siddhirganj (190 MW ) were limited to 100 MW, 160 MW, 120 MW respectively  |   |
| c) Due to gas limitation, Haripur SBU -1 & 2, Raozan -1, Sikalbaha Steam & Barge and Shahjibazar - 2 were under shut down  |   |
| d) Raozan unit -2 was synchronized at 14:20.   |   |
| e) After maintenance, Ullon - Dhanmondi 132 KV U/G cable line -1 was switched on at 12:35. Again it tripped at 13:40 from Ullon end showing ' Over current at Y- phase and differential relay' and was switched on at 17:28. |   |
| f) Ullon - Siddhirganj 132 KV line -1 tripped at 13:39 from Siddhirganj end showing ' DIST Z1' and was switched on at 13:54.   |   |
| g) After maintenance, Halisahar - Julda 132 KV line was switched on at 12:26.  |   |
| h) After maintenance, Hasnabad - Meghnaghat 230 KV line - 2 was switched on at 12:19.  |   |
| i) Shetalakha 132 KV line was under shut down from 07:20(07/06/08) to 07:55 due to maintenance work by Telemetering division.  |   |
| j) Shyampur - Hasnabad 132 KV line was under shut down from 07:27 (07/06/08) to 09:50 due to maintenance work by Telemetering division.  |   |

Deputy General Manager  
Load Despatch Circle