

**DAILY REPORT**

Till now the maximum generation is :-		4130.0 MW	at	20:00	on	Reporting Date : 11-Jun-08 17-Sep-07
<b>The Summary of Yesterday's ( 10-Jun-08 ) Generation &amp; Demand</b>		<b>Today's Actual Min Gen. &amp; Probable Gen. &amp; Demand</b>				
Day Peak Generation :	3320.5	MW	Hour :	12:00	Min Gen. at 6:00	2986 MW
Evening Peak Generation :	3402.2	MW	Hour :	19:30	Max Generation :	3402 MW
E.P. Demand (at gen end) :	4300.0	MW	Hour :	19:30	Max Demand :	4300 MW
Maximum Generation :	3402.2	MW	Hour :	19:30	Shortage :	898 MW
Total Gen. (MKWH) :	77.15	System L/ Factor :		94.49%	Load Shed :	762 MW

<b>EXPORT /IMPORT THROUGH EAST-WEST INTERCONNECTOR</b>					
Export from Ghorasal to Ishurdi :-	Maximum	240 MW	at	19:00	Energy 3696000 KWHR.
Import from Ishurdi to Ghorasal:-	Maximum	-	MW	at -	Energy - KWHR.
Water Level of Kaptai Lake at 6:00 A M of 11-Jun-08					
Actual :	70.10	Ft.(MSL) ,	Rule curve :	78.60	Ft.( MSL )

Oil Consumed :			
PDB	SKO	:	0 Liter
	HSD	:	282695 Liter
	FO	:	732789 Liter

<b>Gas Consumed : Total</b>	662.39	MMCFt.				
Cost of the Consumed Fuel (PDB) : Gas	:	Tk38,537,775	Oil	:	Tk15,948,476	Total : Tk54,486,251

**Load Shedding & Other Information**

Area	Yesterday				Today			
	Actual Shedding (s/s end), MW				Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)	
	from	18:30	to	00:50				
Dhaka		195				1550	291	19%
Chittagong Area		140				458	108	24%
Khulna Area		98				380	80	21%
Rajshahi Area		94				350	78	22%
Comilla Area		51				270	63	23%
Mymensing Area		56				205	45	22%
Sylhet Area		31				160	36	23%
Barisal Area		27				67	16	24%
Rangpur Area		70				210	45	21%
Total		762	(	19:30	)	3650	762	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	9) Haripur SBU GT1(05/06/08) 10) Haripur SBU GT2(03/06/08) 11) Ashuganj 1(09/06/08) 12) Ghorasal -1 (10/06/08) 13) Bhrramara-3 (09/06/08)
	1) Ashuganj CCPP St-(20/10/07) 2) Shahjibazar -2 (19/05/08) 3) Kaptai unit-3 (19/04/08) 4) 4 units of KPCL 5) Raozan1 -(06/06/08) 6) Sikalbaha St -(08/05/08) 7) Ashuganj -3 (13/05/08) 8) RPCL -1 (22/05/08)

**Additional Information of Machines, lines, Interruption / Forced Load shed etc.**

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 762 MW (19:30) of load shed was imposed over the whole area of the national grid.
b) Due to gas limitation, Ghorasal (835 MW) ,Raozan (180 MW) , RPCL ( 210 MW ) and Siddhirganj (190 MW ) were limited to 650 MW, 110 MW, 125 MW and 100 MW respectively	
c) Due to gas limitation, Haripur SBU -1 & 2, Raozan -1, Sikalbaha Steam & Barge and Shahjibazar - 2 were under shut down	
d) Barapukuria - Saidpur 132 KV line -2 was under shut down from 08:35 to 09:45 due to red-hot maintenance at Barapukuria end.	
e) Dohazari - Sikalbaha 132 KV line -1 was shut down at 10:28 due to project work and was switched on by bus coupler at 14:40.	
f) Syedpur - Purbasadipur 132 KV line -1 was under shut down from 10:30 to 18:03 due to maintenance of post insulator.	
g) After maintenance, Sreemongal - Shahjibazar 132 KV line -1 was switched on at 15:08.Again it is under shut down at 08:4 5(11/06/08) due to the same reason.	

Deputy / Asstt. Manager  
Load Despatch Division

Manager  
Load Despatch Division

Deputy General Manager  
Load Despatch Circle