

DAILY REPORT

Till now the maximum generation is :-		4130.0 MW	at	20:00	on	Reporting Date : 22-Jun-08 17-Sep-07
The Summary of Yesterday's (21-Jun-08)		Generation & Demand			Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :	3147.5	MW	Hour :	11:00	Min Gen. at 6:00	2923 MW
Evening Peak Generation :	3306.1	MW	Hour :	19:30	Max Generation :	3340 MW
E.P. Demand (at gen end) :	4000.0	MW	Hour :	19:30	Max Demand :	4300 MW
Maximum Generation :	3306.1	MW	Hour :	19:30	Shortage :	960 MW
Total Gen. (MKWH) :	71.94	System L/ Factor :		90.67%	Load Shed :	810 MW
EXPORT /IMPORT THROUGH EAST-WEST INTERCONNECTOR						
Export from Ghorasal to Ishurdi :- Maximum		330 MW	at	19:30	Energy	6204000 KWHR.
Import from Ishurdi to Ghorasal:- Maximum		-	MW	at -	Energy	- KWHR.
Water Level of Kaptai Lake at 6:00 A M of				22-Jun-08		
Actual :	71.11	Ft.(MSL) ,	Rule curve :	81.57	Ft.(MSL)	
Oil Consumed :						
PDB					SKO :	0 Liter
					HSD :	292349 Liter
					FO :	307902 Liter
Gas Consumed : Total 664.54 MMCFt.						
Cost of the Consumed Fuel (PDB) : Gas :		Tk38,210,613	Oil :	Tk11,094,168	Total :	Tk49,304,781

Load Shedding & Other Information

Area	Yesterday			Today			
	Actual Shedding (s/s end), MW			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)	
	from	18:30	to 03:40				
Dhaka		78		1531	301	20%	
Chittagong Area		128		480	140	29%	
Khulna Area		78		380	88	23%	
Rajshahi Area		106		345	79	23%	
Comilla Area		11		265	63	24%	
Mymensing Area		50		205	49	24%	
Sylhet Area		46		156	36	23%	
Barisal Area		20		65	15	23%	
Rangpur Area		68		200	39	20%	
Total		585	(19:30)	3627	810		

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	1) Ashuganj CCPP ST-(20/10/07) 2) Shahjibazar -4 (22/05/08) 3) Kaptai-3 (19/04/08) 4) 4 units of KPCL 5) Raozan -2 (19/06/08) 6) Sikalbaha St- (19/06/08) 7) Ashuganj -3 (13/05/08)
	8) Haripur SBU GT-1 (05/06/08) 9) Haripur SBU GT-3(13/06/08) 10) Ghorasal -1 (22/06/08) 11) Barapukuria-1 (18/06/08) 12) Fenchuganj GT1,2 &st (19/06/08) 13) Khulna 110 MW -19/06/08

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 585 MW (19:30) of load shed was imposed over the whole area of the national grid.
b) Due to gas limitation, Ghorasal (835 MW) ,Raozan (180 MW) , RPCL (210 MW) and Siddhirganj (190 MW) were limited to 730 MW, 90 MW, 142 MW and 100 MW respectively	
c) Due to gas limitation, Haripur SBU -1 & 3, Raozan -2, Sikalbaha Steam & Barge and Shahjibazar - 2 were under shut down	
d) After maintenance, Fenchuganj GT-2, GT-1 and steam were synchronized at 17:25, 20:21 and 23:28 respectively. Again GT-2 was shut down at 07:08 (22/06/08) due to combine mode and was synchronized at 07:48.	
e) After maintenance, Ghorasal unit -1 was synchronized at 17:48 . But it was forced shut down at 19:45 due to boiler tube leakage.	
f) After maintenance, Shahjibazar unit - 8 was synchronized at 18:17.	
g) Ashuganj steam unit -2 tripped at 05:10 (22/06/08) due to low pressure turbine problem. It is now under inspection and maintenance.	
h) Ishurdi 132/33 KV T1 transformer was under shut down from 10:0 8 to 11:08 due to maintenance work by Distribution division.	
i) Fenchuganj 90 MW - Sylhet 132 KV line -2 and 1 were under project work from 10:33 to 16:55 and 10:42 to 16:15 respectively.	
j) Halisahar 132/33 KV T1 transformer was under shut down from 05:40(22/06/08) to 06:45 due to red-hot maintenance at 33 KV bushing.	

Deputy / Asstt. Manager
Load Despatch Division

Manager
Load Despatch Division

Deputy General Manager
Load Despatch Circle