6600000 KWHR.

**KWHR** 

## DAILY REPORT

300 MW

Oil Consumed : PDB

Reporting Date :

Till now the maximum generation is 4130.0 MW οn at The Summary of Yesterday's ( 23-.lun-08 ) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand MW Day Peak Generation 3148.0 9:00 Min Gen. at 3120 MW Hour 6:00 3301 MW **Evening Peak Generation** 3291.7 MW Hour 19:30 Max Generation E.P. Demand (at gen end) 4300.0 MW 19:30 Max Demand 4350 MW Hour Maximum Generation 3291 7 MW Hour 19:30 Shortage 1049 MW Total Gen. (MKWH) 94.28% 884 MW 74.49 System L/ Factor Load Shed THROUGH EAST-WEST INTERCONNECTOR EXPORT / IMPORT

Import from Ishurdi to Ghorasal:- Maximum MW Water Level of Kaptai Lake at 6:00 A M of 24-Jun-08

71 76 Ft.(MSL) Rule curve 82.11 Ft.( MSL )

> SKO 0 Liter HSD 356238 Liter FO 715676 Liter

Energy

Energy

Gas Consumed: Total MMCFt. 672.36 Cost of the Consumed Fuel (PDB): Oil Tk17,604,495 Tk56,965,924 Gas Total

## **Load Shedding & Other Information**

Export from Ghorasal to Ishurdi :- Maximum

Actual :

Area	Yesterday		Today		
	Actual Shedding	g (s/s end), MW	Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding
	from 18:30 to	00:00	MW	MW	(On Estimated Demand)
Dhaka	239		1562	348	22%
Chittagong Area	215		480	144	30%
Khulna Area	65		385	96	25%
Rajshahi Area	85		345	83	24%
Comilla Area	55		265	66	25%
Mymensing Area	65		205	51	25%
Sylhet Area	50		158	39	25%
Barisal Area	10		65	16	25%
Rangpur Area	65		200	41	21%
Total	849 (	( 19:30	) 3665	884	

Information of the Generating machines under maintenance

Planned Shut- Down		Forced Shut-Down		
1) Khulna 60 MW (05/07/06)	1) Ashuganj CCPP ST-(20/10/07)	8) Haripur SBU GT-1 (05/06/08)		
	2) Shahjibazar -4 (22/05/08)	9) Haripur SBU GT-3(13/06/08)		
	3) Kaptai-3 (19/04/08)	10) Ghorasal -1 (22/06/08)		
	4) 4 units of KPCL	11) Barapukuria-1 (18/06/08)		
	5) Raozan -2 (19/06/08)	12) Ashuganj -2 (22/06/08)		
	6) Sikalbaha St- (19/06/08)	13) Kaptai 1 &2-(23/06/08)		
	7) Ashuganj -3 (13/05/08)			
	<u> </u>			

## Additional Information of Machines, lines, Interruption / Forced Load shed etc.

a) There was generation shortage in the evening peak hour yesterday So about 849 MW (19:30) of load shed was imposed over the whole

- b) Due to gas limitation, Ghorasal (835 MW) ,Raozan (180 MW ), RPCL (210 MW ) and Siddhirganj (190 MW) were limited to 700 MW, 90 MW, 110 MW and 100 MW respectively
- c) Due to gas limitation, Haripur SBU -1, Raozan -2, Sikalbaha Steam & Barge and Shahjibazar 2 were under shut down
- d) After maintenance, Fenchuganj CCPP GT-1 was synchronized at 13:29. Again GT-2 was shut down at 15:33 due to combine mode and GT-2 and steam were synchronized at 16:19 and 15:33 respectively.
- e) Ashuganj Serajganj 230 KV line -1 & 2 were under shut down from 09:32 to 18:04 and 09:33 to 18:06 respectively due to project work. Again they are under shut down since 07:58 (24/06/08) and 07:59 respectively due to the same reason.
- f) Chowmuhani 132/33 KV T2 transformer was under shut down from 16:06 to 16:25 due to SF6 gas filling of 33 KV breaker.

Partial power interruption occurred (8 MW) under Chowmuhani S/S areas for 19 minutes.

area of the national grid.

Due to generation shortage, about 180 MW of load shed has been running since morning (24/06/08) over the whole areas of the national grid.

Deputy / Asstt. Manager Load Despatch Division Manager Load Despatch Division Deputy General Manager Load Despatch Circle