

DAILY REPORT

Reporting Date : 26-Jun-08

Till now the maximum generation is :-

4130.0 MW at 20:00 on

17-Sep-07

The Summary of Yesterday's (25-Jun-08)		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :	3132.0	MW	Hour : 10:00	Min Gen. at 1:00	3061.7 MW
Evening Peak Generation :	3269.7	MW	Hour : 20:00	Max Generation :	3346 MW
E.P. Demand (at gen end) :	4350.0	MW	Hour : 20:00	Max Demand :	4350 MW
Maximum Generation :	3269.7	MW	Hour : 20:00	Shortage :	1004 MW
Total Gen. (MKWH) :	73.65	System L/ Factor :	93.86%	Load Shed :	850 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from Ghorasal to Ishurdi :-	Maximum	324 MW	at 2:00	Energy	6303000 KWHR.
Import from Ishurdi to Ghorasal:-	Maximum	-	MW at -	Energy	- KWHR.

Water Level of Kaptai Lake at 6:00 A M of

26-Jun-08

Actual : 72.43 Ft.(MSL) , Rule curve : 82.65 Ft.(MSL)

Oil Consumed :

PDB :

SKO :

0

Liter

HSD :

424026

Liter

FO :

575934

Liter

Gas Consumed : Total

662.05

MMCFt.

Cost of the Consumed Fuel (PDB) : Gas :

Tk38,660,419

Oil :

Tk17,643,297

Total :

Tk56,303,716

Load Shedding & Other Information

Area	Yesterday			Today			
	Actual Shedding (s/s end), MW			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)	
	from	18:30	to 00:00				
Dhaka		222		1565	327	21%	
Chittagong Area		195		480	137	29%	
Khulna Area		98		385	91	24%	
Rajshahi Area		98		345	78	23%	
Comilla Area		51		265	62	23%	
Mymensing Area		80		205	48	23%	
Sylhet Area		70		165	44	27%	
Barisal Area		18		70	20	29%	
Rangpur Area		83		205	43	21%	
Total		915	(20:00)	3685	850		

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	1) Ashuganj CCPP ST-(20/10/07) 2) Shahjibazar -4 (22/05/08) 3) Kaptai- 3 (19/04/08) 4) Raozan -2 (19/06/08) 5) Sikalbaha St- (19/06/08) 6) Ashuganj -3 (13/05/08) 7) Shahjibazar GT-8 (24/06/08)
	8) Haripur SBU GT-1 (05/06/08) 9) Haripur SBU GT-3(13/06/08) 10) Ghorasal -1 (22/06/08) 11) Barapukuria-1 (18/06/08) 12) Kaptai 1 &2-(23/06/08)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 915 MW (20:00) of load shed was imposed over the whole area of the national grid.
b) Due to gas limitation, Ghorasal (835 MW) ,Raozan (180 MW) , RPCL (210 MW) and Siddhirganj (190 MW) were limited to 710 MW, 90 MW, 103 MW and 100 MW respectively.	
c) Due to gas limitation, Haripur SBU -1, Raozan -2, Sikalbaha Steam & Barge and Shahjibazar - 2 were under shut down.	
d) Ashuganj CCPP GT-1 tripped at 20:38 due to combustion abnormality and was synchronized at 21:56 Again it tripped at 22:30 due to governor system failure It may be synchronized before evening peak hour today.	
e) After maintenance Ashuganj unit-2 was synchronized at 22:53.	
f) Tongi (Dist-Z1,E/F) - Kabirpur (Dist-C, E/F) 132 KV line-1 tripped at 16:25 and was switched on at 16:45	
g) After project work, Ashuganj - Seraiganj 230 KV line -1 & 2 were switched on at 19:55.	
	Due to generation shortage, about 200 MW of load shed has been running since morning (26/06/08) over the whole areas of the national grid.

Deputy / Asstt. Manager
Load Despatch DivisionManager
Load Despatch DivisionDeputy General Manager
Load Despatch Circle