

DAILY REPORT

Till now the maximum generation is :-		4130.0 MW	at	20:00	on	Reporting Date : 3-Jul-08 17-Sep-07
The Summary of Yesterday's (2-Jul-08)		Generation & Demand			Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation :	3285.0	MW	Hour :	11:00	Min Gen. at 6:00	2850 MW
Evening Peak Generation :	3346.9	MW	Hour :	20:00	Max Generation :	3388 MW
E.P. Demand (at gen end) :	4250.0	MW	Hour :	20:00	Max Demand :	4250 MW
Maximum Generation :	3453.0	MW	Hour :	24:00	Shortage :	862 MW
Total Gen. (MKWH) :	75.54	System L/ Factor :		91.15%	Load Shed :	722 MW
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR						
Export from Ghorasal to Ishurdi :- Maximum		286 MW	at	20:00	Energy	4752000 KWHR.
Import from Ishurdi to Ghorasal:- Maximum		-	MW	at -	Energy	- KWHR.
Water Level of Kaptai Lake at 6:00 A M of				3-Jul-08		
Actual :	72.75	Ft.(MSL) ,	Rule curve :	84.32	Ft.(MSL)	
Oil Consumed :						
PDB					SKO :	0 Liter
					HSD :	282223 Liter
					FO :	562446 Liter
Gas Consumed : Total 657.31 MMCFt.						
Cost of the Consumed Fuel (PDB) : Gas :		Tk40,307,063	Oil :	Tk13,892,404	Total :	Tk54,199,467

Load Shedding & Other Information

Area	Yesterday				Today			
	Actual Shedding (s/s end), MW				Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)	
	from	18:30	to	5:10				MW
Dhaka		172			1515	279	18%	
Chittagong Area		168			475	132	28%	
Khulna Area		74			370	76	21%	
Rajshahi Area		93			325	58	18%	
Comilla Area		55			260	57	22%	
Mymensing Area		60			192	35	18%	
Sylhet Area		58			160	39	24%	
Barisal Area		10			66	16	24%	
Rangpur Area		65			192	30	16%	
Total		755	(20:00)	3555	722	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	1) Ashuganj CCPP ST-(20/10/07) 2) Kaptai- 3 (19/04/08) 3) Raozan -2 (19/06/08) 4) Sikalbaha St- (19/06/08) 5) Ashuganj-3 (13/05/08) 6) Haripur SBU GT-1 (05/06/08)
	7) Ghorasal -1 (22/06/08) 8) 4 units of KPCL

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 755 MW (20:00) of load shed was imposed over the whole area of the national grid.
b) Due to gas limitation, Ghorasal (835 MW), Raozan (180 MW), RPCL (210 MW) and Siddhirganj (190 MW) were limited to 600 MW, 90 MW, 114 MW and 100 MW respectively.	
c) Due to gas limitation, Raozan -2, Sikalbaha Steam & Barge and Shahjibazar - 2 were under shut down.	
d) After maintenance,Ashugonj unit-4 was synchronized at 13:00.	
e) After maintenance Haripur SBU -3 was synchronized at 07:42(03/07/08) on test purpose..	
f) Tongi 230/132 KV To1 transformer tripped at 14:56 showing 'main protection trip and was switched on at 15:18. Again it tripped at 16:10 showing same relay and was switched on at 18:07.	
g) Faridpur 132/33 KV T1 & T2 transformers tripped at 11:47 due to 33KV Magura feeder fault and were switched on at 11:05	Partial power interruption occurred (20 MW) under Faridpur S/S areas from 11:47 to 11:50.
Deputy / Asstt. Manager Load Despatch Division	Manager Load Despatch Division
	Deputy General Manager Load Despatch Circle