6006000 KWHR.

KWHR

DAILY REPORT

Reporting Date : 6-Jul-08 Till now the maximum generation is 4130.0 MW at οn The Summary of Yesterday's (
Day Peak Generation : Today's Actual Min Gen. & Probable Gen. & Demand
Min Gen. at 6:00 2 5-Jul-08) Generation & Demand MW 3141.0 9:00 2763 MW Hour Max Generation 3325 MW **Evening Peak Generation** 3342.6 MW Hour 19:30 Hour E.P. Demand (at gen end) 4150.0 MW 19:30 Max Demand 4300 MW Maximum Generation 3371.5 MW Hour 19:00 Shortage 975 MW Total Gen. (MKWH) 74.74 92.37% 818 MW System L/ Factor Load Shed EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from Ghorasal to Ishurdi :- Maximum 276 MW Import from Ishurdi to Ghorasal:- Maximum MW

Water Level of Kaptai Lake at 6:00 A M of 6-Jul-08 74 95 Actual : Ft.(MSL) Rule curve 84.80 Ft.(MSL)

Oil Consumed : PDB

SKO 0 Liter HSD 271897 Liter

Energy

Energy

579537

FO Liter

Gas Consumed: Total MMCFt. 646.19

Cost of the Consumed Fuel (PDB): Gas Tk13,836,140 Tk50,739,026 Total

Load Shedding & Other Information

Area	Yesterday			Today		
	Actual Shedding (s/s end), MW			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding
	from 18:30	to :	3:20	MW	MW	(On Estimated Demand)
Dhaka	174			1532	315	21%
Chittagong Area	156			470	133	28%
Khulna Area	62			385	96	25%
Rajshahi Area	87			345	82	24%
Comilla Area	29			265	65	25%
Mymensing Area	56			200	45	23%
Sylhet Area	54			155	36	23%
Barisal Area	7			65	16	25%
Rangpur Area	52			190	30	16%
Total	677	(1	9:30) 3607	818	

Information of the Generating machines under maintenance

Planned Shut- Down Forced Shut-Down 1) Khulna 60 MW (05/07/0 1) Ashuganj CCPP ST-(20/10/07) 2) Kaptai- 3 (19/04/08) 9) 4 units of KPCL 3) Raozan -1 (05/07/08) 10) Siddhirganj 210 MW(03/07/08) 4) Sikalbaha St- (19/06/08) 11) Barapukuria -2 (03/07/08) 5) Ashuganj -3 (13/05/08) 6) Haripur SBU GT-1 (03/07/08)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

7) Haripur SBU GT-2 (28/06/08)

a) There was generation shortage in the evening peak hour yesterday

So about 677 MW (19:30) of load shed was imposed over the whole area of the national grid.

b) Due to gas limitation, Ghorasal (835 MW), Raozan (180 MW), RPCL (210 MW) were limited to 590 MW, 90 MW and 161 MW respectively.

- c) Due to gas limitation, Raozan -1, Sikalbaha Steam & Barge Haripur SBU GT-1, 2 and Shahjibazar 2
- were under shut down
- d) Raozan unit -2 was synchronized at 14:11. Again unit -1 was shut down at 16:55 due to gas shortage
- e) After maintenance, Tongi GT was synchronized at 17:51.
- f) After maintenance, Kulshi Bakulia 132 KV line -1 was switched on at 14:05.

Deputy / Asstt Manager Load Despatch Division Manager Load Despatch Division Deputy General Manager Load Despatch Circle