

QF-LDC-08  
Page -1

Description	Forced load shaded / Interrupted Areas
<p>a) There was generation shortage in the evening peak hour yesterday.</p> <p>b) Due to low gas pressure Baghabari 100 MW ,RPCL (210 MW) and Tongi GT were limited to 60 MW,89 MW and 40 MW respectively.</p> <p>c) Ashuganj CCPP GT-1 &amp; ST was forced shut down at 00:20 (1/11/10) &amp; 00:42 (1/11/10) due to turbine air cooler motor trip.</p> <p>d) Baghabari 71 MW was shut down at 06:30(1/11/10) due to filter change and was synchronized at 08:21(1/11/10).</p> <p>e) Ghorasal - Joydevpur 132 KV line-2 tripped at 11:08 showing remote protection relay from Ghorasal end and was switched on at 11:14.</p> <p>f) Kabirpur - Tangail 132 KV line-1 tripped at 11:05 showing main protection ,MVGL E/f relays from and was switched on at 11:30.</p> <p>g) Dohazari - Sikalbaha 132 KV line-1 was under shut down from 08:35 to 15:50 due to dead line checking.</p> <p>h) Hathazari - Raozan 230 KV line-1 was under shut down from 09:43 to 10:58 due to breaker maint.</p> <p>i) Barisal 132/33 KV T1 X-former is under shut down since 07:06(1/11/10).</p>	<p>So about 974 MW (19:00) of load shed was imposed over the whole areas of the national grid .</p>
	<p>Due to generation shortage, about 80 MW (09:00) of load shed has been running since morning (1/11/10) over the whole area (except Sylhet) of the national grid.</p>

Deputy / Asstt. Manager  
Network Operation Division

Manager  
Network Operation Division

Deputy General Manager  
Load Despatch Circle