QF-LDC-08 Page -1

3663000 KWHR.

KWHR.

Liter

Reporting Date: Till now the maximum generation is: - MW at 4130.0 20.00 The Summary of Yesterday's () Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation MW Hour 12:00 Min Gen. at **Evening Peak Generation** 3551.7 1/1/1/ Hour 18:00 Max Generation 3583 MM E.P. Demand (at gen end) : 4100.0 MW Hour 18:00 Max Demand 4050 MW Maximum Generation MW 467 MW 3551.7 Hour 18:00 Shortage Total Gen. (MKWH) System L/ Factor 80.65% 399 MW 68.74 Load Shed EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

210 MW

7:00

Oil Consumed (PDB):

 Import from Ishurdi to Ghorasal: Maximum
 MW
 at

 Water Level of Kaptai Lake at 6:00 A M of
 1-Dec-08

Actual: 84.04 Ft.(MSL). Rule curve: 106.00 Ft.(MSL)

MMCFt

Actual: 84.04 Ft.(MSL), Rule curve: 106.00 Ft.(MSL)

HSD : 245634 Liter FO : 490250 Liter

Energy

Energy

SKO

So about 469 MW (18:00) load shed was imposed over the whole

area of the national grid.

Cost of the Consumed Fuel (PDB): Gas : Tk44,549,253 Oil : Tk12,099,999 Total : Tk56,649,251

Load Shedding & Other Information

602 75

Area	Yesterday			Today		
	Actual Shedding (s/s end), MW		end), MW	Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding
	frtoom 17	:05 2	22:29	MW	MW	(On Estimated Demand)
Dhaka	1	103		1500	87	6%
Chittagong Area		79		446	71	16%
Khulna Area		75		398	63	16%
Rajshahi Area		60		317	50	16%
Comilla Area		57		243	38	16%
Mymensing Area		31		184	29	16%
Sylhet Area		28		148	24	16%
Barisal Area		13		74	12	16%
Rangpur Area		23		155	25	16%
		(
Total	4	169 1	18:00	3465	399	

Information of the Generating machines under maintenance

Planned Shut- Down		Forced Shut- Down		
1) Khulna 60 MW (05/07/06)	1) Kaptai- 3 (19/04/08)	9) Sikalbaha Barge (19/06/08)		
	2) Raozan -1 (19/11/08)	10) Sikalbaha Steam (21/11/08)		
	3) Shajibazar-2 (13/07/08)	11) Haripur SBU GT1 (24/11/08)		
	4) Shajibazar-4 (18/10/08)	12) Ashuganj CCPP GT 2 (27/11/08)		
	5) Ghorasal-1 (30/09/08)	13) Ashuagnj -4 (28/11/08)		
	6) Meghnaghat GT-1 (31/10/08)			
	7) Haripur SBU GT-2 (25/11/08)			
	8) Shajibazar-6 (11/11/08)			

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description Forced load shaded / Interrupted Areas

a) There was generation shortage in the evening peak hour yesterday .

Export from Ghorasal to Ishurdi :- Maximum

Gas Consumed: Total

- b) Due to gas limitation, Sikalbaha Barge & St, Raozan -1, Haripur SBU GT-1& GT-2 and Shahjibazar -2, 4 & 6 are under shut down.
- c) Fenchuganj GT-1 was shut down at 11:38 due to combined mode and was synchronized at 14:20. d) After maintenance Baghabari WMPL unit -1 was synchronized at 12:47.
- e) After maintenance, Ghorasal unit -2 was synchronized at 20:17.
- f) Shahjibazar GT-9 was shut down at 23:30 due to air filter problem . It may be synchronized before evening peak hour today.
- g) Patuakhali 132/33 KV T2 transformer, Gopalganj 132/33 KV T1 transformer, Tangail 132/33 KV T1 transformer, Rangpur Saidpur 132KV line -1, Khulna (C) 132/33 KV T1 transformers were under annua maintenance from 07:03 to 17:12, 07:36 to 15:28, 08:45 to 16:40, 08:57 to 15:52 and 08:58 to 17:33 respectively.
- h) Meghnaghat Comilla (N) 230 KV line -2 tripped at 13:52 from both side showing ' DIST relay' and was switched on at 17:15.
- i) After annual maintenance, Ghorasal Rampura 230 KV line -1 and Ghorasal Ashuganj 230 KV line -1 were switched on at 17:34 and 16:44 respectively.
- j) After annual maintenance, Bogra Palashbari 132 KV line -2, Patuakhali 132/33 KV T2 transformer, Kaptai - Madanhat 132 KV line -1 and Ashuganj - Kishorganj 132 KV line -1 were switched on at 15:44 13:20, 16:05 and 15:10 respectively.
- k) Khulna Ishurdi 230 KV line -1 & 2 were switched on at 14:38 and 14:48 respectively
- I) Comilla (N) Comilla (S) 132 KV line and Comilla (S) 132/33 KV T2 transformer tripped at 02:38 (01/12/08) due to R-phase lightning arrester burst and were switched on at 02:48 and 02:38 respectively
- m) Madanhat Kaptai 132 KV line -1, Bogra Palashbari 132 KV line -1 and Joydevpur S/S Ghorasal P/S 132 KV line -1 are under annual maintenance since 07:33 (01/12/08), 07:33 and 08:27 respectively
- n) Ghorasal Rampura 230 KV line -1, Ghorasal Ashuganj 230 KV line -1 and Haripur (S/S) Haripur Powe Ltd. 230 KV line -2 are under annual maintenance since 07:16 (01/12/08), 07:55 and 08:27 respectively

Manager Load Despatch Division Deputy General Manager Load Despatch Circle

Deputy / Asstt. Manager Load Despatch Division