QF-LDC-08 Page -1

3465000 KWHR.

KWHR.

Liter

Reporting Date: Till now the maximum generation is: - MW at 4130.0 20.00 The Summary of Yesterday's () Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation MW Hour 12:00 Min Gen. at 2292 MW **Evening Peak Generation** 3/187 7 1/1/1/ Hour 18:30 Max Generation 3630 MW E.P. Demand (at gen end) : 4050.0 MW Hour 18:30 Max Demand 4050 MW Maximum Generation 3487.7 MW 18:30 420 MW Hour Shortage Total Gen. (MKWH) System L/ Factor 82.30% 355 MW 68.89 Load Shed EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

240 MW

8:00

Oil Consumed (PDB):

Import from Ishurdi to Ghorasal:- Maximum - MW a

Water Level of Kaptai Lake at 6:00 A M of 3-Dec-08

Actual: 83.97 Ft.(MSL), Rule curve: 105.82 Ft.(MSL)

MMCFt

HSD : 248685 Liter

FO : 503635 Liter

Energy

Energy

SKO

So about 475 MW (18:30) load shed was imposed over the whole

area of the national grid.

Cost of the Consumed Fuel (PDB): Gas : Tk44,870,761 Oil : Tk12,337,840 Total : Tk57,208,601

Load Shedding & Other Information

607 10

Area	Yesterday Actual Shedding (s/s end), MW			Today	
			Estimated Demand(s/s end)	Estimated Shedding (s/s end	Rates of Shedding
	fr to m 17:05	22:17	MW	MW	(On Estimated Demand)
Dhaka	114		1484	70	5%
Chittagong Area	79		440	64	15%
Khulna Area	73		393	58	15%
Rajshahi Area	54		313	46	15%
Comilla Area	53		240	35	15%
Mymensing Area	28		182	27	15%
Sylhet Area	33		145	21	14%
Barisal Area	14		73	11	15%
Rangpur Area	27		153	23	15%
	(
Total	475	18:30	3423	355	

Information of the Generating machines under maintenance

Planned Shut- Down		Forced Shut- Down
1) Khulna 60 MW (05/07/06)	1) Kaptai- 3 (19/04/08)	9) Sikalbaha Barge (19/06/08)
	2) Raozan -1 (19/11/08)	10) Sikalbaha Steam (21/11/08)
	3) Shajibazar-2 (13/07/08)	11) Haripur SBU GT1 (24/11/08)
	4) Shajibazar-4 (18/10/08)	12) Ashuganj CCPP GT 2 (27/11/08)
	5) Ghorasal-1 (30/09/08)	
	6) Meghnaghat GT-1 (31/10/08)	
	7) Haripur SBU GT-2 (25/11/08)	
	8) Shaiibazar-5 (22/11/08)	

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description Forced load shaded / Interrupted Areas

a) There was generation shortage in the evening peak hour yesterday .

Export from Ghorasal to Ishurdi :- Maximum

Gas Consumed: Total

- b) Due to gas limitation, Sikalbaha Barge & St, Raozan -1, Haripur SBU GT-1& GT-2 and Shahjibazar -2,
 4 & 5 are under shut down.
- c) After maintenance, Ghorasal unit -4 was synchronized at 21:24 and unit -2 was shut down at 23:10 due to boiler tube leakage.
- d) RPCL unit -2 was shut down at 03:20 due to combustion inspection.
- e) Khulna (C) 132/33 KV T2 transformer was under annual maintenance from 09:14 to 14:04.
- f) Tongi Aminbazar 230 KV line -1, Haripur S/S Haripur Power Ltd. 230 KV line -1 were under annual maintenance from 08:45 to 13:43 and 08:48 to 13:32 respectively.
- g) After annual maintenance, Patuakhali 132/33 KV T3 transformer, Gopalganj 132/33 KV T2 transformer, Fenchuganj Sreemongal 132 KV line -1, Jessore Jhenidaha 132 KV line -2, Ashuganj Kishorganj 132 KV line -1 and Mymensing Jamalpur 132 KV line -1 were switched on at 16:21, 14:07, 15:17, 16:21 16:13 and 16:14 respectively.
- h) After annual maintenance, Ghorasal Ashuganj 230 KV line -1 and Rampura Ghorasal 230 KV line -1 were switched on at 17:03 and 17:08 respectively.
- i) Comilla (N) 132/33 KV T04 transformer was under shut down from 09:21 to 17:11 for oil centrifuging
- k) Manikganj 132/33 KV GT-3 transformer was under shut down from 10:15 to 14:45 for insulation test
 j) Ishurdi 132/33 KV T1 transformer was under shut down from 10:25 to 14:04 due to parallel operation with new installed transformer.
- k) Madanhat 132/33 KV T1, T2 and T3 transformers were under shut down from 10:18 to 11:46 for parallel Operation.
- I) Ashuganj Ghorasal 230 KV line -1 is under annual maintenance since 07:25 (03/12/08)
- m) Patuakhali 132/33 KV T3 transformer, Fenchuganj Sreemongal 132 KV line -2, Mymensing Jamalpur 132 KV line -1 and Ashuganj Kishorganj 132 KV line are under annual maintenance since 07:15 (03/12/08), 07:45, 08:05, and 08:18 respectively.

Deputy / Asstt. Manager Load Despatch Division Manager Load Despatch Division Deputy General Manager Load Despatch Circle