QF-LDC-08 Page -1

KWHR.

Reporting Date : 11-Dec-08 Till now the maximum generation is: - MW at 4130.0 20:00 The Summary of Yesterday's ( ) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation MW Hour 9:00 Min Gen. at 1808 MW **Evening Peak Generation** 3398 5 1/1/1/ Hour 19:00 Max Generation 3652 MM E.P. Demand (at gen end) : 3398.5 MW Hour 19:00 Max Demand 3500 MW Maximum Generation 3398.5 MW 19:00 Shortage 0 MW Hour Total Gen. (MKWH) 63.98% System L/ Factor Load Shed - MW 52.19 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from Ghorasal to Ishurdi :- Maximum 396 MW 19:30 Energy 3432000 KWHR.

Import from Ishurdi to Ghorasal:- Maximum - MW at

Water Level of Kaptai Lake at 6:00 A M of 11-Dec-08

Actual: 83.65 Ft.(MSL), Rule curve: 105.10 Ft.(MSL)

MMCFt

Oil Consumed (PDB): SKO: 0 Liter

Forced load shaded / Interrupted Areas

HSD : 122228 Liter FO : 461839 Liter

Load Despatch Circle

Energy

Cost of the Consumed Fuel (PDB): Gas : Tk35,692,617 Oil : Tk8,635,662 Total : Tk44,328,279

## **Load Shedding & Other Information**

482 92

Gas Consumed: Total

Description

Load Despatch Division

Area	Yesterday	Today		
	Actual Shedding (s/s end), MW	Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding
	frtom	MW	MW	(On Estimated Demand)
Dhaka	-	1427	-	-
Chittagong Area	-	395	-	-
Khulna Area	-	352	-	-
Rajshahi Area	-	280	-	-
Comilla Area	-	214	-	-
Mymensing Area	-	162	-	-
Sylhet Area	-	130	-	-
Barisal Area	-	65	-	-
Rangpur Area	-	136	-	-
	(			
Total	0	3161	0	

## Information of the Generating machines under maintenance

Planned Shut- Down		Forced Shut- Down		
1) Khulna 60 MW (05/07/06)	1) Kaptai- 3 (19/04/08)	9) Sikalbaha Barge (19/06/08)		
1) Kilulia 60 MW (05/07/06)				
	2) Raozan -2 (09/12/08)	10) Meghnaghat GT-2 - (09/12/08)		
	3) Shajibazar-2 (13/07/08)	11) Ashuganj - 2 (08/12/08)		
	4) Shajibazar-4 (18/10/08)			
	5) Ghorasal-1 (30/09/08)			
	6) Meghnaghat GT-1 (31/10/08)			
	7 ) Haripur SBU GT-2 (25/11/08)			
	8) Shajibazar-5 (22/11/08)			

## Additional Information of Machines. lines. Interruption / Forced Load shed etc.

a) There was no generation shortage in the evening peak hour yesterday .

b) Due to gas limitation, Sikalbaha Barge & St, Raozan -2, Haripur SBU GT-2 and Shahjibazar -2, 4, & 5 are under shut down.

c) Sikalbaha Steam was synchronized at 13:08 but it tripped at 14:04 due to feed pump trip and was synchronized at 18:52.
d) After maintenance, Shahjibazar GT-8 and GT-9 were synchronized at 14:04 and 13:25 respectively.
e) After maintenance, Shahjibazar GT-8 and GT-9 were synchronized at 17:08.
f) Raozan unit -1 was synchronized at 19:26.
g) After maintenance, Cornilla (N) - Meghnaghat 230 KV line -1 was switched on at 20:25.
h) After project work, Hasnabad - Meghnaghat 230 KV line -2 was switched on at 20:27. Again it is under shut down since 07:16 (11/12/08) due to the same reason.
j) Meghnaghat - Haripur 230 KV line -1 is under shut down since 07:12 (11/12/08) for project work

Deputy / Asstt. Manager

Deputy General Manager

Load Despatch Division