

DAILY REPORT

Till now the maximum generation is :-		4130.0 MW	at	20:00	on	Reporting Date : 23-Apr-08
The Summary of Yesterday's (22-Apr-08)		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand		
Day Peak Generation :	3519.0	MW	Hour :	11:00	Min Gen. at 8:00	3539 MW
Evening Peak Generation :	3794.3	MW	Hour :	20:00	Max Generation :	3808 MW
E.P. Demand (at gen end) :	4650.0	MW	Hour :	20:00	Max Demand :	4700 MW
Maximum Generation :	3794.3	MW	Hour :	20:00	Shortage :	892 MW
Total Gen. (MKWH) :	83.34	System L/ Factor :		91.52%	Load Shed :	773 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR					
Export from Ghorasal to Ishurdi :-	Maximum	396 MW	at	21:00	Energy 8992500 KWHR.
Import from Ishurdi to Ghorasal:-	Maximum	-	MW	at -	Energy - KWHR.
Water Level of Kaptai Lake at 6:00 A M of 23-Apr-08					
Actual :	77.43	Ft.(MSL) ,	Rule curve :	83.60	Ft.(MSL)

Oil Consumed :			
PDB	SKO :	0	Liter
	HSD :	323397	Liter
	FO :	404703	Liter

Gas Consumed : Total	751.39	MMCFt.				
Cost of the Consumed Fuel (PDB) : Gas :		Tk27,989,907	Oil :	Tk13,041,603	Total :	Tk41,031,510

Load Shedding & Other Information

Area	Yesterday				Today			
	Actual Shedding (s/s end), MW				Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)	
	from	18:20	to	0:00				
Dhaka		216			1660	283	17%	
Chittagong Area		154			490	97	20%	
Khulna Area		150			430	86	20%	
Rajshahi Area		47			415	86	21%	
Comilla Area		44			330	69	21%	
Mymensing Area		22			250	51	20%	
Sylhet Area		37			185	37	20%	
Barisal Area		41			79	16	20%	
Rangpur Area		31			235	48	20%	
Total		742	(20:00)	4074	773	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	1) Haripur SBU GT-3 (25/05/06) 2) Ashuganj CCPP St-(20/10/07) 3) Ghorasal unit -3 (03/04/08) 4) Haripur SBU GT-2 (12/04/08) 5) Shahjibazar -2 (09/04/08) 6) Kaptai unit-3 (19/04/08) 8) Bheramara -2 (18/04/08) 9) 4 units of KPCL(22/04/08)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 742 MW (20:00) of load shed was imposed over the whole area of the national grid.
b) Due to gas limitation, Raozan (420 MW), RPCL (210 MW) and Siddhirganj (210 MW) were 260 MW, 124 MW and 115 MW respectively.	
c) Due to gas limitation, Haripur SBU GT-2, Sikalbaha Barge, Shahjibazar -2 and Ghorasal -3 were under shut down.	
d) After maintenance, Barapukuria unit -2 was synchronized at 12:54.	
e) Ashuganj GT-1 tripped at 21:54 showing 'Combustion abnormality' and was synchronized at 22:58.	
f) Sylhet GT was forced shut down at 00:01 (23/04/08) due to bearing temperature high. It may be synchronized before evening peak hour today.	
g) After installation of optical fiber, Halisahar - Julda 132 KV line was switched on at 16:38. Again it is under shut down since 06:25 (23/04/08) due to the same reason.	
h) Ashuganj 230/132 KV OAT11 transformer is under shut down since 06:32 (23/04/08) due to installation of DFDR.	
	Due to generation shortage, about 230 MW of load shed has been running since morning (23/04/08) over the whole area of the national grid.

Deputy / Asstt. Manager
Load Despatch DivisionManager
Load Despatch DivisionDeputy General Manager
Load Despatch Circle