

DAILY REPORT

Till now the maximum generation is :-		4130.0 MW	at	20:00	on	Reporting Date : 26-Apr-08
The Summary of Yesterday's (25-Apr-08)		Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand		
Day Peak Generation :	3428.5	MW	Hour :	9:00	Min Gen. at 6:00	3357 MW
Evening Peak Generation :	3597.2	MW	Hour :	20:00	Max Generation :	3603 MW
E.P. Demand (at gen end) :	4450.0	MW	Hour :	20:00	Max Demand :	4550 MW
Maximum Generation :	3600.6	MW	Hour :	22:00	Shortage :	947 MW
Total Gen. (MKWH) :	81.41	System L/ Factor :		94.21%	Load Shed :	818 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR					
Export from Ghorasal to Ishurdi :-	Maximum	348 MW	at 19:30	Energy	8415000 KWHR.
Import from Ishurdi to Ghorasal:-	Maximum	-	MW at -	Energy	- KWHR.
Water Level of Kaptai Lake at 6:00 A M of 26-Apr-08					
Actual :	76.03	Ft.(MSL) ,	Rule curve :	83.00	Ft.(MSL)

Oil Consumed :

PDB :

SKO :

HSD :

FO :

0

418583

0

Liter

Liter

Liter

Gas Consumed : Total	741.70	MMCFt.					
Cost of the Consumed Fuel (PDB) : Gas :			Tk30,342,052	Oil :	Tk10,594,323	Total :	Tk40,936,376

Load Shedding & Other Information

Area	Yesterday				Estimated Demand(s/s end)	MW	Today	
	Actual Shedding (s/s end), MW						Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	from	18:30	to	0:00				
Dhaka		167				1610	310	19%
Chittagong Area		150				479	110	23%
Khulna Area		164				420	96	23%
Rajshahi Area		67				395	85	22%
Comilla Area		40				315	70	22%
Mymensing Area		32				240	52	22%
Sylhet Area		47				175	36	21%
Barisal Area		41				75	16	21%
Rangpur Area		28				220	43	20%
Total		736	(20:00)	3929	818	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	8) Khulna 110 MW (24/04/08)
	9) NEPC # 4
	1) Haripur SBU GT-3 (25/05/06)
	2) Ashuganj CCPP St-(20/10/07)
	3) Haripur SBU GT-2 (12/04/08)
	4) Shahjibazar -4 (23/04/08)
	5) Kaptai unit-3 (19/04/08)
	6) Bheramara -2 (18/04/08)
	7) 4 units of KPCL(22/04/08)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 736 MW (20:00) of load shed was imposed over the whole area of the national grid.
b) Due to gas limitation, Ghorasal (835 MW), Ashuganj (646 MW), Raozan (360 MW), RPCL (210 MW) Tongi (80MW), Baghabari (171 MW), WMPL (90 MW) and Siddhirganj (190 MW) were limited to 510 MW, 549 MW, 260 MW, 126 MW, 60 MW, 168 MW, 56 MW and 100 MW respectively.	
c) Due to gas limitation, Haripur SBU GT-2, Sikalbaha Barge and Shahjibazar -4 were under shut down.	
d) Ghorasal unit -3 was synchronized at 12:52.	
e) After installation of DFDR Ashuagnj - Ghorasal 230 KV line -2 was switched on at 09:29. Again line -1 was under shut down from 09:30 to 10:36 due to the same reason.	
f) Fenchuganj P/S - Fenchuganj S/S 132 KV line -1 and 2 were under shut down from 11:04 to 12:03 and 12:07 to 12:52 respectively due to CVT checking by carrier division.	
g) After maintenance, Halisahar 132 KV bus was switched on at 11:43.	
h) After maintenance, Kabirpur 132/ 33 KV T1 transformer was switched on at 12:05.	
i) Baraulia - Abul Khair 132KV line is under shut down since 07:30 (26/04/08) due to installation of optical fiber.	Due to generation shortage, about 150 MW of load shed has been running since morning (26/04/08) over the whole area of the national grid.

Deputy / Asstt. Manager
Load Despatch DivisionManager
Load Despatch DivisionDeputy General Manager
Load Despatch Circle