

Reporting Date : 4-May-08
17-Sep-07

4130.0 MW at 20:00 on

	Oil Consumed :			
	PDB	SKO :	0	Liter
		HSD :	235955	Liter
		FO :	0	Liter

Gas Consumed : Total	673.03	MMCFt.					
Cost of the Consumed Fuel (PDB) :	Gas :		Tk34,919,477	Oil :	Tk5,972,021	Total :	Tk40,891,498

Area	Yesterday		Today		
	Actual Shedding (s/s end), MW		Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	from 18:30	to 22:10			
Dhaka	96		1470	241	16%
Chittagong Area	108		450	105	23%
Khulna Area	146		395	90	23%
Rajshahi Area	31		380	88	23%
Comilla Area	38		298	69	23%
Mymensing Area	28		230	53	23%
Sylhet Area	43		168	38	23%
Barisal Area	45		72	17	24%
Rangpur Area	25		215	47	22%
Total	560	(19:30)	3678	748	

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	9) Khulna 110 (01/05/08)
2) Haripur SBU GT-3 (25/05/05)	10) Shahjibazar GT-2 (30/04/08)
3) Ashuganj CCP St-(20/10/07)	11) Barupukuria unit-1(03/05/08)
4) Haripur SBU GT-2 (12/04/08)	12) 4 units of KPCL
5) Shahjibazar -4 (23/04/08)	
6) Kaptai unit-3 (19/04/08)	
7) Bheramara -2 (18/04/08)	
8) NEPC # 4	
9) Ashuganj 3-(28/04/08)	

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 560 MW (19:30) of load shed was imposed over the whole area of the national grid.
b) Due to gas limitation, Ghorasal (835 MW), Raozan (360 MW), RPCL (210 MW), Tongi (80MW), Baghabari (171 MW), WMPL (90 MW) and Siddhirganj (190 MW) were limited to 640 MW, 280 MW, 180 MW, 50MW, 146 MW, 70 MW and 105 MW respectively.	
c) Due to gas limitation, Haripur SBU GT-2, Sikalbaha Barge and Shahjibazar -2, 4 were under shut down.	
d) Tongi GT tripped at 10:39 due to phase cooler temperature high and was synchronized at 16:08.	
e) Barapukuria unit -1 was forced shut down at 16:51 due to maintenance of coal mill .	
f) Khulna KPCL unit tripped at 20:18 due to voltage fluctuation and was synchronized at 20:25. But it tripped again at 06:19 (04/05/08) due to the same reason and was synchronized at 06:23.	
g) Baghabari GT-1 (71 MW) was shut down at 07:14 (04/05/08) due to filter change . It may be synchronized before evening peak hour today.	
h) Kaptai unit -4 was shut down at 07:30 (04/05/08) due to monthly maintenance. It may be synchronized before evening peak hour today.	
i) Rajshahi 132 KV main bus was under shut down from 10:35 to 11:15 due to red-hot maintenance of R & B- phase isolator loop.	
j) Haripur 132 KV bus section -III (main bus) was under shut down from 09:50 to 13:10 due to re-connection of loop joint of TR3 transformer.	
k) Ishurdi - Natore 132 KV line -1 was under shut down from 13:11 to 16:05 due to conductor maintenance between tower no.- 269 and 270.	
l) Hasnabad 132/33 KV T6 transformer was under shut down from 10:51 to 12:55 due to oil leakage.	
m) Hathazari 132/33 KV T1 and T2 transformers were under shut down from 08:51 to 13:20 and 08:55 to 13:33 respectively for project work by greater Chittagong division.	Power interruption (27 MW) occurred under Hathazari S/S areas from 08:51 to 13:20.
n) Barisal - Bhandaria 132 KV line tripped at 20:43 from Bhandaria S/S end due to heavy rain and storm showing ' E/F at B-phase' . At the same time , Bagerhat - Bhandaria 132 KV line also tripped from Bagerhat S/S end showing same relay and were switched on at 21:37 and 21:15 respectively. But again they tripped at 20:17 and 21:23 respectively due to the same reason and were switched on at 21:45 and 21:27 respectively. Barisal - Bhandaria 132 KV line tripped from Barisal end at 21:28 showing ' E/F at B-phase' and it is now under maintenance.	Power interruption (10 MW) occurred under Bhandaria S/S areas from for 12 and 24 minutes respectively.
o) Haripur -Comilla (N) 132 KV line is under shut down since 06:39 (04/05/08) for project work.	
p) Bhandaria 132/33 KV T2 transformer tripped at 21:47 due to C-phase lightning arrester burst . It is now under maintenance	

Deputy General Manager
Load Despatch Circle