POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTEF DAILY REPORT

Reporting Date : 12-Nov-10 Till now the maximum generation is : -4698.5 MW at 21:00 Hrs on 20-Aug-10 The Summary of Yesterday's (11-Nov-10) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 3326.2 MW 3154 MW Hour 10:00 Min Gen. at 7:00 Evening Peak Generation : 3744.6 MW Hour : 20:00 Max Generation 3819 MW E.P. Demand (at gen end) : 5000.0 MW 4900 MW Hour : 20:00 Max Demand 3744.6 MW 1081 MW Maximum Generation Hour : 20:00 Shortage Total Gen. (MKWH) 85.41% 73.76 System L/ Factor Load Shed 969 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 430 MW 7:00 Energy 8410000 KWHR. at Import from West grid to East grid :- Maximum MW KWHR. Energy at Water Level of Kaptai Lake at 6:00 A M of 12-Nov-10 104.73 107.90 Ft.(MSL) Actual : Ft.(MSL) Rule curve : Gas Consumed : Total 624.42 MMCFt. Oil Consumed (PDB) : HSD : 1779433 Liter FO 0 Liter Tk46,150,882 Oil : Tk71,177,322 Total : Tk117,328,204

Cost of the Consumed Fuel (PDB): Gas

Load Shedding & Other Information

Area	Yesterday			Today	
			Estimated Demand(s/s end)	Estimated Shedding (s/s e	Rates of Shedding
	MW		from toMW	MW	(On Estimated Demand)
Dhaka	412	(17:05-00:23 gen. shortage)	1895	382	20%
Chittagong Area	163	(17:05-23:58 gen. shortage)	542	137	25%
Khulna Area	143	(17:05-23:27 gen. shortage)	495	125	25%
Rajshahi Area	123	(17:05-23:37 gen. shortage)	406	102	25%
Comilla Area	96	(17:05-23:57 gen. shortage)	321	81	25%
Mymensing Area	72	(17:05-23:31 gen. shortage)	208	52	25%
Sylhet Area	19	(17:05-22:54 gen. shortage)	204	9	4%
Barisal Area	30	(17:05-23:27 gen. shortage)	96	24	25%
Rangpur Area	67	(17:05-23:24 gen. shortage)	227	57	25%
Total	1125	20:00	4394	969	

Information of the Generating machines under shut down.

Planned Shut- Down		Forced Shut-Down	
1) Haripur SBU GT-3 (18/06/09)	8) Megnaghat P. Itd GT-1(7/11/10)	1) Ghorasal 6(18/07/10)	
2) Ghorasal 2(26/04/10)	9) Barapukuria-1(09/11/10)	2) Shahjibazar GT-9(13/10/10)	
3) Siddirganj GT-1 (18/06/10)		3) Khulna 60 MW (27/10/10)	
4) Ashuganj-4(12/09/10)		4) Ashuganj-1(09/11/10)	
5) Raozan-1 (03/10/10)			
6) Sikalbaha GT (24/10/10)			
7) Raozan-2 (21/10/10)			

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

 a) There was generation shortage in the evening peak hour yesterday. b) Due to low gas pressure Baghabari WMPP 90 MW and RPCL (210 MW) were limited to 70 MW and 107 MW respectively. c) Baghabari GT-2 tripped at 08:50 due to problem of control circuit and was synchronized at 18:53. d) Baghabari WMPP #1 tripped at 11:37 due to bearing temperature high and was synchronized at 18:69. e) After maintenance Khulna 110 MW was synchronized at 13:32. f) Kaptai #3 tripped at 11:08 due to trip of station supply and was synchronized at 11:55. g) Haripur NEPC #5 tripped at 21:10 due to fuel line burst. n) Ishurdi - Khulna(s) 230 KV line-2 was shut down at 08:11 due to annual maintenance and was switched on at 16:50. j) Natore - Bogra 132 KV line-2 was shut down at 08:10 due to annual maintenance and was switched on at 16:56. j) Madanhat - Hathazari 132 KV line-1 was shut down at 09:49 due to annual maintenance 	So about 1125 MW (20:00) of load shed was imposed over the whole areas of the national grid .
limited to 70 MW and 107 MW respectively. b) Baghabari GT-2 tripped at 08:50 due to problem of control circuit and was synchronized at 18:53. c) Baghabari WMPP #1 tripped at 11:37 due to bearing temperature high and was synchronized at 18: c) After maintenance Khulna 110 MW was synchronized at 13:32. c) Kaptai #3 tripped at 11:08 due to trip of station supply and was synchronized at 11:55. c) Haripur NEPC #5 tripped at 21:10 due to fuel line burst. c) Ishurdi - Khulna(s) 230 KV line-2 was shut down at 08:11 due to annual maintenance and was switched on at 16:50. Natore - Bogra 132 KV line-2 was shut down at 08:10 due to annual maintenance and was switched on at 16:56.	whole areas of the national grid .
Baghabari GT-2 tripped at 08:50 due to problem of control circuit and was synchronized at 18:53. Baghabari WMPP #1 tripped at 11:37 due to bearing temperature high and was synchronized at 18: After maintenance Khulna 110 MW was synchronized at 13:32. Kaptai #3 tripped at 11:08 due to trip of station supply and was synchronized at 11:55. Haripur NEPC #5 tripped at 21:10 due to fuel line burst. I shurdi - Khulna(s) 230 KV line-2 was shut down at 08:11due to annual maintenance and was switched on at 16:50. Natore - Bogra 132 KV line-2 was shut down at 08:10 due to annual maintenance and was switched on at 16:56.	
) Baghabari WMPP #1 tripped at 11:37 due to bearing temperature high and was synchronized at 10) After maintenance Khulna 110 MW was synchronized at 13:32. Kaptai #3 tripped at 11:08 due to trip of station supply and was synchronized at 11:55.) Haripur NEPC #5 tripped at 21:10 due to fuel line burst.) Ishurdi - Khulna(s) 230 KV line-2 was shut down at 08:11due to annual maintenance and was switched on at 16:50. Natore - Bogra 132 KV line-2 was shut down at 08:10 due to annual maintenance and was switched on at 16:56.	
Baghabari WMPP #1 tripped at 11:37 due to bearing temperature high and was synchronized at 10 After maintenance Khulna 110 MW was synchronized at 13:32. Kaptai #3 tripped at 11:08 due to trip of station supply and was synchronized at 11:55. Haripur NEPC #5 tripped at 21:10 due to fuel line burst. I shurdi - Khulna(s) 230 KV line-2 was shut down at 08:11due to annual maintenance and was switched on at 16:50. Natore - Bogra 132 KV line-2 was shut down at 08:10 due to annual maintenance and was switched on at 16:56.	
After maintenance Khulna 110 MW was synchronized at 13:32. Kaptai #3 tripped at 11:08 due to trip of station supply and was synchronized at 11:55. Haripur NEPC #5 tripped at 21:10 due to fuel line burst. Ishurdi - Khulna(s) 230 KV line-2 was shut down at 08:11due to annual maintenance and was switched on at 16:50. Natore - Bogra 132 KV line-2 was shut down at 08:10 due to annual maintenance and was switched on at 16:56.	6:34.
Haripur NEPC #5 tripped at 21:10 due to fuel line burst. Ishurdi - Khulna(s) 230 KV line-2 was shut down at 08:11due to annual maintenance and was switched on at 16:50. Natore - Bogra 132 KV line-2 was shut down at 08:10 due to annual maintenance and was switched on at 16:56.	
Ishurdi - Khulna(s) 230 KV line-2 was shut down at 08:11due to annual maintenance and was switched on at 16:50. Natore - Bogra 132 KV line-2 was shut down at 08:10 due to annual maintenance and was switched on at 16:56.	
and was switched on at 16:50. Natore - Bogra 132 KV line-2 was shut down at 08:10 due to annual maintenance and was switched on at 16:56.	
Natore - Bogra 132 KV line-2 was shut down at 08:10 due to annual maintenance and was switched on at 16:56.	
and was switched on at 16:56.	
Madanhat - Hathazari 132 KV line-1 was shut down at 09:49 due to annual maintenance	
ind was switched on at 15:53.	
Mirpur - Uttara 132 KV line was shut down at 09:49 due to annual maintenance	
and was switched on at 17:17.	
Tongi 132 KV bus-2 was shut down at 09:03 due to annual maintenance and was switched on at 16:56.	
) Noapara 132 KV bus-2 was shut down at 10:45 due to annual maintenance	
and was switched on at 16:51.	
Rampura 230 KV bus-1 was shut down at 09:29 due to annual maintenance	
and was switched on at 13:56	
Ishurdi - Khulna 230 KV line-1 & 2 are under shut down at 08:09(12/11/10) & 08:10(12/11/10)	
espectively due to annual maintenance.	
Deputy / Asstt. Manager	

QF-LDC-08 Page -1