QF-LDC-08 Page -1

Reporting Date: Till now the maximum generation is: - MW at 4130.0 20.00

The Summary of Yesterday's (10-Nov-08) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation MW Hour 11:00 Min Gen. at 2440 MW **Evening Peak Generation** 3681 2 1/1/1/ Hour 19:30 Max Generation 3600 M/M E.P. Demand (at gen end) 4150.0 MW Hour 19:30 Max Demand 4150 MW Maximum Generation MW 19:30 460 MW 3681.2 Hour Shortage Total Gen. (MKWH) 80.46% 397 MW 71.08 System L/ Factor Load Shed EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from Ghorasal to Ishurdi :- Maximum 312 MW

20:00 Energy 4422000 KWHR. Import from Ishurdi to Ghorasal:- Maximum MW Energy KWHR.

Water Level of Kaptai Lake at 6:00 A M of 11-Nov-08 85.00 108.00 Ft.(MSL) Actual Ft.(MSL) Rule curve

Gas Consumed: Total 653.06 MMCFt Oil Consumed (PDB): SKO Liter HSD 200815 Liter

FO 534094 Liter

Tk59,759.410 Cost of the Consumed Fuel (PDB): Gas Tk48 267 665 Oil : Tk11.491.746 Total

Load Shedding & Other Information

Area	Yesterday			Today		
	Actual Shedding (s/s end), MW		g (s/s end), MW	Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding
	frtom	17:15	22:03	MW	MW	(On Estimated Demand)
Dhaka		154		1554	88	6%
Chittagong Area		64		461	70	15%
Khulna Area		42		412	63	15%
Rajshahi Area		37		328	50	15%
Comilla Area		34		252	39	15%
Mymensing Area		24		190	28	15%
Sylhet Area		26		153	24	16%
Barisal Area		11		76	11	14%
Rangpur Area		13		160	24	15%
		(
Total		405	19:30	3586	397	

Information of the Generating machines under maintenance

Planned Shut- Down		Forced Shut- Down		
1) Khulna 60 MW (05/07/06)	1) Kaptai- 3 (19/04/08)	7) Barapukuria -1 (29/10/08)		
	2) Raozan -2(02/11/08)	8) Fenchuganj GT-2 (01/11/08)		
	3) Sikalbaha St- (19/06/08)	9) Meghnaghat GT-1 (31/10/08)		
	4) Shajibazar-2 (13/07/08)	10) Haripur SBU GT-2 (02/11/08)		
	5) Shajibazar-4 (18/10/08)	11) Haripur SBU GT-3 (03/11/08)		
	6) Ghorasal-1 (30/09/08)			

Additional Information of Machines. lines. Interruption / Forced Load shed etc

Description Forced load shaded / Interrupted Areas

a) There was generation shortage in the evening peak hour yesterday

- So about 405 MW (19:30) of load shed was imposed over the whole area of the national grid.
- b) Due to gas limitation, Raozan -2, Haripur SBU GT-2, GT-3, Sikalbaha Steam and Shahjibazar -2, 4 are under shut down
- c) Tongi Mirpur 132 KV line, Feni Chowmuhani 132 KV line -2, Sreemongal Fenchugani 132 KV line -1, Thakurgaon 132/33 KV T2 transformer, Pabna 132/33 KV T2 transformer, Jessore 132/33 KV T3 transformer, Mongla 132/33 KV T1 transformer and Madaripur 132/33 KV T2 transformers were under annual maintenance from 08:28 to 16:00, 08:24 to 18:04, 08:25 to 17:33, 09:05 to 15:20, 09:03 to 15:15, 08:21 to 14:03, 09:16 to 16:35 and 09:34 to 16:40 respectively.
- d) After annual maintenance, Joydevpur 132/33 KV GT-3 transformer, Faridpur 132/33 KV T2 transformer, Satkhira 132/33 KV T1 transformer, Netrokona 132/33 KV T1 transformer and Jamalpur 132/33 KV T1 transformers were switched on at 15:52, 15:10, 19:22, 16:42 and 16:20 respectively
- e) Ishurdi 230/132 KV T03 transformer was under annual maintenance from 08:18 to 17:30
- f) Palashbari 132/33 KV T1 transformer was under shut down from 09:38 to 09:58 due to gas filling at 33 KV breaker.
- g) Faridpur Bheramara 132 KV line -2 was under shut down from 10:50 to 15:10 due to red-hot maintenance of tower no.-28.
- h) Hathazari Raozan 230 KV line -1 was under shut down from 09:45 to 12:52 due to red- hot maintenance of isolator at Hathazari end.
- i) Satkhira 132/33 KV T2 transformer, Faridpur 132/33 T2 transformer, Jamalpur 132/33 KV T1 transformer and Feni - Chowmuhani 132 KV line -2 are under shut down since 07:08 (11/11/08), 07:06, 08:07 and 08:23 respectively.
- j) Haripur Rampura 230 KV line -1 and Ishurdi 230/132 KV T03 transformers are under shut down since 08:03 (11/11/08) and 08:23 respectively.

Deputy / Asstt. Manager Load Despatch Division

Manager Load Despatch Division Deputy General Manager Load Despatch Circle