

QF-LDC-08  
Page -1

The Summary of Yesterday's (	26-Nov-08	) Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand		
Day Peak Generation :	2851.0	MW	Hour :	12:00	Min Gen. at 4:00	2228 MW
Evening Peak Generation :	3523.0	MW	Hour :	18:00	Max Generation :	3704 MW
E.P. Demand (at gen end) :	4100.0	MW	Hour :	18:00	Max Demand :	4100 MW
Maximum Generation :	3523.0	MW	Hour :	18:00	Shortage :	396 MW
Total Gen. (MKWH) :	66.89	System L/ Factor :		79.12%	Load Shed	340 MW

Export from Ghorasal to Ishurdi :- Maximum	252 MW	at 6:00	Energy	3663000 KWHR.
Import from Ishurdi to Ghorasal:- Maximum	-	at -	Energy	- KWHR.

		Water Level of Kaptai Lake at 6:00 A M of		27-Nov-08	
Actual :	84.20	Ft.(MSL) ,		Rule curve :	106.40 Ft.(MSL)

Cost of the Consumed Fuel (PDB): Gas	: Tk43,889,236	Oil	: Tk11,238,821	Total	: Tk55,128,057
--------------------------------------	----------------	-----	----------------	-------	----------------

Area	Yesterday		Today		
	Actual Shedding (s/s end), MW		Estimated Demand (s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	from 17:00	22:10			
Dhaka	148		1524	62	4%
Chittagong Area	83		453	63	14%
Khulna Area	63		404	56	14%
Rajshahi Area	58		322	45	14%
Comilla Area	55		247	34	14%
Mymensing Area	24		187	26	14%
Sylhet Area	29		150	21	14%
Barisal Area	11		75	11	15%
Rangpur Area	24		157	22	14%
	(				
<b>Total</b>	<b>495</b>	<b>18:00</b>	<b>3519</b>	<b>340</b>	

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	8) Shajibazar-6 (11/11/08)
2) Kaptai- 3 (19/04/08)	9) Sikalbaha Barge (19/06/08)
3) Raozan -1 (19/11/08)	10) Sikalbaha Steam (21/11/08)
4) Shajibazar-2 (13/07/08)	11) Ashuiganj -4 (22/11/08)
5) Shajibazar-4 (18/10/08)	12) Haripur SBU GT1 (24/11/08)
6) Ghorasal-1 (30/09/08)	
7) Meghnaghat GT-1 (31/10/08)	
8) Haripur SBU GT-2 (25/11/08)	

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	: So about 495 MW (18:00) load shed was imposed over the whole area of the national grid.
b) Due to gas limitation, Sikalbaha Barge & St, Raozan -1, Haripur SBU GT-1& GT-2 and Shahjibazar -2, 4 & 6 are under shut down.	
c) After maintenance Baghabari WMPL unit -1 was synchronized at 17:54.	
d) Ghorasal unit-2 tripped at 16:25 due to tripping of sealing oil pump and was synchronized at 17:05.	
e) Sylhet rental was under shut down from 16:30 to 17:16 due to circuit breaker problem.	
f) After annual maintenance, Patuakhali 132/33 KV T1 transformer and Madanhat - Kaptai 132 KV lines were switched on at 16:10 and 14:50 respectively.	
g) Uttara 132/33 KV GT1 transformer, Sreemongal - Shahjibazar 132 KV line-1 Saidpur 132 KV bus -A and Jessore - Jhenidaha 132 KV line -2 were under annual maintenance from 08:31 to 18:47, 08:40 to 15:07 and 09:30 to 16:40 respectively.	
h) Madanhat - Kaptai 132 KV line -1 and Rampura - Ghorasal 230 KV line-1, are under annual maintenance since 07:13 (27/11/08) and 07:42 respectively.	

Deputy General Manager  
Load Despatch Circle