POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER. LDC.DHAKA DAILY REPORT

Ft.(MSL)

88.51

QF-LDC-08 Page -1

Reporting Date: 29-Mar-10 Till now the maximum generation is: 4296.0 MW at 28-Mar-10 The Summary of Yesterday's () Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand 3532.0 MW Day Peak Generation Min Gen. at 3340 ΜW Hour 9:00 8:00 Evening Peak Generation 3654.0 MW 19:30 Max Generation 3590 MW E.P. Demand (at gen end) 5350.0 MW Hour 19:30 Max Demand 5300 MW Maximum Generation 3951.5 MW Hour 3.00 Shortage 1710 MW Total Gen. (MKWH) 84.36 System L/ Factor 85.41% Load Shed 1385 MW

EXPORT/IMPORT THROUGH EAST-WEST INTERCONNECTOR

Rule curve

Export from East grid to West grid: - Maximum 634 MW at 24:00 Energy 11645000 KWHR. Import from West grid to East grid: - Maximum - MW at - Energy - KWHR.

Water Level of Kaptai Lake at 6:00 A M of 29-Mar-10

Gas Consumed : Total 744.16 MMCFt. Oil Consumed (PDB) :

HSD : 479653 Liter

FO: 0 Liter

Cost of the Consumed Fuel (PDB): Gas : Tk55,000,866 Oil : Tk19,186,138 Total : Tk74,187,004

Load Shedding & Other Information

Area	Yesterday		Today					
	Actual Shedding (s/s end)		Estimated Demand(s/s end)	Estimated Shedding (s/s e	Rates of Shedding			
	MW		from toMW	MW	(On Estimated Demand)			
Dhaka	536	(17:55- 04:30, gen. shortage)	1810	546	30%			
Chittagong Area	188	(17:55- 02:00, gen. shortage)	497	180	36%			
Khulna Area	183	(17:55- 02:00, gen. shortage)	464	168	36%			
Rajshahi Area	147	(17:55- 23:00, gen. shortage)	422	152	36%			
Comilla Area	111	(17:55- 01:42, gen. shortage)	340	123	36%			
Mymensing Area	90	(17:55- 01:42, gen. shortage)	250	90	36%			
Sylhet Area	-	0	166	-	-			
Barisal Area	31	(17:55- 02:00, gen. shortage)	94	34	36%			
Rangpur Area	88	(17:55- 23:00, gen. shortage)	250	92	37%			
Total	1374	19:30	4293	1385				

Information of the Generating machines under shut down.

Planned Shut- Down		Forced Shut- Down
	1) Kaptai- 3 (19/04/08)	09) Ashuganj CCPP ST (05/12/09)
	2) Shajibazar- 2 (13/07/08)	10) Kaptai -4 (17/01/10)
	3) Shajibazar-4 (18/10/08)	11) Khulna 60 MW (16/03/09)
	4) Khulna 110MW (31/03/09)	12) Ghorasal- 1 (08/03/10)
	5) Haripur SBU GT-3 (18/06/09)	13) Ashuganj CCPP GT-1 (23/03/10)
	6) Shahjibazar 5 (05/08/09)	
	7) Shahjibazar -6 (11/10/09)	
	8) Raozan -2 (08/11/09)	

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

scription			 Forced		Interrupt	

- a) There was generation shortage in the evening peak hour yesterday.
- b) Due to gas limitation, RPCL (175 MW), Raozan (180 MW), NEPC(110 MW) and Siddhirganj 210 MW were limited to 74 MW,100 MW, 48 MW and 100 MW respectively.
- c) Due to gas limitation, Haripur SBU GT-1 & 2, Raozan -2 were under shut down
- d) Tongi GT was shut down at 09:30 due to gas pressure low and was synchronized at 23:40 .
- e) After maintenance, Khulna 60 MW was synchronized at 14:43. But it tripped at 17:05 due to excitation problem.
- f) Shahjibazar 86 MW tripped at 23:30 showing 'mains failure' and was synchronized at 23:58.
- g) Shahjibazar 50 MW RPP tripped at 23:36 due to thunder & lightning and was synchronized at 23:57.
- h) Ghorasal -3 was forced shut down at 05:49 (29/03/10) due to firing at exciter.
- i) Aminbazar Tongi 230 KV line -1 & 2 were under shut down from 08:24 to 19:40 due to erection of new tower.
- j) Meghnaghat Comilla (N) 230 KV line -2 was under annual maintenance from 08:41 to 18:01.
- k) Mirpur 132/33 KV T2 transformer was shut down at 09:25 due to maintenance of oil leakage. I) Comilla (N) Haripur 132 KV line -1 tripped at 13:55 from Haripur end showing ' DIST Z1' and
- Comilla (N) Haripur 132 KV line -1 tripped at 13:55 from Haripur end showing 'DIST Z1' and was switched on at 14:00. Again line -2 tripped at 00:35 (29/03/10) showing 'DIST Z1' and was switched on at 00:50 (29/03/10).
- m) Bottail 132/33 KV T1 & T2 transformers tripped at 17:10 showing '51 Lockout & O/C' and were switched on at 17:15 and 17:16 respectively.
- n) Ashuganj Kishorganj 132 KV line -2 tripped at 23:35 from Ashuganj end showing ' DIST A phase & O/C' and was switched on at 00:45 (29/03/10).
- o) Hathazari Kaptai 132 KV line -1 & 2 tripped at 06:10 (29/03/10) from both end showing 'E/F' and were switched on at 06:53 (29/03/10).

So about 1374 MW (19:30) of load shed was imposed over the whole area (except Sylhet) of the national grid.

Power interruption occurred (24 MW) under Bottail S/S areas from 17:10 to 17:15.

Due to generation shortage, about 750 MW (09:00) of load shed has been running since morning (29/03/10) over the whole area (except Sylhet) of the national grid.

Deputy / Asstt. Manager Load Despatch Division

Actual

77.47

Ft.(MSL)

Manager Load Despatch Division Deputy General Manager Load Despatch Circle