POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER, LDC.DHAKA. DAILY REPORT

Ft.(MSL)

QF-LDC-08 Page -1

Reporting Date: 12-May-10 Till now the maximum generation is:-4606.0 MW at Hrs 11-May-10 The Summary of Yesterday's () Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 3473.0 MW 11:00 Min Gen. at 3450 MW Hour 8:00 Evening Peak Generation 3688.0 MW 20:00 Max Generation 3855 MW E.P. Demand (at gen end) : 5000.0 MW Hour 20:00 Max Demand 5000 MW Maximum Generation 3768.5 MW Hour : 24:00 Shortage 1145 MW Total Gen. (MKWH) 83.50 System L/ Factor 85.41% Load Shed 954 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR $\mathsf{M}\mathsf{W}$

Export from East grid to West grid :- Maximum 7136000 KWHR. Energy Import from West grid to East grid :- Maximum MM Energy KWHR.

Water Level of Kaptai Lake at 6:00 A M of 12-May-10 75.47 Actual Ft.(MSL) Rule curve 79.91

Oil Consumed (PDB):

HSD : 468626 Liter

FO 0 Liter

Cost of the Consumed Fuel (PDB): Gas Tk56,719,273 Oil : Tk18,745,022 Total: Tk75,464,295

Load Shedding & Other Information

Area	Yesterday		Today			
	Actual Shedding (s/s end)		Estimated	Demand(s/s end)	Estimated Shedding (s/s e	Rates of Shedding
	MW		from	toM/W	MW	(On Estimated Demand)
Dhaka	355	(18:30 - till now, gen. shortage)		1745	356	20%
Chittagong Area	159	(18:30 - till now, gen. shortage)		480	128	27%
Khulna Area	144	(18:30 - till now, gen. shortage)		448	120	27%
Rajshahi Area	135	(18:30 - till now, gen. shortage)		410	110	27%
Comilla Area	108	(18:30 - till now, gen. shortage)		328	87	27%
Mymensing Area	79	(18:30 - till now, gen. shortage)		243	65	27%
Sylhet Area	-	0		181	-	-
Barisal Area	30	(18:30 - till now, gen. shortage)		91	24	26%
Rangpur Area	83	(18:30 - till now, gen. shortage)		239	64	27%
Total	1093	20:00		4165	954	

Information of the Generating machines under shut down.

Planned Shut- Down		Forced Shut- Down		
	1) Kaptai- 3 (19/04/08)	9) Ghorasal 2(26/04/10)		
	2) Khulna 110MW (31/03/09)	10) Ghorasal 6 (07/05/10)		
	3) Haripur SBU GT-3 (18/06/09)			
	4) Ashuganj CCPP ST (05/12/09)	4) Ashuganj CCPP ST (05/12/09)		
	5) Raozan -1 (08/05/10)			
	6) Sikalbaha St (02/05/10)			
	7) MPL GT-1 (06/05/10)			
	8) MPL GT-2 & ST (07/05/10)			

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

	,
a) There was generation shortage in the evening peak hour vectorday	So about 1003 MW (20:00) of load shed was impos

Description

- b) Due to low gas pressure, RPCL (175 MW), NEPC (110 MW) and Tongi GT (105 MW) were limited to 103 MW, 80 MW and 60 MW respectively.
- c) Baghabari WMPL unit -1 tripped at 14:25 due to high inlet manifold vacuum problem and was synchronized at 19:22.
- d) Ashuganj unit -1 tripped at 15:56 due to vacuum problem and was synchronized at 20:47.
- e) Aminbazar 132/33 KV TR3 transformer was under shut down from 13:12 to 13:56 due to replacement of 132 KV PT.
- f) Ashuganj (on DIST BC) Kishorganj (on DIST BC) 132 KV line -1 tripped at 10:59 from both side and was switched on at 11:29.

Forced load shaded / Interrupted Areas osed over the whole (except Sylhet) areas of the national grid.

Due to generation shortage, about 600 MW (09:00) of load shed has been running since morning (12/05/10) over the whole area (except Sylhet) of the national grid.

Deputy / Asstt Manager Load Despatch Division

Gas Consumed:

Manager

Load Despatch Division

Deputy General Manager Load Despatch Circle