## POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER. LDC.DHAKA DAILY REPORT

QF-LDC-08 Page -1

Reporting Date: 21-May-10 Till now the maximum generation is: 4606.0 MW at 20-Mav-10 The Summary of Yesterday's ( ) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 3611.0 MW 9:00 Min Gen. at 2548 MW Hour 6:00 Evening Peak Generation 3971.0 MW 21:00 Max Generation MW E.P. Demand (at gen end) 3971.0 MW Hour 21:00 Max Demand 4500 MW Maximum Generation 4027 5 MW Hour : 1.00 Shortage 230 MW Total Gen. (MKWH) 88.53 System L/ Factor 85.41% Load Shed 209 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :- Maximum MW at 21:00 Import from West grid to East grid :- Maximum N/N/

Water Level of Kaptai Lake at 6:00 A M of 21-May-10 75.22 Ft.( MSL ) Actual : Ft.(MSL) Rule curve 78.20

MMCFt

Oil Consumed (PDB):

HSD : 402747 Liter FO

Total: Tk71,709,413

Energy

0 Liter

10193000 KWHR.

KWHR

Cost of the Consumed Fuel (PDB): Gas Tk55,599,537 : Tk16,109,876

## **Load Shedding & Other Information**

Area	Yesterday Actual Shedding (s/s end)		Today		
			Estimated Demand(s/s end)	Estimated Shedding (s/s e	Estimated Shedding (s/s e Rates of Shedding
	MW		from to/IW	MW	(On Estimated Demand)
Dhaka	-	0	1796	38	2%
Chittagong Area	-	0	504	42	8%
Khulna Area	-	0	438	36	8%
Rajshahi Area	-	0	365	30	8%
Comilla Area	-	0	282	23	8%
Mymensing Area	-	0	210	17	8%
Sylhet Area	-	0	210	-	-
Barisal Area	-	0	87	7	8%
Rangpur Area	-	0	196	16	8%
Total	0		4088	209	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut-Down		
	1) Kaptai- 3 (19/04/08)	9) Barapukuria -2 (18/05/10)	
	2) Khulna 110MW (31/03/09)		
	3) Haripur SBU GT-3 (18/06/09)		
	4) Ashuganj CCPP ST (05/12/09)		
	5) Raozan -1 (08/05/10)		
	6) Sikalbaha St (02/05/10)		
	7) Ghorasal 2(26/04/10)		
	8) Kaptai- 4 (17/01/10)		

## Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was no generation shortage in the evening peak hour yesterday. Due to heavy rain and	So no load shed required.
storm, the system demand was dropped yesterday.	

- b) Baghabari 100MW tripped at 15:42 due to trippings of booster and was synchronized at 16:24.
- c) After maintenance Khulna 60MW was synchronized at 16:28.

Gas Consumed:

- d) After maintenance Ashuganj unit-1 was synchronized at 20:02
- e) Ashuganj unit-3 was forced shut down at 21:47 due to demy water leakage.
- f) Ashuganj unit-4 tripped at 21:48 due to CW pump tripped and was synchronized at 02:27 (21/05/10)
- g) Shahjibazar GT-9 was shutdown at 00:11(21/05/10) due to schedule maintenance.
- h) After maintenance Ashuganj Shahjibazar 132 KV line 2 was synchronized at 14:20
- i) After maintenance Jamalpur 132/33 KV T3 transformer was synchronized at 14:21
- j) Jhenida Bottail line-1 was under shut down from 10:40 to 13:11 due to bay extension work.
- k) Bheramara Bottail 132 KV line-1 tripped at 15:01 due to snapping of mid phase jumper at Bheramara and was synchronized at 20:23.
- I) Tongi 132/33 KV T2 transformer tripped at 22:12 showing "Buchholz" and was switched on at 02:12 (21/05/10)

Partial power interruption occurred (about 10 MW) under Tongi S/S areas from 22:12 to 02:12 (21/05/10).

Deputy / Asstt. Manager Manager Deputy General Manager Load Despatch Division Load Despatch Division Load Despatch Circle