POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER. LDC.DHAKA DAILY REPORT

QF-LDC-08 Page -1

				Repor	rting Date :	2-Jun-10	
Till now the maximum generation is : -		4606.0 MW at	22:00	Hrs on	14-Apr-10		
The Summary of Yesterday's (1-Jun-10) Generation & Demand		Today's Actual M	/lin Gen. & P	robable Gen.	& Demand
Day Peak Generation :	3936.0	MW Hour :	12:00	Min Gen. at	6:00	3769	MW
Evening Peak Generation :	4178.5	MW Hour :	20:00	Max Generation	n :	4195	MW
E.P. Demand (at gen end) :	5000.0	MW Hour :	20:00	Max Demand	:	5100	MW
Maximum Generation :	4178.5	MW Hour :	20:00	Shortage	:	905	MW
Total Gen. (MKWH) :	91.56	System L/ Factor :	85.41%	Load Shed	:	778	MW
· · · · ·	EXPO	ORT/IMPORT THROUGH EAST	WEST INTERCONNECTOR				
Export from East grid to West grid :- Maximu	ım	520	MW at	1:00	Energy	10745000) KWHR.
Import from West grid to East grid :- Maximu	ım	-	MW at	-	Energy	-	KWHR.
Wat	er Level of Kaptai L	ake at 6:00 A M of	2-Jun-10				
Actual : 80.78 Ft.(MSL),		Rule curve : 76.26	Ft.(MSL)			
				. ,			
Gas Consumed : Total	809.94	MMCFt.	Oil Consume	ed (PDB):			
				. ,	HSD :	214185	Liter
					FO :	0	Liter

Cost of the Consumed Fuel (PDB): Gas :

Tk59,862,665

Oil : Tk8,567,404 Total : Tk68,430,069

Load Shedding & Other Information

Area	Yesterday		Today		
ľ			Estimated Demand(s/s end)	Estimated Shedding (s/s e	Rates of Shedding
	MW		from toMW	MW	(On Estimated Demand)
Dhaka	286	(18:30-03:20, gen. shortage)	1910	329	17%
Chittagong Area	67	(18:30-03:25, gen. shortage)	545	107	20%
Khulna Area	93	(18:30-03:44, gen. shortage)	479	94	20%
Rajshahi Area	79	(18:30-03:42, gen. shortage)	399	79	20%
Comilla Area	70	(18:30-03:32, gen. shortage)	311	61	20%
Mymensing Area	51	(18:30-03:27, gen. shortage)	232	46	20%
Sylhet Area	-	0	196	-	-
Barisal Area	18	(18:30-03:44, gen. shortage)	96	19	20%
Rangpur Area	42	(18:30-03:42, gen. shortage)	215	43	20%
Total	706	20:00	4383	778	

Information of the Generating machines under shut down.

Planned Shut- Down	Forced Shut- Down		
	1) Kaptai- 3 (19/04/08)	9) Ashuganj CCPP GT-2 (26/05/10)	
	2) Khulna 110MW (31/03/09)	10) Khulna 60 MW (27/05/10)	
	3) Haripur SBU GT-3 (18/06/09)	11) Ashuganj -1 (30/05/10)	
	4) Ashuganj CCPP ST (05/12/09)		
	5) Raozan -1 (08/05/10)		
	6) Sikalbaha St (02/05/10)		
	7) Ghorasal 2(26/04/10)		
	8) Kaptai- 4 (17/01/10)		

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description		Forced load shaded / Interrupted Areas
a) There was generation shortage in the even	ing peak hour yesterday.	So about 706 MW (20:00) of load shed was imposed over the
		whole (except Sylhet) areas of the national grid.
b) Due to gas limitation, Raozan (180 MW), F	RPCL (210 MW), NEPC (110 MW) ,	
and Siddhirganj peaking plant (240 MW) we	re limited to 170 MW, 106 MW, 55 MW and	
70 MW respectively.		
) After maintenance Ashuganj unit-2 was syr	chronized at 14:10.	
) Tongi GT was shut down at 12:32 due to ga	as buster cooler maintenance.	
	lue to generator cooling system problem. And GT-2	
	leaning of filter pipeline. It may be synchronized	
before evening peak hour today		
	10) due to drum level high problem. It may be	
synchronized before evening peak hour to	· · ·	
j) Sikalbaha RPP was shutdown at 07:30 (02 It may be synchronized before evening per		
it may be synchronized before evening pea	ak nour today.	

Deputy / Asstt. Manager Load Despatch Division Manager Load Despatch Division

Deputy General Manager Load Despatch Circle