## POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER. LDC.DHAKA DAILY REPORT

QF-LDC-08 Page -1

Reporting Date: 2-Dec-09 Till now the maximum generation is: - MW at 4296.0 1-Dec-09 The Summary of Yesterday's ( ) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation MW 12:00 1708 MW 2171.0 Min Gen. at Hour 4:00 Evening Peak Generation 3666.5 MW 20:00 Max Generation 4000 MW E.P. Demand (at gen end) : 3666.5 MW Hour 20:00 Max Demand 3800 MW Maximum Generation 3666.5 MW Hour 20:00 Shortage 0 MW Total Gen. (MKWH) 92.35% 55.60 System L/ Factor Load Shed - MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :- Maximum

Import from West grid to East grid :- Maximum

- S80 MW at 19:00 Energy 9092000 KWHR.

MW at - Energy - KWHR.

Water Level of Kaptai Lake at 6:00 A M of 2-Dec-09

Actual: 99.73 Ft.(MSL), Rule curve: 105.91 Ft.(MSL)

536.41 MMCFt. Oil Consumed (PDB):

HSD : 199529 Liter FO : 0 Liter

Cost of the Consumed Fuel (PDB): Gas : Tk39,646,063 Oil : Tk7,981,148 Total : Tk47,627,211

## Load Shedding & Other Information

Area	Yesterday Actual Shedding (s/s end)			Today			
				Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding	
	MW	from	to	MW	MW	(On Estimated Demand)	
Dhaka	-	C		1520	-	-	
Chittagong Area	-	0		388	-	-	
Khulna Area	-	0		332	-	-	
Rajshahi Area	-	0		265	-	-	
Comilla Area	-	0		270	-	-	
Mymensing Area	-	0		184	-	-	
Sylhet Area	-			193	-	-	
Barisal Area	-	0		70	-	-	
Rangpur Area	-	0		148	-	-	
Total	0			3370	0		

Information of the Generating machines under maintenance

Planned Shut- Down		Forced Shut- Down	
1) Khulna 60 MW (05/07/06)	1) Kaptai- 3 (19/04/08)	9) Shahjibazar -6 (11/10/09).	
	2) Shajibazar- 2 (13/07/08)	10) Raozan -1 (19/10/09)	
	3) Shajibazar-4 (18/10/08)	11) Raozan -2 (08/11/09)	
	4) Khulna 110 (31/03/09)	12) Ghorasal -2 (14/11/09)	
	5) RPCL GT-4 (06/06/09)	13) Ghorasal -1 (24/11/09)	
	6) Haripur SBU GT-3 (18/06/09).	14) Ashuganj 1 &2 (27/11/09)	
	7) Baghabari GT-2 (02/07/09)	15) Barapukuria -1 (27/11/09)	
	8) Shahiihazar 5 (05/08/09)		

## Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description Forced load shaded / Interrupted Areas

So no load shed required

- a) There was no generation shortage in the evening peak hour yesterday.
- b) Due to gas limitation ,  $\,$  Raozan -1, 2 and Shahjibazar 4 & 5 were under shut down.
- c) KPCL tripped at 21:55 showing 'over voltage' and were synchronized at 22:02.
   d) After maintenance, Meghnaghat Steam and GT-1 was synchronized at 02:40 (02/12/09) and 08:59 (02/12/09) respectively.
- e) Rampura Basundhara 132 KV line -1 & 2 and Tongi 230/132 KV T01 transformers were under NLDC project work from 09:37 to 12:07, 09:37 to 12:08 and 09:58 to 15:45 respectively.
- f) Bogra Naogaon 132 KV line -1 was under annual maintenance from 09:50 to 15:12.
- g) Mirpur 132/33 KV T1 transformer was under shut down from 13:02 to 13:12 due to protection test.

Manager Load Despatch Division Deputy General Manager Load Despatch Circle

Deputy / Asstt. Manager Load Despatch Division

Gas Consumed: Total