

QF-LDC-08  
Page -1

Reporting Date : 5-Dec-09  
on 18-Sep-09

## EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Energy  
Energy

Rule curve : 105.64 Ft.( MSL )

HSD	:	204547	Liter
FO	:	0	Liter

Oil : Tk8,181,866                      Total : Tk48,131,699

### Load Shedding & Other Information

Area	Yesterday			Today		
	Actual Shedding (s/s end)			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	MW	fro	to			
Dhaka	-		0	1574	-	-
Chittagong Area	-		0	408	-	-
Khulna Area	-		0	348	-	-
Rajshahi Area	-		0	277	-	-
Comilla Area	-		0	284	-	-
Mymensing Area	-		0	194	-	-
Sylhet Area	-			209	-	-
Barisal Area	-		0	74	-	-
Rangpur Area	-		0	155	-	-
<b>Total</b>	<b>0</b>			<b>3523</b>	<b>0</b>	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	8) Shahjibazar -6 (11/10/09).
2) Shajibazar- 2 (13/07/08)	9) Raozan -1 (19/10/09)
3) Shajibazar-4 (18/10/08)	10) Raozan -2 (08/11/09)
4) Khulna 110 (31/03/09)	11) Ghorasal -2 (14/11/09)
5) Haripur SBU GT-3 (18/06/09).	12) Ashuganj 2 (27/11/09)
6) Baghabari GT-2 (02/07/09)	13) Barapukuria -1 (27/11/09)
7) Shahjibazar 5 (05/08/09)	

**Additional Information of Machines. lines. Interruption / Forced Load shed etc.**

Description	Forced load shaded / Interrupted Areas
a) There was no generation shortage in the evening peak hour yesterday.	So no load shed required.
b) Due to gas limitation , Raozan -1, 2 and Shahjibazar - 4 & 5 were under shut down.	
c) After maintenance, Ashuganj unit -1 was synchronized at 18:50.	
d) Fenchuganj CCPP GT-2 was shut down at 00:35 (05/12/09) due to hot gas path inspection.	
e) After maintenance, RPCL unit -4 was synchronized at 00:08 (05/12/09).	
f) Ullon - Dhanmondi 132 KV line -3, Ashuganj - Ghorasal 132 KV line -2and Rampura - Magbazar 132 KV line were under NLDC project work from 08:30 to 12:05, 09:21 to 19:47 and 09:28 to 14:17 respectively.	
g) Meghnaghat - Hasnabad 230 KV line -1, Gulshan 132/33 KV MT! transformer and Maniknagar - Narinda 132 KV line -1 were under annual maintenance from 08:53 to 16:38, 09:12 to 15:46 and 09:30 to 13:38 respectively.	
h) Sylhet 132/33 KV T4 transformer tripped at 03:45 (05/12/09) showing ' Inst. E/F' and was switched on at 04:15 (05/12/09).	Partial power interruption occurred (18 MW) under Sylhet S/S areas for 30 minutes.

Deputy General Manager  
Load Despatch Circle