

Page -1

Reporting Date : 1-Jun-20

**Today's Actual Min Gen. & Probable Gen. & Demand**

### EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Oil Consumed (PDB):

**Gas :**

### Load Shedding & Other Information

Area	Yesterday		Estimated Demand (S/S end)	Today	
	MW	0:00		Estimated Shedding (S/S end)	Rates of Shedding (On Estimated Demand)
Dhaka	0	0:00	3945	0	0%
Chittagong Area	0	0:00	1342	0	0%
Khulna Area	0	0:00	1202	0	0%
Rajshahi Area	0	0:00	1086	0	0%
Cumilla Area	0	0:00	981	0	0%
Mymensingh Area	0	0:00	792	0	0%
Sylhet Area	0	0:00	443	0	0%
Barisal Area	0	0:00	204	0	0%
Rangpur Area	0	0:00	611	0	0%
<b>Total</b>	<b>0</b>		<b>10606</b>	<b>0</b>	

Information of the Generating Units under shut down.

## Forced Shut-Down

- 1) Barapukuria ST: Unit-1,2
- 2) Bibiyana #3
- 3) Ghorasal Unit-2,3,5 & 7.
- 4) Ashuganj unit-4,5
- 5) Bhola-225 MW GT-2
- 6) Kaptai-1,2,4
- 7) Raozan # 2

**Additional Information of Machines, lines, Interruption / Forced Load shed etc.**

Description
-------------

- a) After maintenance Baghabari-71 MW was synchronized at 11:39 and shut down at 19:53.
- b) Tangail-RPCL 132 kV Ckt-2 was under shut down from 11:41 to 13:50 for kite swinging at R-phase.
- c) Ashuganj-Sraiganj 230 kV Ckt-2 was under shut down from 11:42 to 16:21 for C/M.
- d) Gopalganj 132/33 kV T-1 & T-2 transformers tripped at 08:02 showing E/F relay due to fuse burn of auxiliary transformer and were switched on at 08:20 & 09:51 respectively.
- e) Mymensingh-Kishorganj 132 kV Ckt-2 was under shut down from 13:57 to 15:27 for kite swinging in conductor.
- f) Meghnath-Shyamrup 230 kV Ckt-2 tripped at 14:30 showing dist Z1 at Meghnath end and dist Z3 Shyamrup end as cap welding of B-phase line PT at Meghnath got damaged and was switched on at 21:15.
- g) AES Meghnath-450 MW GT-2 tripped at 14:30 and was synchronized at 19:35.
- h) After maintenance Bholu-225 MW GT-1 was synchronized at 18:01.
- i) Tangail-RPCL 132 kV Ckt-1 tripped at 05:35(1/6/20) showing dist Z1 and was switched on at 05:56(1/6/20).
- j) Rangamati 132/33 kV T-1 & T-2 transformers tripped at 06:11(1/6/20) showing 51 DMT & differential 3-phase and were switched on at 07:15 & 07:13 (1/6/20) respectively.
- k) Thakurgaon 132/33 kV T-1 & T-2 transformers tripped at 07:45(1/6/20) due to crow on 33 kV Bus and was switched on at 07:53(1/6/20).

	<b>Comments on Power Interruption</b>
--	---------------------------------------

About 40 MW power interruption occurred under Gopalganj(old) S/S area from 08:02 to 08:20.

About 06 MW power interruption occurred under Rangamati S/S area from 06:11 to 07:11(1/6/20).

About 40 MW power interruption occurred under Thakurgaon S/S area from 07:45 to 07:53(1/6/20).

Sub Divisional Engineer  
Network Operation Division

Executive Engineer  
Network Operation Division

Superintendent Engineer  
Load Despatch Circle