

POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT										QF-LDC-08 Page -1	
										Reporting Date : 22-Apr-21	
Till now the maximum generation is :-										13380.0	
The Summary of Yesterday's										21-Apr-21	
Day Peak Generation :										11129.0 MW	
Evening Peak Generation :										12542.0 MW	
E.P. Demand (at gen end) :										12542.0 MW	
Maximum Generation :										12542.0 MW	
Total Gen. (MKWH) :										267.9	
System Load Factor :										88.99%	
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum										-372 MW	
Import from West grid to East grid :- Maximum										-	
Water Level of Kaptai Lake at 6:00 A M on										22-Apr-21	
Actual : 78.60										Ft.(MSL) ,	
Rule curve :										83.80	
Ft.(MSL)											
Gas Consumed : Total =										1174.30 MMCFD.	
Oil Consumed (PDB) :											
HSD :										Liter	
FO :										Liter	
Cost of the Consumed Fuel (PDB+Pvt) :											
Gas :										Tk159,414,915	
Coal :										Tk86,597,770	
Oil :										Tk564,730,518	
Total :										Tk810,743,203	
Load Shedding & Other Information											
Area										Yesterday	
MW										Estimated Demand (S/S end)	
MW										Today	
MW										Estimated Shedding (S/S end)	
MW										Rates of Shedding	
MW										(On Estimated Demand)	
Dhaka										0	
Chittagong Area										0	
Khulna Area										0	
Rajshahi Area										0	
Cumilla Area										0	
Mymensingh Area										0	
Sylhet Area										0	
Barisal Area										0	
Rangpur Area										0	
Total										0	
Information of the Generating Units under shut down.											
Planned Shut- Down										Forced Shut- Down	
										1) Barapukuria ST: Unit-2	
										2) Ghorasal-3,4,7	
										3) Ashuganj-4,5	
										4) Kaptai-2	
										5) Raozan #2	
										6) Siddirganj-335 MW ST	
										7) Baghabari 100 & 71 MW	
Additional Information of Machines, lines, Interruption / Forced Load shed etc.											
a) Sirajganj #1 tripped at 08:53 due to valve malfunction and was synchronized at 15:53.											
b) Koddas-300 MW-Kaliakoir 230 kV Ckt was under shut down from 09:45 to 10:38 for SF6 gas filling.											
c) Mirpur-Aminbazar 132 kV Ckt-2 was under shut down from 10:12 to 12:58 for D/W.											
d) Sikalbaha 132 kV GIS Bus-2 was under shut down from 10:19 to 16:36 for D/W.											
e) Khulna(S)-HVDC 230 kV Ckt-1 was under shut down from 08:46 to 14:05 for C/M.											
f) Kulaura-Fenchuganj 132 kV Ckt-2 was under shut down from 11:30 to 12:09 due to red hot maintenance at DS at Kulaura end.											
g) Keraniganj (new) 230/132 kV T-2 transformer was shut down at 12:01 for D/W.											
h) B.Baria 132/33 kV T-2 transformer was under shut down from 11:35 to 12:44 due to red hot maintenance at LT B-phase CT.											
i) Faridpur 132/33 kV T-2 transformer was under shut down from 09:44 to 12:35 for CT loop replacement.											
j) Faridpur 132/33 kV T-1 transformer was under shut down from 12:39 to 13:16 for CT loop replacement.											
k) Ashuganj-225 MW CCPP GT was shut down at 17:04 due to problem with air compressor and was synchronized at 20:42 & ST tripped at 16:57 showing droop protection trip.											
l) Ammnura-C.Nawabganj 132 kV Ckt tripped at 18:40 showing dist.Z2 at Ammnura end.											
m) Rajshahi(O) 132 kV T-2 & T-3 transformers tripped at 18:34 showing O/C relay due to problem with 33 kV extension bus and T-2 transformer was switched at 19:57.											
n) Bheramara HVDC-Baharampur 400 kV Ckt-1 tripped at 19:11 showing distance relay at Baharampur end.											
o) Ashuganj-Sirajganj 230 kV Ckt-1 tripped at 21:50 showing dist.ZS phase at Ashuganj end.											
p) Koddas-Rajendrapur 132 kV Ckt-2 tripped at 22:40 showing dist.Z1 and was switched on at 23:19.											
q) Ghorasal-Norsingdi 132 kV Ckt-1 tripped at 22:41 showing dist.B-phase and was switched on at 23:42.											
r) Ashuganj-B.Baria 132 kV Ckt-1 tripped at 23:42 showing dist.BC phase and was switched on at 23:53.											
s) Barishal(S) 132/33 kV T-2 transformer was under shut down from 07:01 to 07:34(22/4/21) for C/M.											
t) Barishal(S) 132/33 kV T-1 transformer was under shut down from 07:36 to 08:08(22/4/21) for C/M.											
u) Sirajganj #1 was forced shut down at 22:52 due to low demand and was synchronized at 08:33.											
Sub Divisional Engineer										Executive Engineer	
Network Operation Division										Network Operation Division	
										Superintendent Engineer	
										Load Despatch Circle	