

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 3-May-21		Page - 2					
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CAPP Unit-1	PDB	170	170	0	0	Under maint.
2	Ghorasal Repowered CAPP Unit-2	PDB	1210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1210	190	180	4296600	
4	Ghorasal 365 MW CAPP Unit-7	QRPP	1243*1122	365	0	0	Under maint.
5	Ghorasal 78.5 MW PPMAX	QRPP	2*40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regen)	IPP	343.35	108	102	1964409	
7	Haripur GTTP	SBU, PDB	2*32	20	0	0	Under maint.
8	Haripur 412 MW CAPP	EGCB	1273*1139	412	239	6642920	Gas shortage
9	Haripur 360MW CAPP(HPL)	IPP	1235*1125	360	203	5634000	Gas shortage
10	Meghnaghat 450 MW CAPP(MP)	IPP	2150*1150	450	260	6108500	Gas shortage
11	Meghnaghat 100 MW(EL)	QRPP	12*8.9	100	93	954240	Engine problem
12	Meghnaghat CAPP(Summit)	IPP	2110*1110	305	260	4752553	FGMO
13	Madanganj 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
14	Madanganj-55 MW PP(Summit)	(IPP)	317.08*111.3	55	55	1243201	
15	Keraniganj 100 MW PP (Powerpa)	QRPP	813.45	100	15	107439	Low demand
16	Narsinghdi 22 MW PP (Doreen)	SIPP, REB	82.90	22	22	430884	
17	210 MW Siddhirgonj TPP	PDB	1210	115	0	0	Under maint.
18	Siddhirgonj 2120 MW GTTP	EGCB	2105	210	145	3217000	Gas shortage
19	Siddhirgonj 100 PP(Dutch Bangla)	QRPP	128.9	100	100	1260480	
20	Siddhirgonj 335 MW CAPP	EGCB	1217*118	335	223	5047457	ST under maint.
21	Gagnagar 102 MW PP (Digital P)	IPP	128.924	102	102	844128	
22	Katpott 52 MW PP (Sinha)	IPP	77.9	51	0	0	Engine problem
23	Kamatnagar 54 MW PP(Banco E)	IPP	319.8	54	35	537840	Engine problem
24	Kodda 150MW PP	BFDB-RPCL	917.06	149	64	357120	Low demand
25	Manikganj 55 MW PP (Northern)	IPP	319.3	55	55	342467	
26	Nababganj 55 MW PP (Southern)	IPP	319.3	55	35	435031	Engine problem
27	Bosila 108MW PP(CLG)	IPP	128.775*13.5	108	0	0	Fuel shortage
28	Summit Power, Madhabadi-Ashul	SIPP, REB	3167.48*73	80	53	1172520	Engine problem
29	Machra 33 MW PP(Summit)	SIPP, REB	48.73	33	28	734100	Engine problem
30	Ruganj 33 MW PP(Summit)	SIPP, REB	48.73	33	25	690100	Engine problem
31	Gazipur 52 MW PP	IPP	61.9	52	27	256800	Low demand
32	Tongi 80 MW GTTP	PDB	1105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	1817.076	300	228	1455272	Engine problem
34	Keraniganj 300 MW PP (AFR)	IPP	2581.4	300	0	0	Reserve.
35	Bramhangonj 100 MW PP (Agg)	IPP	100	100	0	0	Reserve.
36	Aurahati 100MW PP (Aggreko)	IPP	0.8523*0.9591	100	0	0	Reserve.
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	149	149	149	3572784	
38	Gazipur 100 MW PP	RPCL	100 MW	105	105	1860900	
39	Meghnaghat 104 MW PP (OPCL)	IPP	185.5	104	90	1065600	
40	Manikganj 162MW PP(MPCL)	IPP	918	162	162	1861920	Engine problem
41	Spectra Solar Plant Ltd.	IPP	35	35	0	188480	
Dhaka area Total			5829	3055	57040745		
39	Chattogram TPP-1	PDB	1210	180	90	2300000	Gas shortage.
40	Chattogram TPP-2	PDB	1210	180	0	0	Gas shortage
41	Raozan 25 MW PP	IPP	38.9	25	17	408211	Engine problem
42	Teknaf 20MW PP (SolarTech)Khat Solartech Energy	IPP	20	20	0	118530	
43	Patenga 50MW PP (Baraka)	IPP	86.98	50	50	463680	
44	Kaptai Hydro: Unit-1,2,3,4, 5	PDB	240*3*50	230	21	484740	Unit-2 under maint
45	Sikalbaha 225MW	PDB	1150*1175	225	203	4942346	FGMO
46	Sikalbaha Peaking GT	PDB	1150	150	120	2744840	Gas shortage
47	Sikalbaha 105 MW PP (Baraka S)	IPP	105 MW	105	105	2565953	
48	Hathazari 100 MW peaking PP	PDB	118.9	98	0	0	
49	Dohazari -Kalaish 100 MW Peak	PDB	61.7	102	68	778469	Engine problem
50	Juldah 100 MW Unit-1 (Acorn)	QRPP	813.45	100	0	0	Fuel shortage
51	Juldah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	2082240	
52	Burabkunda 22 MW PP (Regent)	SIPP, PDB	0	22	21	472320	
53	Malancha, Ctg. EZZ	IPP	518.72*19.34	0	28	464160	
54	Chattogram 108 MW PP (ECPV)	IPP	67	108	89	434880	Engine problem
55	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	29520	
56	Anwara 300 MW PP (Uniled)	IPP	300 MW	300	0	0	Reserve.
57	Jodiak Power	IPP	318.55*13.6	54	54	1299048	
58	Karnaphuli Power Ltd.	IPP	110	110	17	227489	Low demand
59	Juldah unit-2 (Acorn)	IPP	813.6	100	100	1990080	
60	Anlima Energy Ltd.	IPP	621.2	116	112	1709945	
Chattogram area Total			2382	1193	23516461		
58	Ashuganj TPP Unit- 3	APSCL	1150	135	0	0	Gas Shortage
59	Ashuganj TPP Unit- 4	APSCL	1150	129	0	0	Gas shortage
60	Ashuganj TPP Unit- 5	APSCL	1150	134	100	2153870	Gas shortage
61	Ashuganj 225 MW CAPP	APSCL	1144*2175	221	207	4457000	FGMO
62	Ashuganj 450 MW CAPP(North)	APSCL	1360	360	305	7582800	FGMO
63	Ashuganj 450 MW CAPP(South)	APSCL	1360	300	300	7368000	FGMO
64	Ashuganj 50 MW PP	APSCL	143.968	45	26	570456	Engine problem
65	Ashuganj 55 MW PP (Precision)	RPP	154	55	57	1231200	
66	Ashuganj 150MW PP (APCL-U)	IPP	2073*1116	195	8	200727	Gas shortage
67	Ashuganj 51 MW PP (Midland)	IPP	69.34	51	51	1182671	
68	Ashuganj 150MW PP (Midland)	IPP	237.015	150	150	1378327	
69	Tilas 50 MW Peaking PP	PDB	68.92	52	0	0	Reserve.
70	Chandpur 150 MW CAPP	PDB	1106*157	163	84	2052040	Gas shortage
71	Chandpur 200MW (Desh energy)	IPP	0	200	160	2757600	Engine problem
72	Feni 22MW PP (Doreen)	SIPP, PDB	82.90	22	22	480744	
73	Feni 11 MW PP (Doreen)	SIPP, REB	42.90	11	10	232020	
74	Impopr (Tripura)	Imported power	0	160	154	2992320	
75	Jangalia 33MW PP (Summit)	SIPP, PDB	48.73	33	25	755400	Engine problem
76	Jangalia 52 MW PP (Lakdanavi)	IPP	68.92	52	52	834317	
77	Cumilla 25 MW PP (Summit)	SIPP, PDB	3167.2*6.97	25	20	450630	Engine problem
78	Baidyandi 200 MW PP (B.Trac)	IPP	1541.4	200	0	0	Reserve.
79	Feni Lanka Power	IPP	718.415*19.78	114	70	303240	Low demand
80	Chowmuhani 113 MW	IPP	129.78*23.1	113	113	1737960	
81	Bhairab 54.5 MW	IPP	318.2	54	35	873720	Engine problem
Cumilla Area Total			3034	1949	39895242		
78	RPCL 210MW CAPP	IPP	435*1170	202	154	3562680	Gas shortage
79	Tangail 22 MW PP (Doreen)	SIPP, PDB	82.90	22	19	484272	
80	Jamalpur 95 MW PP(Powerpac)	IPP	128.924	95	73	1242240	Engine problem
81	Sarishabari 3 MW Solar Plant	IPP	13	3	0	13650	
82	Mymensingh 200 MW PP (Unite)	IPP	200	156	1070400	Low demand	
83	Jamalpur 115 MW PP (Uniled)	IPP	115 MW	115	115	2084400	
84	Sutakhirali 50 MW Solar PP	IPP	50	0	0	328990	
85	Tangail Palli Power Gen 22 MW	IPP	46.7	22	24	482160	
Mymensingh Area Total			709	541	9229992		
86	Fenchugonj CAPP Phase-1	PDB	232*133	70	43	1027000	Machine problem
87	Fenchugonj CAPP Phase-2	PDB	235*135	90	22	404400	Machine problem
88	Kushkhara 163 MW CAPP (KP)	IPP	1109*154	163	163	3447490	
89	Shahjibazar 330 MW CAPP	PDB	3110	330	273	3773000	Machine problem
90	Fenchugonj 51 MW PP (Barakat)	RPP	192.90	51	53	963600	
91	Fenchugonj 44MW (Energyprim)	RPP	1213.3*52	0	0	0	Contract Expired
92	Hobiganj 11MW PP Confidence-E	SIPP, REB	42.90	11	11	182576	
93	Shahjibazar GTTP Unit- 8 & 9	PDB	235	66	66	1465152	
94	Shahjibazar 80MW PP (Shahjiba)	RPP	322.90	86	78	1407360	Engine problem
95	Shahjibazar 100 MW GTTP	PDB	1100	100	0	0	Under Shut down
96	Sylhet 225 MW CAPP	PDB	1142*1189	231	224	5174420	
97	Sylhet 20 MW GTTP	PDB	120	20	17	417000	
98	Sylhet 50MW PP (EPL)	RPP	272	0	0	0	Contract Expired
99	Shahjahanulla 25 MW PP	SIPP, REB	31.34	25	16	373776	Engine problem
100	Bibiana-II 341 MW CAPP (Summit)	IPP	1222*1119	341	280	7412000	FGMO
101	Bibiyana-III 400 MW CAPP	PDB	400 MW	400	367	9010000	FGMO
102	Sylhet 10MW PP (Desh)	RPP	61.95	10	7	163260	Engine problem
103	Bibiyana South 400 MW	PDB	400 MW	383	370	8925700	FGMO
Sylhet Area Total			2377	2000	44151734		
102	Bheramara GTTP Unit-3	PDB	120	16	0	0	Reserve.
103	Bheramara (NWDCL)	Imported power	21500	1000	907	2192281	
104	Khulna 115 PP MW (KPCL-2)	QRPP	717	115	99	1560000	Engine problem
105	Fariapur 50 MW Peaking PP	PDB	86.89	54	4	37440	
106	Khulna 225 MW CAPP	NWPGCL	1150*1175	230	0	0	Reserve.
107	Gopalganj 100 MW Peaking PP	PDB	166.98	109	0	0	Reserve.
108	Bheramara 410 MW CAPP	NWPGCL	1278*1132	410	285	8631936	Gas shortage
109	Noapara 40 MW CAPP (Khanjahan)	IPP	511.5	40	32	121125	Engine problem
110	Noapara 100 MW PP (Bangla Tr)	IPP	701.4	100	96	278400	
111	Rupsha 105 MW PP (Orion rupa)	IPP	618.445	105	91	934560	Engine problem
112	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	414576	Reserve.
Khulna Area Total			2284	1514	33900218		
112	Bansail 110 MW PP (Summit)	IPP	717.076	110	110	1873632	
113	Bhola 33 MW PP (Venture)	RPP	1134.50	33	35	622732	
114	Bhola 225 MW CAPP	PDB	263*1168	194	64	830000	Machine problem
115	Bhola 95 MW PP (Aggreko)	QRPP	961.10	95	97	2313173	
116	Payra 1320 MW	BCPCL	2*622	1244	560	5903300	
117	Bhola Nutan Biddut BD LTD	IPP	220	0	0	0	On Test
118	Uniled Payra Power Ltd.	IPP	818.5*19.5	150	22	1326000	Line OIL
Bansail Area Total			1826	938	12688977		
117	Baghabari 71 MW GTTP	PDB	171	71	0	0	Gas shortage
118	Baghabari 100 MW GTTP	PDB	1100	100	0	0	Gas shortage.
119	Baghabari 50 MW Peaking PP	PDB	68.9	52	50	191408	
120	Bera 70 MW Peaking PP	PDB	98.29	71	0	0	Reserve.
121	Annara 50 MW PP(Sinha)	QRPP	77.79	50	18	88500	Low demand