			NATIONAL L		BANGLADESH LTD. PATCH CENTER ORT		Reporting Date:	QF-LDC-08 Page -1 19-May-21
Till now the maximum generation	n is : -	13792.0				20:00 Hrs on	27-Apr-21	19-Way-21
The Summary of Yesterday's		lay-21 Generation &					in Gen. & Probable Gen.	
Day Peak Generation :		10113.0 MW		Hour :	12:00	Min. Gen. at	8:00	8781 MW
Evening Peak Generation : E.P. Demand (at gen end) :		10978.0 MW 10978.0 MW		Hour : Hour :	21:00 21:00	Available Max Ger Max Demand (Eve		15161 MW 12500 MW
Maximum Generation :		11234.0 MW		Hour :	22:00	Reserve(Generation		2661 MW
Total Gen. (MKWH) :		243.7	System Load F		90.38%	Load Shed	:	0 MW
		EXPORT / IMPORT THE	ROUGH EAST-WEST					
Export from East grid to West grid :-				-210	MW at MW at	19:00	Energy	MKWHR. - MKWHR.
Import from West grid to East grid :- Water Level of Kaptai Lake at		19-May-21	•		MW at	-	Energy	- MKWHR.
	.95 Ft.(MSL),	10 may 21	R	tule curve	78.58	Ft.(MSL)		
Gas Consumed :	Total =	1213.60 MMCFD.			Oil Consumed (PDB):			
							HSD : FO :	Liter Liter
							10 .	Liter
Cost of the Consumed Fuel (PDB+P)	rt):	Gas :	Tk157,716,793					
:		Coal :	Tk77,999,002		(Oil : Tk386,549,797	Total :	Tk622,265,592
	1 4 0 4	di 0 Other lefe						
	Load Snedd	ding & Other Information						
Area Ye	sterday					Today		
	,	Esti	mated Demand (S/S er	nd)		Estimated Sheddir	ng (S/S end)	Rates of Shedding
	IW		MW					(On Estimated Demand)
		:00	4459				0	0%
		:00	1520				0	0%
		:00 :00	1363 1231				0 0	0% 0%
		:00	1113				0	0%
		:00	898				ő	0%
Sylhet Area	0 0:	:00	497				0	0%
		:00	231				0	0%
· · · · · · · · · · · · · · · · · · ·		:00	693				0	0%
Total	0		12004				0	
Inform	nation of the Generating U	Jnits under shut down						
	-							
Planned S	hut- Down				Forced Shut- Down			
					1) Barapukuria ST: Unit-1	,2		
					2) Ghorasal-3,4,7			
					3) Ashuganj-3,4			
					4) Kaptai-2 5) Raozan #1,2			
					5) Raozan #1,2			
Additional	Information of Machine	s, lines, Interruption / Force	ad I and shed atc					
Additional	information of machine	s, illes, illerraption / r ore	ca Loua snea etc.					
a) Kodda-Joydevpur 132 kV Ckt-2 is under shut down since 08:25 for OPGW replacing work.								
b) After maintenance Ashuganj 225 N								
c) Haripur-Sonargaon 132 kV Ckt-1 v								
d) Haripur-Sonargaon 132 kV Ckt-2 was under shut down from 12:21 to 13:52 for C/M. e) Haripur P.PHaripur 230 kV S/S 132 kV Ckt-2 Bus side Breaker was under shut down from 10:42 to								
11:48 for loop maintenance.	02 NV ON 2 Duo 0140 Dro	and was and or or at down in	0111 10:12 10					
f) Tongi-Bashundhara 132 kV Ckt-1 v	vas under shut down from	12:21 to 13:24 for C/M at B	ashundhara end.					
g) Naogaon 132/33 kV T-3 transform	er tripped at 12:05 due to	o 33 kV PBS feeder fault and	l was switched				er interruption occurred un	der Naogaon S/S area
on at 12:25. h) Bheramara 230/132 kV T-02 transformer tripped at 12:15 showing PRD relay and was switched on at 17:45.							5.	
 i) Barishal(N) 230/132 kV T-01 transfe j) Julda-Shahmirpur 132 kV Ckt-2 wa 							İ	
k) Sylhet 225 MW CCPP ST was shu			ia ciiu.				ļ	
I) Chatak 132/33 kV T-2 transformer			15:20.					
m) Haripur-Siddhirganj 132 kV Ckt-1	was under shut down fror	m 14:00 to 15:03 for C/M.						
n) Fatulla-Shyampur 132 kV Ckt-2 trip	oped at 16:27 from Fatulla	a end showing Dist.Z1 and w	as switched					
on at 17:01.								
 Daudkandi-Sonargaon 132 kV Ckt switched on at 17:11. 	-2 tripped at 16:32 from b	ooth ends snowing Dist.21, R	-pnase and was					
p) Daudkandi-Cumilla(N) 132 kV Ckt-	1 trinned at 17:15 from h	oth ends showing Diet 71 R.	nhase and was					
switched on at 17:49.	Talpped at 17:10 from b	our crids snowing bist.21, 10	priase and was					
switched on a 17-9-9. (a) Ashuganj-Cumilla(N) 230 kV Ckt-1 tripped at 17:33 from both ends showing Dist. B-phase and was switched								
on at 18:30.		-						
r) Rampura-Bashundhara 132 kV Ckt	-1 tripped at 17:26 from b	both ends showing Dist.Z1, C	-phase and was					
switched on at 18:07.							ver interruption occurred un	ider Cov's Bazar S/S area
s) Cox's Bazar 132/33 kV T-3 transformer tripped at 18:40 due to 33 kV feeder fault and was switched on at 18:54.							/er interruption occurred un i4.	idei Cox 8 dazai 3/3 area
on at 16:54. I) Sonargaon 132/33 kV T-1 transformer tripped at 20:21 from 33 kV side due to 33 kV feeder fault.							•••	
Soriargaon 32/35 kV F1 transformer imped at 20/21 from 35 kV side due to 35 kV feeder fatur.								
v) Bheramara 230/132 kV T-01 transformer is under shutdown since 07:20(19/05/2021) due to PRD maintenance.								
w) Kodda-Joydevpur 132 kV both Ck								
x) Khulna(S)-Satkhira 132 kV Ckt-2 is	under shut down since 0	7:14(19/05/2021) due to R/H	maintenance					
at Khulna(S) end.	NA O in condens 1 1 1 1	-: 07:40(40(05(0004) 1	2001					
y) Mymensingh-Kishoreganj 132 kV Cz) Shariatpur 132/33 kV T-1 transform								
R/H maintenance.	ici is unuci snutuowii SIN	00 01.00(10/00/2021) due to	OO KY ICCUE!					
aa) Aftabnagar 132/33 kV T-2 transfo	rmer tripped at 05:06(19/	/05/2021) due to High windin	g temperature.					
ab) Sikalbaha 225 MW CCPP ST wa	s shutdown at 00:15(19/0	05/2021) for maintenance.	•					

Superintendent Engineer Load Despatch Circle

Executive Engineer Network Operation Division

Sub Divisional Engineer Network Operation Division