Bangladesh Power Development Board

DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month June, 2021	Day : Wednesday	Date : 09.06.21
Probable Maximum Demand : 13000 MW	Probable Maximum Generation : 15482 MW	
Water Level of Kaptai Lake at 06:00 AM	Yesterday = 73.11 ft	Today = 73.42 ft. Rule Curve = 78.08 ft.

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.06.21 (Yesterday) Actual Peak Generation (MW)		09.06.21 (Today) Probable Peak Generation (MW)		08.06.21 (Yesterday) Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
							Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A)	**Plants in operation:**													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas	(PDB)	1 x 210	260	260	0	0	0	0		260	Under maint.	
2	a) Ghorasal Repowered CCPP Unit-4	Gas	(PDB)	1 x 210	210	180	0	0	0	0		180	Under Repowering	
	b) Ghorasal TPP Unit-5	Gas	(PDB)	1 x 210	210	190	185	185	185	185				
3	Ghorasal 365 MW CCPP Unit-7	Gas	(PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.	
4	Ghorashal 108MW PP (Regent)	Gas	(IPP)	34x3.35	108	108	95	97	104	104				
5	Tongi 80 MW GTPP	Gas	(PDB)	1 x 105	105	105	0	0	0	0		105	CB Problem	
6	Haripur GTPP	Gas	(PDB)	1 x 32	32	20	0	0	0	0		20	Under Maint.	
7	Haripur 360MW CCPP(HPL)	Gas	(IPP)	1x235+1x125	360	360	222	201	260	260	159		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas	(IPP)	2x140+1x170	450	450	300	300	300	300	150		Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas	(PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas	(EGCB)	1x273+1x139	412	412	0	0	0	0		412	Under maint.	
11	Siddhirgonj 2*120 MW GTPP	Gas	(EGCB)	2 x 105	210	210	90	182	150	200	28		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas	(EGCB)	1 x 217+1x118	335	335	332	335	300	320				
13	Siddhirganj 100 PP(Dutch Bangla)	HFO	(QRPP)	12x8.9	100	100	100	100	100	100				
14	Meghnaghat CCPP(Summit)	GAS	(IPP)	2x110+1x110	305	305	280	260	280	300				
15	Meghnaghat 100 MW(IEL)	HFO	(QRPP)	12x8.9	100	100	0	0	0	0				
16	Madanganj-55 MW PP(Summit)	HFO	(IPP)	5x17.08+1x11.3	55	55	0	55	55	55				
17	Keraniganj 100 MW PP (Powerpac)	HFO	(QRPP)	8x13.45	100	100	0	51	87	87				
18	Gagnagar 102 MW PP (Digital Power)	HFO	(IPP)	12x8.924	102	102	24	40	102	102				
19	Narshingdi 22 MW PP (Doreen)	Gas	(SIPP, REB)	8x2.90	22	22	15	21	20	21				
20	Summit Power,(Madhabdi+Ashulia)	Gas	(SIPP, REB)	6x3.67+7x8.73	80	80	47	55	55	55				
21	Maona 33 MW PP(Summit)	Gas	(SIPP, REB)	4x8.73	33	33	33	33	33	33				
22	Rupganj 33 MW PP(Summit)	Gas	(SIPP, REB)	4x8.73	33	33	33	33	33	33				
23	Gazipur 52 MW PP	HFO	(RPCL)	6x8.90	52	52	42	42	42	42				
24	Gazipur 100 MW PP	HFO	(RPCL)	6x18.415	105	105	86	85	85	85				
25	Kodda 150MW PP	HFO	(BPDB-RPCL)	9x17.06	149	149	98	150	150	150				
26	Katpotti 52 MW PP (Sinha)	HFO	(IPP)	7x7.90	51	51	0	0	0	0				
27	Kamalaghat 54 MW PP (Banco Energy)	HFO	(IPP)	3x18.69	54	54	53	54	54	54				
28	Kodda 300 MW PP Unit-2 (Summit)	HFO	(IPP)	18x17.076	300	300	0	228	245	245				
29	Kodda 149 MW PP Unit-1 (Summit)	HFO	(IPP)	8x18.415+1x8.97	149	149	80	132	149	149				
30	Keraniganj 300 MW PP (APR)	HSD	(IPP)	256x1.4	300	300	0	0	100	300				
31	Bramhangoan 100 MW PP (Aggreko)	HSD	(IPP)	23x0.85+91x.959	100	100	0	0	100	100		.		
32	Aurahati 100MW PP (Aggreko)	HSD	(IPP)	23x0.85+91x.959	100	100	0	0	50	100				
33	Nababganj 55 MW PP (Southern powe	HFO	(IPP)	3x19.3	55	55	55	50	55	55				
34	Manikganj 55 MW PP (Northern)	HFO	(IPP)	3x19.3	55	55	0	35	55	55				
35	Bosila 108MW PP(CLC)	HFO	(IPP)	12x8.775+1x3.5	108	108	0	0	0	0				
36	Meghnaghat 104 MW PP (OPSL)	HFO	(IPP)	6x18.5	104	104	17	91	104	104				
37	Manikgonj 162MW PP(MPGL)	HFO	(IPP)	9x18	162	162	78	126	162	162				
38	Manikgonj 35MW Solar PP (Inspectra	Solar	(IPP)	1x35	35	35	22	0	30	0				
	Dhaka Zone Total				**6076**	**5919**	**2287**	**2941**	**3445**	**3756**	**337**	**1457**		
39	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro	(PDB)	2x40, 3x50	230	230	20	20	20	20	210		Low Water Level	
40	a) Chattogram TPP-1	Gas	(PDB)	1 x 210	210	180	100	100	100	100				
	b) Chattogram TPP-2	Gas	(PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
41	Kaptai 7 MW Solar PP	Solar	(PDB)		7	7	2	0	5	0				
42	Raozan 25 MW PP	HFO	(RPCL)	3x8.9	25	25	17	17	17	17				
43	Teknaf 20MW PP (Solartech)	Solar	(IPP)	1x20	20	20	10	0	20	0				
44	Patenga 50MW PP (Baraka)	HFO	(IPP)	8x6.89	50	50	0	50	50	50				
45	Sikalbaha 105 MW PP (Baraka Sikalba	HFO	(IPP)	6x18.415	105	105	105	105	105	105				
46	Shikalbaha Peaking GT	Gas	(PDB)	1 x 150	150	150	120	120	120	120				
47	Sikalbaha 225 MW CCPP	Gas	(PDB)	1 x 150+1 x 75	225	225	199	196	220	220				
48	Anwara 300 MW PP (United)	HFO	(IPP)	17x17.076+ 3x8.04	300	300	0	0	300	300				
49	Juldah 100 MW Unit-1 (Acorn)	HFO	(QRPP)	8x13.45	100	100	80	100	100	100				
50	Juldah 100 MW PP Unit-3 (Acorn)	HFO	(IPP)	8x13.45	100	100	30	30	100	100				
51	Dohazari -Kalaish 100 MW Peaking	HFO	(PDB)	6x17.0	102	102	13	85	85	85				
52	Hathazari 100 MW peaking PP	HFO	(PDB)	11x8.9	98	98	0	0	0	0				
53	Barabkunda 22 MW PP (Regent)	Gas	(SIPP, PDB)	8x2.90	22	22	0	0	22	22				
*	Malancha, Ctg.EPZ (United)	Gas		5x8.73+3x9.34			6	18	10	25				
54	Chattogram 108 MW PP (ECPV)	HFO	(IPP)	16x7.00	108	108	0	0	6	6				
55	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO	(IPP)	3x18.55+1x3.6	54	54	54	54	54	54				
56	Karnaphuli Power Ltd.	HFO	(IPP)	6x18.41+1x6.4	110	110	82	110	110	110				
57	Juldah unit-2 (Acorn)	HFO	(IPP)	8x13.6	100	100	0	0	100	100				
58	Chattogram 116 MW PP (Anlima Ener	HFO	(IPP)	6x21.06	116	116	0	0	116	116				
	Chattogram Zone Total				**2442**	**2382**	**838**	**1005**	**1660**	**1650**	**210**	**180**		
59	a) Ashuganj TPP Unit- 3	Gas	(APSCL)	1 x 150	150	135	0	0	0	0	135		Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas	(APSCL)	1 x 150	150	129	100	135	110	135				
	c) Ashuganj TPP Unit- 5	Gas	(APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
60	Ashuganj 50 MW PP	Gas	(APSCL)	14x3.968	53	45	23	26	26	26				
61	Ashuganj 225 MW CCPP	Gas	(APSCL)	1×142+1*75	221	221	187	219	220	220				
62	Ashuganj 450 MW CCPP(South)	Gas	(APSCL)	1x360	360	360	270	275	320	350				
63	Ashuganj 450 MW CCPP(North)	Gas	(APSCL)	1x361	360	360	265	280	320	340				
64	Ashuganj 55 MW PP (Precision)	Gas	(RPP)	15*4	55	55	56	56	55	55				
65	Ashuganj 195MW PP (APSCL-United)	Gas	(IPP)	20*9.73+1*16	195	195	8	26	26	26	169		Gas shortage	
66	Ashuganj 51 MW PP (Midland)	Gas	(IPP)	6x9.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO	(IPP)	23x7.015	150	150	28	50	143	143				
68	Titas 50 MW Peaking PP	HFO	(PDB)	6x8.92	52	52	0	50	0	50				
69	Chandpur 150 MW CCPP	Gas	(PDB)	1X106+1x57	163	163	88	127	135	140				
70	Chandpur 200MW (Desh energy)	HFO	(IPP)	12x18.415	200	200	162	179	185	185				
71	Feni 22MW PP (Doreen)	Gas	(SIPP, PDB)	8x2.90	22	22	16	19	22	22				
72	Feni 11 MW PP (Doreen)	Gas	(SIPP, REB)	4x2.90	11	11	5	11	11	11				
73	Jangalia 33MW PP (Summit)	Gas	(SIPP, PDB)	4x8.73	33	33	33	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO	(IPP)	6x8.92	52	52	34	34	43	43				
75	Cumilla 25 MW PP (Summit)	Gas	(SIPP, REB)	3x3.67+2x6.97	25	25	11	20	20	21				
76	Daudkandi 200 MW PP (B.Trac)	HSD	(IPP)	99x1.4+40x1.515+15x1.056	200	200	0	0	100	200				
77	Feni 114 MW Power Plant(Lakdanavi)	HFO	(IPP)	7*18.415+1*9.78	114	114	99	100	100	100				
78	Chowmuhani 113 MW	HFO	(IPP)	12*9.78+2*3.1	113	113	111	120	113	113				
79	Bhairob 54 MW PP	HFO	(IPP)	3x18.2	54	54	10	17	35	35				
**	Impoprt (Tripura)		India		160	160	102	124	152	180				
	Cumilla Zone Total				**3094**	**3034**	**1659**	**1952**	**2220**	**2479**	**438**	**0**		
80	RPCL 210MW CCPP	Gas	(IPP)	4x35+1x70	210	202	148	148	154	154	54		Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas	(SIPP, PDB)	8x2.90	22	22	17	20	20	20				
82	Jamalpur 95 MW PP(Powerpac)	HFO	(IPP)	12x8.924	95	95	8	8	8	8				
83	Jamalpur 115 MW PP (United)	HFO	(IPP)	12x9.87	115	115	115	115	115	115				
84	Mymensingh 200 MW PP (United)	HFO	(IPP)	21x9.780	200	200	0	182	200	200				
85	Sarishabari 3 MW Solar Plant	Solar	(IPP)	1x3	3	3	1	0	1.6	0				
86	Sutiakhali 50 MW Solar PP	Solar	(IPP)	1x50	50	50	26	0	50	0				
87	Tangail 22 MW PP(PPGL)	HFO	(IPP)	4x6.7	22	22	14	24	22	22				
	Mymensing Zone Total				**717**	**709**	**329**	**497**	**571**	**519**	**54**	**0**		

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.06.21 (Yesterday) Actual Peak Generation (MW)		09.06.21 (Today) Probable Peak Generation (MW)		08.06.21 (Yesterday) Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
							Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
88	Fenchugonj CCPP Phase-1	Gas	(PDB)	2x32+1x33	97	70	42	42	42	42		28	Under maint.	
89	Fenchugonj CCPP Phase-2	Gas	(PDB)	2x35+1x35	104	90	42	42	42	42		48	Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas	(RPP)	19x2.90	51	51	50	50	51	51				
91	Kushiara 163 MW CCPP (KP)	Gas	(IPP)	1x109+1x54	163	163	130	163	163	163				
92	Hobiganj 11MW PP Cofidence-E	Gas	(SIPP, REB)	4x2.90	11	11	5	11	11	11				
93	Shahjibazar GTPP Unit- 8 & 9	Gas	(PDB)	2x35	70	66	62	62	61	61				
94	Shajibazar 330 MW CCPP	Gas	(PDB)	2x110+1x110	330	330	163	162	162	162				
95	Shahjibazar 86MW PP (Shahjibazar)	Gas	(RPP)	32x2.90	86	86	77	83	80	83				
96	Sylhet 225 MW CCPP	Gas	(PDB)	1x142+1x89	231	231	218	226	225	226				
97	Sylhet 20 MW GTPP	Gas	(PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas	(RPP)	6x1.95	10	10	7	8	8	8				
99	Shahjahanulla 25 MW PP	Gas	(CIPP, REB)	3x9.34	25	25	8	16	15	15				
100	Bibiana-II 341 MW CCPP (Summit)	Gas	(IPP)	1x222+1x119	341	341	300	295	341	341				
101	Bibiyana-III 400 MW CCPP	Gas	(PDB)	1x285+1x115	400	400	376	376	400	400				
102	Bibiyana South 383 MW CCPP	Gas	(PDB)	1x252+1x131	383	383	400	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas	(PDB)	1x100	100	100	0	0	0	0				
	Sylhet Zone Total				**2422**	**2377**	**1898**	**1954**	**2019**	**2023**	**0**	**76**		
104	Bheramara GTPP Unit- 3	HSD	(PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCPP	Gas	(NWPGCL)	1 x 278+1 x 132	410	410	330	300	340	360	110		Gas Shortage	
106	Faridpur 50 MW Peaking PP	HFO	(PDB)	8x6.98	54	54	0	20	20	20				
107	Gopalganj 100 MW Peaking PP	HFO	(PDB)	16x6.98	109	109	0	0	60	60				
108	Khulna 225 MW CCPP	HSD	(NWPGCL)	1 x 150+1x75	230	230	0	80	0	220				
109	Khulna 115 PP MW (KPCL-2)	HFO	(QRPP)	7x17	115	115	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD	(IPP)	70x1.4+7x1.515	100	100	0	100	50	100				
111	Noapara 40 MW PP (Khanjahan Ali)	HFO	(QRPP)	5x8.5	40	40	0	0	0	0				
112	Rupsha 105 MW PP (Orion rupsha)	HFO	(IPP)	6x18.445	105	105	5	105	105	105				
113	Madhumati 100 MW PP	HFO	(NWPGCL)	6x18.415	105	105	0	0	100	100				
**	Bheramara (HVDC)		India		1000	1000	814	905	927	927				
	Khulna Zone Total				**2288**	**2284**	**1149**	**1510**	**1602**	**1892**	**110**	**0**		
114	Barisal 110 MW PP (Summit)	HFO	(IPP)	7 x 17.076	110	110	0	0	110	110				
115	Bhola 33 MW PP (Venture)	Gas	(RPP)	1x34.50	33	33	17	28	33	33				
116	Bhola 225 MW CCPP	Gas	(PDB)	2x63+1x68	194	194	65	64	65	65		130	GT-2 & STG Under	
117	Bhola 95 MW PP (Aggreko)	Gas	(QRPP)	1.1x96	95	95	32	31	12	12				
118	Payra 1320 MW TPP	Coal	(BCPCL)	2x622	1244	1244	350	510	622	622				
119	Potuakhali 150MW PP (UPPL)	HFO	(IPP)	8x18.415+1x9.78	150	150	0	0	0	110				
	Bhola Nutan Biddut BD LTD	Gas/HSD	(IPP)				55	201	228	233				
	Barishal Zone Total				**1826**	**1826**	**519**	**834**	**1070**	**1185**	**0**	**130**		
120	a) Baghabari 71 MW GTPP	Gas	(PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas	(PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
121	Baghabari 50 MW Peaking PP	HFO	(PDB)	6x8.9	52	52	43	50	50	50				
122	Baghabari 200 MW PP (Paramount)	HSD	(IPP)	135x1.6	200	200	0	0	200	200				
123	Bera 70 MW Peaking PP	HFO	(PDB)	9x8.29	71	71	0	46	51	51				
124	Amnura 50 MW PP(Sinha)	HFO	(QRPP)	7x7.79	50	50	0	35	35	35				
125	Chapainawabganj 100 MW Peaking PI	HFO	(PDB)	12x8.924	104	104	24	85	50	90				
126	Katakhali 50 MW Peaking PP	HFO	(PDB)	6x8.7	50	50	0	38	40	40				
127	Katakhali 50 MW PP (Northern)	HFO	(QRPP)	6x8.9	50	50	0	43	43	43				
128	Santahar 50 MW Peaking PP	HFO	(PDB)	6x8.7	50	50	0	32	0	35				
129	Sirajgonj 225MW CCPP Unit-1	Gas	(NWPGCL)	1x150+1x75	210	210	100	106	100	100	44		Gas Shortage, STG S/D	
130	Sirajgonj 225MW CCPP Unit-2	Gas	(NWPGCL)	1x150 + 1x75	220	220	159	132	155	155	88		Gas Shortage	
131	Sirajgonj 225MW CCPP Unit-3	Gas	(NWPGCL)	1x141+1x79	220	220	190	186	185	185				
132	Sirajgonj 400 MW CCPP Unit-4	Gas	(IPP)	1x282+1x132	414	414	365	400	400	400				
133	Bogra 22 MW PP (GBB)	Gas	(RPP)	6x4.0	22	22	21	22	22	22				
134	Ullapara 11 MW PP (Summit)	Gas	(SIPP, REB)	4x2.90	11	11	8	11	11	11				
135	Natore 52 MW PP (Rajlanka)	HFO	(IPP)	6x8.92	52	52	43	43	34	52				
136	Bagura 113 MW PP (Confidence) Unit-1	HFO	(IPP)	6*18.55	113	113	35	113	113	113				
137	Bagura 113 MW PP (Confidence) Unit-2	HFO	(IPP)	6x18.55	113	113	59	113	113	113				
138	Sirajgonj 6.55 MW Solar	Solar	(NWPGCL)	1x6	6	6	3	0	6	0				
	Rajshahi Zone Total				**2179**	**2179**	**1050**	**1455**	**1608**	**1695**	**303**	**0**		
139	a) Barapukuria TPP Unit-1	Coal	(PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal	(PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
140	Barapukuria 275 MW TPP Unit-3	Coal	(PDB)	1 x 274	274	274	150	150	150	150	124		Coal Shortage	
141	Rangpur 20 MW GTPP	HSD	(PDB)	1 x 20	20	20	0	0	0	10				
142	Rangpur 113 MW PP (Confidence)	HFO	(IPP)	7*16x 2*3	113	113	34	113	113	113				
143	Saidpur 20 MW GTPP	HSD	(PDB)	1 x 20	20	20	0	0	0	10				
144	Majpara, Tatulia 8 MW Solar PP (Sympa Powe	Solar	(IPP)	1 x 8	8	8	3	0	8	0				
	Rangpur Zone Total				**685**	**605**	**187**	**263**	**271**	**283**	**294**	**0**		
	Sub-total: Plants in operation				**21729**	**21315**	**9916.0**	**12411**	**14466**	**15482**	**1746**	**1843**		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							**9400**	**11765**	**13713**	**14676**				
(B) Plants under long term maintenance/ contract expired														
145	Ghorashal 78.5 MW PP(MAX)	Gas	(QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021	
146	Madanganj 102 PP(Summit)	HFO	(QRPP)	6x17	102	0	0	0	0	0				
147	Fenchuganj 44MW (Energyprima)	Gas	(RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021	
148	Sylhet 50MW PP (EPL)	Gas	(RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020	
149	Bogura 20 MW PP (Energyprima)	Gas	(RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
	Sub-Total: Plants under long term maintenance/ contract expired				294	0	0	0	0	0				
	Gross Total				**22023**	**21315**	**9916**	**12411**	**14466**	**15482**	**1746**	**1843**		

(C) Actual data of 08.06.21 (Yesterday) Tuesday :

01.	Max. Demand at eve. peak (Generation end)	:	12411.00	MW, at =	21:00 hrs
02.	Max. Demand at eve. peak (Sub-station end)	:	11765.00	MW, at =	21:00 hrs
03.	Highest Generation (Generation end)	:	12411.00	MW, at =	21:00 hrs
04.	Minimum Generation (Generation end)	:	8374.00	MW, at =	7:00 hrs
05.	Day-peak Generation (Generation end)	:	9916.00	MW, at =	12:00 hrs
06.	Evening-peak Generation (Generation end)	:	12411.00	MW, at =	21:00 hrs
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at =	21:00 hrs
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9143.00	MW, at =	5:00 hrs
09.	Generation shortfall at evening peak due to :	:			
	a) Gas limitation	:	1242	MW	
	d) Coal supply Limitation	:	294	MW	
	b) Low water level in Kaptai lake	:	210	MW	
	c) Plants under shut down/ maintenance	:	1843	MW	
10.	Total Energy (Generation + India Import)	:	248.54	MKWh	
	By Gas = 153.428 MKWH		By Oil =	57.750 MKWh	
	By Coal = 14.284 MKWH		By Hydro =	0.484 MKWh	
	By Solar= 0.524 MKWH				
11.	Total Gas Supplied	:	1238.47	MMCFD	

12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :

Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
Dhaka	4082	4082	0	Mymensingh	987	987	0
Chattogram	1248	1248	0	Sylhet	480	480	0
Khulna	1531	1531	0	Barishal	316	316	0
Rajshahi	1339	1339	0	Rangpur	732	732	0
Cumilla	1050	1050	0				
				Total	11765	11765	0

13.	Fuel cost :	(a) Gas = 164382086 Taka	(c) Coal =	66483407	Taka
		(b) Oil = 445899429 Taka	Total =	676764922	Taka
14.	Maximum Temperature in Dhaka was :	31.1° C			
15.	Export through East-West interconnections :				
	At evening peak-hour	:	-98	MW, at	21:00 hrs
	Maximum	:	-102	MW, at	5:00 hrs
	Energy	:	0.5565	MKWh	

(D) Forecast of 09.06.21 (Today) Wednesday :

01.	Maximum Demand	:	13000	MW	(Generation end)	04.	Maximum Load-shed	: 0	MW At evening peak (Sub-station end)
02.	Maximum Generation	:	15482	MW	(Generation end)	05.	Total Generation	: 260.34	MKWh
03.	Maximum Shortage	:	-2482	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	31.5° C	

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faozul Islam Shaker)
Deputy Secretary, Generation