

Date : 13-Jun-21		Page -2					
Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour	Energy Generated	Remarks
			Unit No. X Capacity	MW	Generation	KWH	
				MW			
1	Ghorasal Repowered CAPP Unit-3	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CAPP Unit-2	PDB	1*210	180	0	0	Under maint.
3	Ghorasal TPP Unit-5	PDB	1*210	190	185	4410000	
4	Ghorasal 365 MW CAPP Unit-7	PDB	1*243+1*122	365	0	0	Under maint.
5	Ghorasal 78.5 MW PP(MAX)	QRPP	2*40	0	0	0	Contract Expired
6	Ghorasal 108MW PP (Regent)	IPP	3*43.35	108	98	2231000	
7	Harihar GTPP	SBU, PDB	2*32	20	0	0	Under maint.
8	Harihar 412 MW CAPP	EGCB	1*273+1*139	412	0	0	Under maint.
9	Harihar 360MW CAPP(HPL)	IPP	1*235+1*125	360	70	3084000	Gas shortage
10	Meghnaghat 450 MW CAPP(MPL)	IPP	2*150+1*150	450	300	7124250	Gas shortage
11	Meghnaghat 100 MW(IELE)	QRPP	12*8.9	100	0	0	Contract Expired
12	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	305	275	6370415	FGMO
13	Madangan 102 PP(Summit)	QRPP	6*17	0	0	0	Contract Expired
14	Madangan 35 MW PP(Summit)	(IPP)	3*11.08+1*11.3	55	55	914287	
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	100	74	758815	Engine problem
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	21	466596	
17	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
18	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	0	770000	Gas shortage
19	Siddhirgonj 100 PPI(Dutch Bangla)	QRPP	12*8.9	100	100	2122960	
20	Siddhirgonj 335 MW CAPP	EGCB	1*217+1*118	335	331	7566376	
21	Gaguar 102 MW PP (Digital Po)	IPP	12*8.924	102	102	1539648	
22	Kalpott 52 MW PP (Sinha)	IPP	7*7.9	51	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco En)	IPP	3*18	54	54	1310760	
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	133	2847840	Engine problem
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	510774	
26	Nababganj 55 MW PP (Southern)	IPP	3*19.3	55	35	902204	Engine problem
27	Bostia 108MW PP(CLO)	IPP	12*9.775+1*9.5	108	0	0	Fuel shortage
28	Summit Power (Madhabdi+Ashuli)	SIPP, REB	3*3.67+4*8.73	80	53	1267800	Engine problem
29	Maona 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	822900	
30	Ruggan 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	783200	
31	Gazipur 52 MW PP	IPP	6*8.9	52	42	578880	Engine problem
32	Tongi 80 MW GTPP	PDB	1*105	0	105	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summ)	IPP	18*17.076	300	226	3562908	Engine problem
34	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	258	1035516	Low demand
35	Bramhangonj 100 MW PP (Aggr)	IPP	100	100	100	324434	
36	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	101	414579	
37	Kodda 149 MW PP Unit-1 (Summ)	IPP	149	149	131	2233008	Engine problem
38	Gazipur 100 MW PP	RPCL	100	105	88	2106000	Engine problem
39	Meghnaghat 104 MW PP (OPCL)	IPP	18*5.6	104	90	1299940	Engine problem
40	Manikganj 162MW PP(MPL)	IPP	9*18	162	126	2704320	Engine problem
41	Spectra Solar Plant Ltd.	IPP	35	35	0	177011	
Dhaka area Total				5919	3169	60243921	
42	Chattogram TPP-1	PDB	1*210	180	100	2300000	Gas shortage
43	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
44	Razzan 25 MW PP	IPP	3*9.9	25	17	350965	Engine problem
45	Teknaf 20MW PP (Solartech/Teknaf Solartech)	Energy	20	20	0	98835	
46	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	41	514080	Engine problem
47	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	25	604000	Low water level & Unit-2 undr
48	Sikalbaha 225MW	PDB	1*150+1*175	225	203	4880312	FGMO
49	Sikalbaha Peaking GT	PDB	1*150	150	100	2402494	Machine problem
50	Sikalbaha 105 MW PP (Baraka S)	IPP	105 MW	105	105	2605272	
51	Hathazari 100 MW Peaking PP	PDB	11*9.9	99	0	0	Under S/D
52	Dohazari-Kalesh 100 MW Peakin	PDB	6*17	102	85	1384682	Engine problem
53	Judah 100 MW Unit-1 (Acorn)	QRPP	8*13.45	100	100	2148720	
54	Judah 100 MW PP Unit-3 (Acorn)	IPP	0	100	100	2112000	
55	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	0	0	Engine problem
56	Malancha, Ctg. EPZ (United)	IPP	5*8.73+3*9.34	0	32	428160	
57	Chattogram 108 MW PP (ECPV)	IPP	18*6	108	0	0	Fuel shortage
58	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	32039	
59	Anwara 300 MW PP (United)	IPP	300 MW	300	0	0	Transformer OIL
60	Jodac Power	IPP	3*18.55+1*3.6	54	54	1298101	
61	Karnaphuli Power Ltd.	IPP	110	110	110	2632024	
62	Judah unit-2 (Acorn)	IPP	8*13.6	100	100	1787520	
63	Anilma Energy Ltd.	IPP	6*21.2	116	17	288545	Transformer OIL
Chattogram area Total				2382	1189	25805749	
64	Ashuganj TPP Unit-3	APSCL	1*150	135	80	2056288	Gas Shortage
65	Ashuganj TPP Unit-4	APSCL	1*150	129	0	0	Gas shortage
66	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Under maint.
67	Ashuganj 225 MW CAPP	APSCL	1*142+1*75	221	200	4882000	FGMO
68	Ashuganj 450 MW CAPP(North)	APSCL	1*360	360	260	7094800	FGMO
69	Ashuganj 450 MW CAPP(South)	APSCL	1*360	360	260	6697000	FGMO
70	Ashuganj 50 MW CAPP	APSCL	14*3.988	45	23	431928	Engine problem
71	Ashuganj 55 MW PP (Precision)	RPP	15*4	55	25	701280	Gas shortage
72	Ashuganj 195MW PP (APSCL-UH)	IPP	20*9.73+1*16	195	8	451636	Gas shortage
73	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1238894	
74	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	40	1589090	R/H problem at Ashuganj Net
75	Titas 50 MW Peaking PP	PDB	6*8.92	52	49	577656	
76	Chandpur 150 MW CAPP	PDB	1*106+1*57	163	130	3149390	
77	Chandpur 200MW (Desh energy)	IPP	0	200	179	3870720	Machine problem
78	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	423000	Engine problem
79	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	209160	
80	Impoport (Tripura)	Imported power	0	160	150	3204480	
81	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	816300	
82	Jangalia 52 MW PP (Ikdanaw)	IPP	6*8.92	52	43	574890	Engine problem
83	Cumilla 25 MW PP (Summit)	SIPP, PDB	3*3.67+2*9.97	25	21	497350	Engine problem
84	Daudkandi 200 MW PP (B. Trac)	IPP	154*1.4	200	200	834240	
85	Feni Lanka Power	IPP	7*18.415+1*9.78	114	100	2079360	Engine problem
86	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	117	2688840	
87	Bhairab 54.5 MW	IPP	3*18.2	54	35	882720	33 kV feeder fault.
Cumilla Area Total				3034	2034	44591022	
88	RPCL 210MW CAPP	IPP	4*35+1*70	202	119	2849323	Gas shortage
89	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	21	444816	
90	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	95	8	192960	Engine problem
91	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	14450	
92	Mymensingh 200 MW PP (Unite)	IPP	200	200	172	2481600	Engine problem
93	Jamalpur 115 MW PP (Unite)	IPP	115 MW	115	115	2676000	
94	Sylhet 50 MW Solar PP	IPP	50	50	0	361750	
95	Tangail Fall Power 22 MW	IPP	4*6.7	22	6	128800	Engine problem
Mymensingh Area Total				709	441	9103696	
96	Fenchugonj CAPP Phase-1	PDB	2*32+1*33	70	0	0	Under maint.
97	Fenchugonj CAPP Phase-2	PDB	2*35+1*35	90	42	975240	Machine problem
98	Kushara 163 MW CAPP (KP)	IPP	1*109+1*54	163	163	3485127	
99	Shahjibazar 330 MW CAPP	PDB	3*110	330	163	3597000	GT-1 under maint
100	Fenchugonj 51 MW PP (Barakati)	RPP	19*2.90	51	47	990000	
101	Fenchugonj 44MW (Energy/Trima)	RPP	12*3.3+5*2	0	0	0	Contract Expired
102	Hobiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	11	179856	
103	Shahjibazar GTPP Unit- 8 & 9	PDB	2*35	66	61	1466976	
104	Shahjibazar 86MW PP (Shahjibaz)	RPP	32*2.90	86	81	1827840	
105	Shahjibazar 100 MW GTPP	PDB	1*100	100	0	0	Under Shut down
106	Sylhet 225 MW CAPP	PDB	1*142+1*89	231	192	5060500	
107	Sylhet 20 MW GTPP	PDB	1*20	20	0	235000	
108	Sylhet 50MW PP (EPL)	RPP	27*2	0	0	0	Contract Expired
109	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	364320	Engine problem
110	Bibiana-II 341 MW CAPP (Summ)	IPP	1*222+1*119	341	290	7095000	FGMO
111	Bibiana-III 400 MW CAPP	PDB	400 MW	400	315	8521000	
112	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	219420	
113	Bibiana South 400 MW	PDB	400 MW	383	310	8283900	
Sylhet Area Total				2377	1701	42316479	
114	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	
115	Bheramara (HVDC)	Imported power	2*500	1000	899	2158545	
116	Khulna 115 PP MW (KPLC-2)	QRPP	7*17	115	0	0	Contract Expired
117	Fairdip 50 MW Peaking PP	PDB	6*8.89	54	19	99830	Engine problem
118	Khulna 225 MW CAPP	NWPGCL	1*150+1*75	226	165	621219	Low demand
119	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Reserve.
120	Bheramara 410 MW CAPP	NWPGCL	1*278+1*132	410	360	8630496	FGMO
121	Noapara 40 MW PP (Khanjahan A)	QRPP	5*8.5	40	0	0	Contract Expired
122	Noapara 100 MW PP (Bangla Tra)	IPP	70*1.4	100	100	562560	
123	Rupsha 105 MW PP (Orion rupsh)	IPP	6*18.445	105	91	1764960	Engine problem
124	Madhumati 100 MW PP	NWPGCL	100 MW	105	0	0	Reserve.
Khulna Area Total				2284	1634	33437610	
125	Basirdal 110 MW PP (Summit)	IPP	7*17.076	110	16	119808	Line OIL
126	Bhola 33 MW PP (Venture)	RPP	1*34.50	33	33	601167	
127	Bhola 225 MW CAPP	PDB	2*63+1*68	194	84	2066872	Machine problem
128	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	95	12	305272	Gas shortage
129	Payra 1320 MW	BCPCL	2*622	1244	520	11574200	
130	Bhola Nutan Biddut BD LTD	IPP	220	0	221	4569100	On Test
131	United Payra Power Ltd.	IPP	8*18.8+1*9.5	150	0	0	Reserve.
Barisal Area Total				1826	886	19236419	
132	Baghbari 71 MW GTPP	PDB	1*71	71	0	0	Gas shortage
133	Baghbari 100 MW GTPP	PDB	1*100	100	0	0	Gas shortage.
134	Baghbari 50 MW Peaking PP	PDB	6*8.9	52	50	760832	
135	Bera 70 MW Peaking PP	PDB	9*8.29	71	50	273026	Engine problem
136	Amnara 50 MW PP(Sinha)	QRPP	7*7.9	50	18	579230	Engine problem
137	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	34	285312	Engine problem
138	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	23	184247	Engine problem
139	Sirajgonj Unit-1 225MW	NWPGCL	1*150+1*75	210	0	0	Gas shortage
140	Sirajgonj Unit-2 225MW	NWPGCL	1*150+1*75	220	192	4338818	Gas shortage
141	Sirajgonj Unit-3 225MW	NWPGCL	1*141	220	193	4389818	FGMO and Gas shortage
142	Sirajgonj 400 MW CAPP Unit-4	SNWPGCL	1*282+1*132	414	406	8804400	FGMO
143	Santihar 50 MW Peaking PP	PDB	6*8.9	50	38	2845983	Engine problem
144	Bogra 22 MW PP (GBB)	RPP	6*4	22	22	491280	
145	Bogura 20 MW PP (Energyprima)	RPP	5*3.3+5*2	0	0	0	Contract Expired
146	Ullapara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	8	161154	Engine problem
147	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52	52	1081920	
148	Chapainawabganj 100 MW Peakin	PDB	12*8.924	104	96	1610200	Engine problem
149	Baghura 200 MW PP (Paramou)	IPP	200 MW	200	50	143945	Low demand
150	Bagura 113 MW PP (Confidence)	IPP	113 MW	113	113	2032320	
151	Confidence Power Bogura Unit-1	IPP	6*18.55	113	113	1876512	
152	Sirajgonj 6.						