POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

Reporting Date: 22-Jun-21 QF-LDC-08

Till now the maximum generation is: -13792.0 27-Apr-21 20:00 Hrs on The Summary of Yesterday's 21-Jun-21 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 8623 MW 10314 0 MW 12:00 Min. Gen. at 8:00 Available Max Generation 15299 MW 12356.0 MW Evening Peak Generation 21:00 Max Demand (Evening) E.P. Demand (at gen end) 12356.0 MW 21:00 12500 MW Maximum Generation 12356.0 MW 21:00 Reserve(Generation end) 2799 MW Total Gen. (MKWH) 246.3 System Load Factor : 83.06%

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Load Shed 0 MW

Export from East grid to West grid :- Maximum -196 MW 19:30 Energy MKWHR. at Import from West grid to East grid :- Maximum MW MKWHR Energy 22-Jun-21

Water Level of Kaptai Lake at 6:00 A M on Ft.(MSL) Rule curve : 81.57 Actual 75.18

> HSD Liter FO Liter

Cost of the Consumed Fuel (PDB+Pvt) : Gas Tk162 403 687

Total =

Tk62,263,155 : Tk391,374,456 Total: Tk616,041,298 Oil

Oil Consumed (PDB)

Ft.(MSL)

Load Shedding & Other Information

1238.47 MMCFD.

Area	Yesterday		Today		
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
	MW		MW	MW	(On Estimated Demand)
Dhaka	0	0:00	4353	0	0%
Chittagong Area	0	0:00	1483	0	0%
Khulna Area	0	0:00	1329	0	0%
Rajshahi Area	0	0:00	1201	0	0%
Cumilla Area	0	0:00	1086	0	0%
Mymensingh Area	0	0:00	876	0	0%
Sylhet Area	0	0:00	486	0	0%
Barisal Area	0	0:00	225	0	0%
Rangpur Area	0	0:00	676	0	0%
Total	0		11716	0	

Information of the Generating Units under shut down.

Planned Shut- Down	Forced Shut-Down	
	1) Barapukuria ST: Unit-1,2	
	2) Ghorasal-3,4,7	
	3) Ashuganj-4	
	4) Kaptai-2	
	5) Raozan #2	
	6) Bhola 225 MW GT-2	
	7) Chandpur-150 MW ST	
	,	

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

- a) Ghorashal-Ashuganj 132 kV Ckt-1 was shut down at 08:22 for D/W
- b) Lalbagh-Kallyanpur 132 kV Ckt-1 was shut down at 09:48 for C/M.
 c) Lalbagh-Bosila-Aminbazar 132 kV Ckt was under shut down from 09:26 to 21:16 for C/M.
- d) Halishahar 132/33 kV T-1 transformer was under shut down from 10:01 to 11:28 C/M
- e) Sikalbaha 230 kV Bus-2 was shut down at 10:30 for D/W.

Gas Consumed :

- f) Halishahar 132/33 kV T-2 transformer was under shut down from 11:36 to 12:07 C/M.
- g) Payra Unit-1 tripped at 11:38 due to low grid voltage and was synchronized at 11:51. h) After maintenance Ashuganj 230 kV Bus-Coupler was switched on at 13:02.
- i) Halishahar-Rampur 132 kV Ckt-1 was under shut down from 12:32 to 13:17 for C/M.
- j) Savar 132/33 kV T-3 transformer was under shut down from 08:51 to 15:14 for D/W. k) Tongi 132/33 kV T-1 transformer was under shut down from 10:02 to 16:02 for D/W.
- I) After maintenance Natore 132/33 kV T-2 transformer was switched on at 14:22
- m) After maintenance Gopalganj-Gollamari 132 kV Ckts 1 & 2 were switched on at 16:32. n) Bogura(N)-Naogaon 132 kV Ckts 1 & 2 were shut down at 16:25 for D/W.
- o) Hasnabad 132/33 kV T-1 & T-5 transformers tripped at 15:54 only 33 kV side showing O/C relay due to
- Nobabganj-2 PBS feeder problem and was switched on at 16:13. p) Netrokona 132/33 kV T-3 transformer was under shut down from 16:17 to 16:21 for D/W.
- q) Netrokona 132/33 kV T-4 transformer was under shut down from 16:31 to 17:15 for D/W.
- r) Sherpur-Mymensingh United 132 kV Ckt-2 was under shut down from 16:16 to 16:57 for emergency tree
- s) Ghorashal unit-7 GT synchronized at 20:50 and tripped at 21:02 due to gas detection system failed.
- t) Baghabari 71 MW GT was synchronized at 21:12.
- u) Mongla 132/33 kV T-1 & T-2 transformers tripped at 18:58 only 33 kV side showing E/F relay due to contact with bird at 33 kV side and were switched on at 19:19. v) Khulna 225 MW CCPP GT was shut down at 23:48 due to low demand.
- w) Natore-Bogura 132 kV Ckt-2 tripped at 01:16(22/6/2021) from Natore end showing Dist. CAT,CE,CD and was switched on at 01:36.
- x) Siddhirganj 335 MW CCPP GT tripped at 06:27 due to tripping of gas booster compressor.
- y) Kabirpur-Manikganj 132 kV Ckt-2 was shut down at 06:57(22/6/2021) for wave trap dismantling. z) Mymensingh S/S-Mymensingh RPCL 132 kV Ckt-1 was shut down at 07:01(22/6/2021) for CT replacement
- aa) Naogaon-Bogura 132 kV Ckt-2 was shut down at 06:20(22/6/2021) for D/W.
- ab) Raozan unit-1 tripped at 07:01(22/6/2021) due to tripping of boiler and was synchronized at 07:38
- ac) Ashuganj-Sirajganj 230 kV Ckt-1 was shut down at 07:30(22/6/2021) for C/M.
- ad) Faridpur-Bheramara 132 kV Ckt-1 was shut down at 07:09(22/6/2021) for D/W
- ae) Khulna(C) 132 kV main Bus section-1 was shut down at 08:06(22/6/2021) for C/M.
- af) Ashuganj 230 kV Bus-1 was shut down at 09:03(22/6/2021) for C/M.

Sub Divisional Engineer **Executive Engineer** Network Operation Division Network Operation Division About 62 MW power interruption occurred under Hasnabad S/S area from 15:54 to 16:13

About 15 MW power interruption occurred under Netrokona S/S area from 16:31 to 17:15.

About 24 MW power interruption occurred under Mongla S/S area from 18:58 to 19:19

> Superintendent Engineer Load Despatch Circle