

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564687, 9551095

Month June, 2021		Day : Friday				Date : 25.06.21					
Probable Maximum Demand :		11800 MW		Probable Maximum Generation :		15711 MW					
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 75.28 ft		Today = 75.44 ft		Rule Curve = 82.38 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.06.21 (Yesterday)		25.06.21 (Today)		24.06.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	185	185	185	185		
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254-1x 126	365	365	190	190	200	200		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	95	96	100	100		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235-1x125	360	360	211	210	300	300	150	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140-1x170	450	450	300	300	300	300	150	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	341	333	350	350		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	3	220	220		
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	88	80	100	100		
14	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110-1x110	305	305	235	260	250	300		
15	Madangan-55 MW PP(Summit)	HFO (IPP)	5x17.08-1x11.3	55	55	0	55	55	55		
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	79	70	100		
17	Gangagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	93	100	102		
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	21	22	22		
19	Summit Power, (Madhab+Ashulia)	Gas (SIPP, PDB)	6x3.07+4x3.73	80	80	55	55	55	55		
20	Maona 33 MW PP(Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
21	Rupganj 33 MW PP(Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	29	50	51	51		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105		
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	64	150	133	150		
25	Katpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
26	Kamalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	143	260	290	290		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	133	132	135	135		
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300		
30	Bramangan 100 MW PP (Aggreko)	HSD (IPP)	23x0.85-91x.959	100	100	0	0	100	100		
31	Aushali 100MW PP (Aggreko)	HSD (IPP)	23x0.85-91x.959	100	100	0	0	100	100		
32	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	55	55	55		
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	55	55		
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	104	90	104		
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	98	126	126	162		
37	Manikganj 33MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	12	0	30	0		
Dhaka Zone Total				5976	5819	2529	3117	3797	4116	510	680
38	Karnaphuli Hydro PP Unit-1,2,3,4,5	Hydro (PDB)	2x40, 3x50	230	230	25	26	51	51	204	Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	6	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	11	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x8.89	50	50	0	24	40	45		
44	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	105	105	105	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	100	100	100	100		
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150-1 x 75	225	225	210	203	220	220		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076-3x8.04	300	300	0	0	300	300		
48	Juldah 100 MW Unit-1 (Accorn)	HFO (QRPP)	8x13.45	100	100	80	100	100	100		
49	Juldah 100 MW PP Unit-3 (Accorn)	HFO (IPP)	8x13.45	100	100	50	70	100	100		
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	102	102		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
*	Malancha Ctg EPZ (United)	Gas	5x8.73-3x9.34			8	29	30	40		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	17	54	54		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110		
56	Juldah unit-2 (Accorn)	HFO (IPP)	8x13.5	100	100	10	100	100	100		
57	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	17	53	116	116		
Chattogram Zone Total				2442	2382	907	1178	1692	1682	204	180
58	a) Ashuganj TPP Unit-3	Gas (APSCL)	1 x 150	150	135	80	80	100	100	55	Gas Shortage
	b) Ashuganj TPP Unit-4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit-5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	26	26	26	26		
60	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	198	216	220	220		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	315	300	330	330		
62	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	330	310	330	330		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	52	47	55	55		
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	36	36	36	36	159	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	50	50		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	130	130	150	150		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106-1x57	163	163	90	89	90	90		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	178	160	160	180		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	17	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, PDB)	4x2.90	11	11	8	11	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	25	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	34	34	34	34		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, PDB)	3x3.67+2x6.97	25	25	19	21	21	21		
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	9x14.4x8.135-1x11.08	200	200	0	0	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	70	114	100	100		
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	115	118	113	113		
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	18	36	35	35		
**	Impoirt (Tripura)	India		160	160	116	134	151	180		
Cumilla Zone Total				3094	3034	1918	2005	2167	2366	477	0
79	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	132	143	160	160	59	Gas Shortage
80	Tangai 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21		
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	8	8	8		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115		
83	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	65	197	175	195		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
85	Sutakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	16	0	50	0		
86	Tangai 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	24	24	22	22		
Myensingh Zone Total				717	709	374	508	553	521	59	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	24.06.21 (Yesterday)		25.06.21 (Today)		24.06.21 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)				
87	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	43	44	44		27	Under maint.		
88	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	Under maint.		
89	Fenchuganj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	44	50	51	51					
90	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163					
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP_REB)	4x2.90	11	11	5	1	11	11					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	61	62	62					
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	161	163	162	164					
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	83	0	84	84					
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	218	218	225	225					
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP_REB)	3x9.34	25	25	10	16	16	16					
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	280	341	341					
100	Bibiyana-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	389	367	400	400					
101	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	390	400	400	400					
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0					
Sylhet Zone Total					2422	2377	1912	1832	2029	2031	0	75		
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
104	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278-1 x 132	410	410	380	385	385	385					
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	20					
106	Capalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60					
107	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150-1x75	230	230	0	0	0	160					
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100					
109	Rupsha 105 MW PP (Onon rupsha)	HFO (IPP)	6x18.445	105	105	0	91	90	90					
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100					
**	Bheramara (HVDC)	India		1000	1000	907	898	898	898					
Khulna Zone Total					2133	2129	1287	1474	1603	1813	0	0		
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	110	110					
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	19	33	25	25					
113	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	86	83	85	86		111	G1-Z & STG Under maint.		
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	12	12	12					
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	380	490	622	622					
116	Potakhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	110					
Bhola Nutan Biddut BD LTD							182	220	220	220				
Barishal Zone Total					1826	1826	678	854	1074	1185	0	111		
117	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	50	65	65		21	Gas Shortage		
117	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage		
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	34	43	50	50					
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	34	30	40					
121	Amnura 50 MW PP(Siraha)	HFO (QRPP)	7x7.79	50	50	0	35	35	35					
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	47	94	95	95					
123	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	37	40	40					
124	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	43	43					
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	35					
126	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	150			Gas Shortage, STG S/D		
127	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	167	178	200	200					
128	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	194	186	200	200					
129	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	406	402	400	400					
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	22	22	22					
131	Ullapara 11 MW PP (Summit)	Gas (SIPP_REB)	4x2.90	11	11	8	8	11	11					
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	43	52	52					
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	0	113	113	113					
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	94	113	113					
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0					
Rajshahi Zone Total					2179	2179	932	1373	1675	1714	271	0		
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	85			Coal Shortage		
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	85			Coal Shortage		
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	149	150	150	150		124	Coal Shortage		
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	34	113	113	113					
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
141	Majpara, Tabula 8 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 8	8	8	5	0	8	0					
Rangpur Zone Total					685	605	188	263	271	283	294	0		
Sub-total: Plants in operation					21474	21060	10725.0	12604	14861	15711	1815	1046		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							10210	11999	14147	14957				
(B) Plants under long term maintenance/ contract expired														
142	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021		
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
144	Fenchuganj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021		
145	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020		
146	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
147	Meghnaghat 100 MW(IEEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
149	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	0	0	0	0	0			Contract Expired on 28/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired					549	0	0	0	0	0	0	0		
Gross Total					22023	21060	10725	12604	14861	15711	1815	1046		
(C) Actual data of 24.06.21 (Yesterday) Thursday :														
01.	Max. Demand at eve. peak (Generation end)	:	12604.00	MW,	at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	11999.00	MW,	at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	12604.00	MW,	at =	21:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	9434.00	MW,	at =	7:00 hrs	Dhaka	4272	4272	0	Mymensingh	989	989	0
05.	Day-peak Generation (Generation end)	:	10725.00	MW,	at =	12:00 hrs	Chattogram	1165	1165	0	Sylhet	516	516	0
06.	Evening-peak Generation (Generation end)	:	12604.00	MW,	at =	21:00 hrs	Khulna	1448	1448	0	Barishal	362	362	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	21:00 hrs	Rajshahi	1289	1289	0	Rangpur	794	794	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9074.00	MW,	at =	5:00 hrs	Cumilla	1164	1164	0				
09.	Generation shortfall at evening peak due to :	:									Total	11999	11999	0
a)	Gas limitation	:	1317	MW			13.	Fuel cost :	(a) Gas = 168718308	Taka	(c) Coal = 69947769	Taka		
d)	Coal supply Limitation	:	294	MW					(b) Oil = 484882374	Taka	Total = 723548452	Taka		
b)	Low water level in Kaptai lake	:	204	MW										
c)	Plants under shut down/ maintenance	:	1046	MW			14.	Maximum Temperature in Dhaka was :			32.7° C			
10.	Total Energy (Generation + India Import)	:	266.66	MKWh			15.	Export through East-West interconnections :						
	By Gas = 161.570	MKWH	By Oil = 64.252	MKWh				At evening peak-hour :	-158	MW,	at	21:00 hrs		
	By Coal = 15.071	MKWH	By Hydro = 0.522	MKWh				Maximum	-158	MW,	at	21:00 hrs		
	By Solar = 0.584	MKWH						Energy	: 0.7475	MKWh				
11.	Total Gas Supplied	:	1270.77	MMCFD										
(D) Forecast of 25.06.21 (Today) Friday :														
01.	Maximum Demand	:	11800	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15711	MW	(Generation end)		05.	Total Generation	:	249.65	MKWh			
03.	Maximum Shortage	:	-3911	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka :	:	34.4° C				

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzi Islam Shaker)
Deputy Secretary, Generation