

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564687, 9551095

Month July, 2021		Day: Sunday				Date: 04.07.21					
Probable Maximum Demand :		12000 MW		Probable Maximum Generation :		15507 MW					
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 78.38 ft		Today = 79.16 ft		Rule Curve = 84.48 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.07.21 (Yesterday)		04.07.21 (Today)		03.07.21 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 210	260	260	0	0	0	0	260	Under maint.
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under Repowering
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maint.
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254-1x 126	365	365	300	300	300	300		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	89	98	100	100		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Hanipur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Under Maint.
7	Hanipur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	343	341	350	360		
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	310	310	300	310	140	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hanipur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	360	340	350	360		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	103	222	220	220		
13	Siddhirgonj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	100	0	95	100	100		
14	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	305	305	265	270	300	300		
15	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	55	55		
16	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	0	70	100		
17	Gaganagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	0	100	102		
18	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	15	19	19	19		
19	Summit Power, (Madhab+Ashulia)	Gas (SIPP, PDB)	6x3.07+4x3.73	80	80	53	55	55	55		
20	Maona 33 MW PP(Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
21	Ruganaj 33 MW PP(Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
22	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	37	42	51	51		
23	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	85	86	84	86		
24	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	16	150	150	150		
25	Katpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0		
26	Kamalghat 54 MW PP (Barco Energy)	HFO (IPP)	3x18.69	54	54	35	35	54	54		
27	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	15	250	290		
28	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	30	80	130	132		
29	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300		
30	Bramanganon 100 MW PP (Aggrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
31	Aushali 100MW PP (Aggrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
32	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	55	55	55		
33	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	55	55		
34	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0		
35	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	4	0	90	104		
36	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	14	108	126	126		
37	Manikganj 33MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	21	0	30	0		
Dhaka Zone Total				5976	5819	2217	2687	3760	4050	350	870
38	Karnaphuli Hydro PP Unit-1,2,3,4,5	Hydro (PDB)	2x40, 3x50	230	230	27	28	29	29	202	Low Water Level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	100	100	100		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	0	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	7	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	8	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	50	50		
44	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	76	105	85	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	115	100	110	115		
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	204	203	210	215		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	0	200	300		
48	Juldah 100 MW Unit-1 (Accorn)	HFO (QRPP)	8x13.45	100	100	100	100	100	100		
49	Juldah 100 MW PP Unit 3 (Accorn)	HFO (IPP)	8x13.45	100	100	0	0	100	100		
50	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	68	68		
51	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
52	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16		
*	Malancha Ctg EPZ (United)	Gas	5x8.73+3x9.34			4	24	5	15		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	85	97	95	97		
54	Sikalbaha 54 MW Power Plant(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	7	17	54	54		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	18	85	110	110		
56	Juldah unit 2 (Accorn)	HFO (IPP)	8x13.5	100	100	0	10	100	100		
57	Chattogram 116 MW PP (Antima Ener)	HFO (IPP)	6x21.06	116	116	111	112	112	112		
Chattogram Zone Total				2442	2382	878	1090	1594	1711	202	180
58	a) Ashuganj TPP Unit 3	Gas (APSCL)	1 x 150	150	135	80	80	80	80	55	Gas Shortage
	b) Ashuganj TPP Unit 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	20	26	26	26		
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+175	221	221	214	182	210	210		
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	275	300	330	350		
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	310	315	350	360		
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	54	57	55	55		
64	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	26	26	26	26	169	Gas shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	3	150	150	150		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	50		
68	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	24	34	170	200		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	22	22	22		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, PDB)	4x2.90	11	11	11	11	11	11		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	25	34	43		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, PDB)	3x3.67+2x6.97	25	25	18	20	21	21		
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	98x1.4+8x1.35+1x1.08	200	200	0	0	100	200		
76	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	114	100	114		
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	116	116	113	113		
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	36	36	18	18		
**	Impoirt (Tripura)	India		160	160	46	128	148	172		
Cumilla Zone Total				3094	3034	1372	1726	2048	2305	487	0
79	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	201	167	200	200		
80	Tangal 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21		
81	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	8	8	8	8		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	48	115	115	115		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	0	90	175	200		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
85	Sutakhali 50 MW Solar PP	Solar (IPP)	1x50	50	50	24	0	50	0		
86	Tangal 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	10	22	22		
Mymensing Zone Total				717	709	303	411	593	566	0	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.07.21 (Yesterday)		04.07.21 (Today)		03.07.21 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)				
87	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	Under maint.		
88	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	42	42		60	Under maint.		
89	Fenchuganj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	47	50	51	51					
90	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0					
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	11	11					
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	61	62	63					
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	110	110	110	110					
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	84	84	84					
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	218	218	225	225					
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18					
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	10	10					
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	14	15	16					
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	285	300	341					
100	Bibiyana-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	402	401	400	400					
101	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	401	400	400	400					
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0					
Sylhet Zone Total					2422	2377	1719	1735	1771	1814	0	87		
103	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
104	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278-1 x 132	410	410	400	400	350	380					
105	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	20	20					
106	Capalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	60	60					
107	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150-1x75	230	230	0	0	0	220					
108	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	100	50	100				
109	Rupsha 105 MW PP (Onon rupsha)	HFO (IPP)	6x18.445	105	105	25	90	90	90					
110	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	100	100					
**	Bheramara (HVDC)	India		1000	1000	710	804	816	816					
Khulna Zone Total					2133	2129	1135	1394	1486	1786	0	0		
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110					
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	19	29	25	33					
113	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	86	86	85	86		108	G1-Z & STG Under maint.		
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	10	11	11					
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	320	500	622	622					
116	Potakhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	110					
Bhola Nutan Biddut BD LTD							221	223	220	220				
Barishal Zone Total					1826	1826	657	848	1073	1192	0	108		
117	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	60	70	60	60					
117	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	60	80	80	80		20	Gas Shortage		
118	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	0	50					
119	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
120	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	43					
121	Amnura 50 MW PP(Siraha)	HFO (QRPP)	7x7.79	50	50	0	12	35	35					
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	95	0	95					
123	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	0	40					
124	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50					
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	42	0	40					
126	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		150	Gas Shortage, STG S/D		
127	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	174	181	200	200					
128	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	188	183	200	200					
129	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	394	415	400	400					
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	18	18	18					
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11					
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	52	52	52					
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	50	90	113	113					
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	0	35	113	113					
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0					
Rajshahi Zone Total					2179	2179	955	1361	1538	1800	170	0		
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage		
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage		
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	150	150	150	150		124	Coal Shortage		
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	34	113	113	113					
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
141	Majpara, Tabula 8 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 8	8	8	2	0	8	0					
Rangpur Zone Total					685	605	186	263	271	283	294	0		
Sub-total: Plants in operation					21474	21060	9422.0	11515	14134	15507	1503	1245		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							9001	11000	13501	14813				
(B) Plants under long term maintenance/ contract expired														
142	Ghorashal 78.5 MW PP(MAX)	Gas (QRPP)	2x40	78	0	0	0	0	0			Contract Expired on 08/01/2021		
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
144	Fenchuganj 44MW (Energyprima)	Gas (RPP)	12x3.3+5x2.0	44	0	0	0	0	0			Contract Expired on 14/02/2021		
145	Sylhet 50MW PP (EPL)	Gas (RPP)	27x2.0	50	0	0	0	0	0			Contract Expired on 04/01/2020		
146	Bogura 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
147	Meghnaghat 100 MW(IEEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
149	Noapara 40 MW PP (Khanjahan Ali)	HFO (QRPP)	5x8.5	40	0	0	0	0	0			Contract Expired on 28/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired					549	0	0	0	0	0				
Gross Total					22023	21060	9422	11515	14134	15507	1503	1245		
(C) Actual data of 03.07.21 (Yesterday) Saturday :														
01.	Max. Demand at eve. peak (Generation end)	:	11515.00	MW,	at =	21:00 hrs	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	11000.00	MW,	at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	11515.00	MW,	at =	21:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	7594.00	MW,	at =	6:00 hrs	Dhaka	3842	3842	0	Mymensingh	897	897	0
05.	Day-peak Generation (Generation end)	:	9422.00	MW,	at =	12:00 hrs	Chattogram	1150	1150	0	Sylhet	445	445	0
06.	Evening-peak Generation (Generation end)	:	11515.00	MW,	at =	21:00 hrs	Khulna	1377	1377	0	Barishal	322	322	0
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW,	at =	21:00 hrs	Rajshahi	1185	1185	0	Rangpur	743	743	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8335.00	MW,	at =	5:00 hrs	Cumilla	1039	1039	0				
09.	Generation shortfall at evening peak due to :	:									Total	11000	11000	0
a)	Gas limitation	:	1007	MW										
d)	Coal supply Limitation	:	294	MW										
b)	Low water level in Kaptai lake	:	202	MW										
c)	Plants under shut down/ maintenance	:	1245	MW										
10.	Total Energy (Generation + India Import)	:	226.52	MKWh										
	By Gas =	157.890	MKWh		By Oil =	35.063	MKWh							
	By Coal =	13.633	MKWh		By Hydro =	0.577	MKWh							
	By Solar =	0.513	MKWh											
11.	Total Gas Supplied	:	1253.34	MMCFD										
(D) Forecast of 04.07.21 (Today) Sunday :														
01.	Maximum Demand	:	12000	MW	(Generation end)		04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	15507	MW	(Generation end)		05.	Total Generation	:	236.06	MKWh			
03.	Maximum Shortage	:	-3507	MW	(Generation end)		06.	Probable Max. Temperature in Dhaka	:	33.3° C				

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzi Islam Shaker)
Deputy Secretary, Generation