				POWER GRID COI NATIONAL L	OAD DESPATCH	CENTER							QF-LDC-08
				DA	AILY REPORT					-			Page -1
Fill now the maxim	aonore4 *-		13792.0					20:00	Hrs or		ting Date :	17-Jul-21	
Till now the maximum The Summary of Yeste		: - 16-Jul-21	Generation & Demand					20:00				e Gen. & Deman	d
Day Peak Generation	:	10643.0	MW	Hour :		12:00			Min. Gen. at	8	3:00	97	'12 MW
Evening Peak Generation	1	12830.0		Hour :		21:00			Available Max G	eneration	:		27 MW
E.P. Demand (at gen end)):	12830.0		Hour :		21:00			Max Demand (E				800 MW
Maximum Generation	:	12864.0		Hour :		1:00			Reserve(Generation	ation end)		21	27 MW
Total Gen. (MKWH)	:	274.4		Syste	m Load Factor	: 88.87	6		Load Shed				0 MW
Export from East grid to W	loot arid · Max	ina 1 100	EXPORT / IMPORT TH	ROUGH EAST-WEST		0R 566 MW	at		22:00		Energy		MKWHR.
mport from West grid to E	ast grid := Max	imum			-	MW	at		22.00		Energy		- MKWHR.
ter Level of Kaptai Lake a	at 6:00 A M on		17-Jul-21										
Actual :	82.58	Ft.(MSL),			Rule cur	/e :	86.56		Ft.(MSL)				
Sas Consumed :			MMCED					(
Gas Consumed :	Total =	1203.90	MMCFD.			Oil Co	nsumed	(PDB) :		HSD			Liter
										FO :			Liter
										10			Liter
Cost of the Consumed Fue	el (PDB+Pvt) :	Gas :		Tk164,119,341									
		Coal :		Tk56,489,226			0	Oil :	Tk580,722,783		Total :	Tk801,331,350	
	<u>I</u>	.oad Shedding &	Other Information										
Area	Yesterda	v							Today				
	, caterua	,	Fs	timated Demand (S/S er	nd)				Estimated Shed	ding (S/S er	nd)	Rates of Shedo	ding
	MW		20	MW	,					MW	1	(On Estimated E	
Dhaka	0	0:00		4688							0	0%	
Chittagong Area	0	0:00		1599							0	0%	
Khulna Area	0	0:00		1434							0	0%	
Rajshahi Area	0	0:00		1296							0	0%	
Cumilla Area	0	0:00		1171							0	0%	
Nymensingh Area	0	0:00		945 521							0	0% 0%	
Sylhet Area Barisal Area	0	0:00		243							0	0%	
Rangpur Area	0	0:00		729							0	0%	
Fotal	0	0.00		12626							0	070	
							apukuria	ST: Unit	1-2				
						2) Gh	rasal-4,	ST: Unit	-2				
						2) Ghi 3) Ash	rasal-4, uganj-4	ST: Unit	-2				
						2) Gh 3) Ash 4) Kap	, irasal-4, uganj-4 tai-2	ST: Unit	-2				
						2) Gh 3) Ash 4) Kap 5) Rad	, uganj-4 tai-2 zan #2		-2				
						2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
						2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	, uganj-4 tai-2 zan #2	w	-2				
						2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
						2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w					
	dditional Inform	nation of Machine	es lines Interruntion / F	Formed Load short ste		2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
			es, lines, Interruption / F			2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
a) Aminbazar-Manikganj F	PP 132 kV Ckt-1	was under shut d	own from 09:13 to 23:46	for D/W.		2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
a) Aminbazar-Manikganj F o) Chandpur-Kochua 132	PP 132 kV Ckt-1 kV Ckt-2 was u	was under shut d nder shut down fro	own from 09:13 to 23:46 m 09:13 to 10:53 for D/W	for D/W.		2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
a) Aminbazar-Manikganj F o) Chandpur-Kochua 132 o) Ishurdi 230/132 kV T02	PP 132 kV Ckt-1 kV Ckt-2 was u transformer wa	was under shut d nder shut down fro s under shut down	own from 09:13 to 23:46 m 09:13 to 10:53 for D/W from 09:12 to 11:33 for 0	for D/W. /. C/M.		2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
a) Aminbazar-Manikganj F b) Chandpur-Kochua 132 c) Ishurdi 230/132 kV T02 d) Chandpur-Kochua 132	PP 132 kV Ckt-1 kV Ckt-2 was u transformer wa kV Ckt-1 was u	was under shut d nder shut down fro s under shut down nder shut down fro	own from 09:13 to 23:46 m 09:13 to 10:53 for D/W from 09:12 to 11:33 for 0 m 10:58 to 12:51 for D/W	for D/W. I. C/M. I.		2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
a) Aminbazar-Manikganj F) Chandpur-Kochua 132 i) Ishurdi 230/132 kV T02 1) Chandpur-Kochua 132 i) Ashuganj(N) CCPP trip	PP 132 kV Ckt-1 kV Ckt-2 was u transformer wa kV Ckt-1 was u ped at 12:07 du	was under shut do nder shut down fro s under shut down nder shut down fro e to problem of ga	own from 09:13 to 23:46 m 09:13 to 10:53 for D/W from 09:12 to 11:33 for 0 m 10:58 to 12:51 for D/W	for D/W. I. C/M. I.		2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
a) Aminbazar-Manikganj F a) Chandpur-Kochua 132 c) Ishurdi 230/132 kV T02 d) Chandpur-Kochua 132 a) Ashuganj(N) CCPP trip STG was synchronized a	PP 132 kV Ckt-1 kV Ckt-2 was u transformer wa kV Ckt-1 was u ped at 12:07 du t 02:54(17/7/20)	was under shut do nder shut down fro s under shut down nder shut down fro e to problem of ga 21).	own from 09:13 to 23:46 m 09:13 to 10:53 for D/W from 09:12 to 11:33 for 0 m 10:58 to 12:51 for D/W s valve and GT was sync	for D/W. I. C/M. I.		2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
a) Aminbazar-Manikganj F o) Chandpur-Kochua 132 o) Ishurdi 230/132 kV T02 d) Chandpur-Kochua 132 o) Ashuganj(N) CCPP tripj STG was synchronized a D Bhola 225 MW CCPP tri	PP 132 kV Ckt-1 kV Ckt-2 was un transformer wa kV Ckt-1 was un ped at 12:07 du t 02:54(17/7/20) ipped at 12:08 d	was under shut do nder shut down fro s under shut down nder shut down fro e to problem of ga 21). Jue to tripping of st	own from 09:13 to 23:46 m 09:13 to 10:53 for D/M from 09:12 to 11:33 for (m 10:58 to 12:51 for D/M is valve and GT was sync urge protection.	for D/W. /. C/M. /. hronized at 22:44 and		2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
a) Aminbazar-Manikganj F b) Chandpur-Kochua 132 b) Ishurdi 230/132 kV TO2 d) Chandpur-Kochua 132 e) Ashuganj(N) CCPP tripj STG was synchronized a b) Bhola 225 MW CCPP tri b) After maintenance Agar	PP 132 kV Ckt-1 kV Ckt-2 was un transformer wa kV Ckt-1 was uped at 12:07 du t 02:54(17/7/20: ipped at 12:08 of gaon-Cantonne	was under shut d nder shut down fro s under shut down nder shut down fro e to problem of ga 21). Jue to tripping of si ent 132 kV Ckt-1 v	own from 09:13 to 23:46 m 09:13 to 10:53 for D/M from 09:12 to 11:33 for (m 10:58 to 12:51 for D/M is valve and GT was sync urge protection.	for D/W. /. C/M. /. hronized at 22:44 and		2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
a) Aminbazar-Manikganj F b) Chandpur-Kochua 132 l b) Ishurdi 230/132 kV T02 d) Chandpur-Kochua 132 l b) Ashuganj(N) CCPP trip STG was synchronized a b) Bhola 225 MW CCPP tri g) After maintenance Agar h) Barapukuria unit-1 was Ghorashal uni-3 was syn	PP 132 kV Ckt-1 kV Ckt-2 was u transformer wa kV Ckt-1 was u ped at 12:07 du t 02:54(17/7/20: ipped at 12:08 or gaon-Cantonne synchronized at 19	was under shut d was under shut down fro s under shut down fro e to problem of ga 21). due to tripping of si ent 132 kV Ckt-1 v 17:08. 3:35.	own from 09:13 to 23:46 m 09:13 to 10:53 for D/M from 09:12 to 11:33 for f m 10:58 to 12:51 for D/M s valve and GT was sync urge protection. vas switched on at 16:53.	for D/W. /. C/M. /. hronized at 22:44 and		2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
a) Aminbazar-Manikgani F b) Chandpur-Kochua 132 (b) c) Ishurdi 230/132 kV T02 b) Chandpur-Kochua 132 (b) c) Ashugani (N) CCPP trig) STG was synchronized a b) Bhola 225 MW CCPP tri g) After maintenance Agar b) Barapukuria unit-1 was Ghorashal unit-3 was syi Barapukuria Unit-1 trigo	PP 132 kV Ckt-1 kV Ckt-2 was ui transformer wa kV Ckt-1 was ui ped at 12:07 du t 02:54(17/7/20) ipped at 12:08 o rgaon-Cantonme synchronized at nchronized at 15 du at 18:55 due	was under shut d nder shut down fro s under shut down fro s under shut down fro e to problem of ga 21). Jue to tripping of si ent 132 kV Ckt-1 v 17:08. 9:35. to tripping of air ht	own from 09:13 to 23:46 m 09:13 to 10:53 for D/M from 09:12 to 11:33 for (m 10:58 to 12:51 for D/M is valve and GT was sync urge protection. vas switched on at 16:53.	for D/W. /. C/M. /. hronized at 22:44 and ed at 00:17(17/7/2021)		2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
a) Aminbazar-Manikganj F () Chandpur-Kochua 132 () Ishurdi 230/132 kV T02 () Chandpur-Kochua 132 () Chandpur-Kochua 132 () Ashuganj(N) CCPP trip STG was synchronized a Bhola 225 MV CCPP tri () After maintenance Agar Boha 252 MV CCPP tri () Barapukura uni-1 was () Ghorashal uni-1 was sy Barapukura uni-1 was () Aminbazar 230/132 kV	PP 132 kV Ckt-1 kV Ckt-2 was ui transformer wa kV Ckt-1 was ui ped at 12:07 du t 02:54(17/7/20) ipped at 12:08 o rgaon-Cantonme synchronized at nchronized at 15 du at 18:55 due	was under shut d nder shut down fro s under shut down fro s under shut down fro e to problem of ga 21). Jue to tripping of si ent 132 kV Ckt-1 v 17:08. 9:35. to tripping of air ht	own from 09:13 to 23:46 m 09:13 to 10:53 for D/M from 09:12 to 11:33 for (m 10:58 to 12:51 for D/M is valve and GT was sync urge protection. vas switched on at 16:53.	for D/W. /. C/M. /. hronized at 22:44 and ed at 00:17(17/7/2021)		2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
a) Aminbazar-Manikgani F b) Chandpur-Kochua 132 b) shardi 230/132 kV T02 b) Chandpur-Kochua 132 b) Ashuganj(N) CCPP trip b) Ashuganj(N) CCPP trip b) Ashuganj(N) CCPP trip b) Afler maintenance Agar b) Afler maintenance Agar b) Afler maintenance Agar b) Afler maintenance Agar b) Barapukruia unit-1 was g(Anorashal unit-3 was sy c) Aminbazar 230/132 kV on at 16:22:	PP 132 kV Ckt-1 kV Ckt-2 was u transformer wa kV Ckt-1 was u ped at 12:07 du t 02:54(17/7/20) ipped at 12:08 o gaon-Cantonm synchronized at nchronized at 15 du at 18:55 due T03 transforme	was under shut d dier shut down fro s under shut down fro e to problem of ga 21). Jue to tripping of su nt 132 kV Ckt-1 v 17:08. 2:35. to tripping of air h r tripped at 15:13 s	own from 09:13 to 23:46 m 09:13 to 10:53 for D/M from 09:12 to 11:33 for 0 m 10:58 to 12:51 for D/M is valve and GT was sync urge protection. was switched on at 16:53. eater and was synchroniz showing Gen. trip,oil purify	for DW. / 2M. hronized at 22:44 and ed at 00:17(17/7/2021) y alarm and was switched		2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
a) Aminbazar-Manikgani, F o) Chandpur-Kochua 132 i) shurdi 230 traz kV 102 i) Chandpur-Kochua 132 i) Adhugani(N) CCPP trip STG was synchronized a Bhola 225 MW CCPP trip J After maintenance Agar i) Barapukuria uni-1 was Barapukuria Uni-1 tripp Ghorashal uni-1 swas sys Barapukuria Uni-1 tripp J Aminbazar 230 J132 kV on at 16:22.	PP 132 kV Ckt-1 kV Ckt-2 was u transformer wa kV Ckt-1 was u ped at 12:07 du t 02:54(17/7/20) ipped at 12:08 o gaon-Cantonm synchronized at nchronized at 15 du at 18:55 due T03 transforme	was under shut d dier shut down fro s under shut down fro e to problem of ga 21). Jue to tripping of su nt 132 kV Ckt-1 v 17:08. 2:35. to tripping of air h r tripped at 15:13 s	own from 09:13 to 23:46 m 09:13 to 10:53 for D/M from 09:12 to 11:33 for 0 m 10:58 to 12:51 for D/M is valve and GT was sync urge protection. was switched on at 16:53. eater and was synchroniz showing Gen. trip,oil purify	for DW. / 2M. hronized at 22:44 and ed at 00:17(17/7/2021) y alarm and was switched	1	2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
a) Aminbazar-Manikgani, F b) Chandpur-Kochua 132 b) shardi 230/132 kV T02 b) Shardi 230/132 kV T02 b) Chandpur-Kochua 132 b) Chandpur-Kochua 132 b) STG was synchronized a B) Bhola 225 MV CCPP tri b) After maintenance Agar b) After maintenance Agar b) After maintenance Agar b) Barapukuria unit-1 trippe c) Aminbazar 230/132 kV purbasadipur 132/33 kV switched on at 20:25.	PP 132 kV Ckt-1 kV Ckt-2 was u transformer wa kV Ckt-1 was u ped at 12:07 du t 02:54(17/7/20) ipped at 12:08 d rgaon-Cantonm synchronized at nchronized at 15 ed at 18:55 due T03 transforme 'T-3 transforme	was under shut down fro sunder shut down fro der shut down fro e to problem of ga 21). Uue to tripping of si ant 132 kV Ckt-1 v 17:08. 3:55. To tripping of air h r tripped at 15:13 s r tripped at 20:01 (own from 09:13 to 23:46 m 09:13 to 10:53 for DM from 09:12 to 11:33 for (0 m 09:12 to 11:33 for (0 m 10:58 to 12:51 for DW s valve and GT was sync urge protection. vas switched on at 16:53. eater and was synchroniz showing Gen. trip.ol purify due to shetabganj NESC	for DW. / CM. / hronized at 22:44 and ed at 00:17(17/7/2021) y alarm and was switched O feeder fault and was	1	2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
a) Aminbazar-Manikgani, F) Chandpur-Kochua 132,) Ishurd; 230142 kV 102,) Johandpur-Kochua 132, Johandpur-Kochua 132,) Johanguan(1V) CCPP trip STG was synchronized a Bhola 225 MW CCPD trip) After maintenance Agar) Barapukuria uni-1 was sy Barapukuria Uni-1 tripp (Ghorashal uni-3 was sy Barapukuria Uni-1 tripp) / Johandbazar 200132 kV on at 16:22. Purbasadigur 132/33 kV switched on at 20:25.	PP 132 kV Ckt-1 kV Ckt-2 was u transformer wa kV Ckt-1 was u kV Ckt-1 was u ped at 12:07 du t 02:54(17/7/20: ipped at 12:08 du gaon-Cantonm synchronized at 1 ed at 18:55 due T03 transforme 'T-3 transforme :V Ckt tripped al	was under shut down fro s under shut down fro dider shut down fro e to problem of ga 21). fue to tripping of st mt 132 kV Ckt-1 v 17:08. 3:35. i to tripping of air h r tripped at 15:13 s r tripped at 20:01 (05:20(17/7/2021)	own from 09:13 to 23:46 m 09:13 to 10:53 for D/M from 09:12 to 11:33 for 1/M from 09:12 to 11:33 for 1/M s 10:58 to 12:51 for D/M s valve and GT was sync urge protection. was switched on at 16:53. bater and was synchroniz eater and was synchroniz due to shetabganj NESC from AKSM end and was	for DW. / CM. / hronized at 22:44 and ed at 00:17(17/7/2021) y alarm and was switched O feeder fault and was	4	2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
a) Aminbazar-Manikgarij F b) Chandpur-Kochua 132 b) Chandpur-Kochua 132 b) Chandpur-Kochua 132 b) Ashugarij(N) CCPP trip STG was synchronized a Bhola 225 MV CCPP tri b) After maintenace Agar b) Barapukuria uni-1 was b) Barapukuria uni-1 was b) Barapukuria Uni-1 trip c) Aneinbazar 230/132 kV on at 16:22. Purbasadipur 132/33 kV on at 16:22. Purbasadipur 132/33 kV on at 16:22.	PP 132 kV Ckt-1 kV Ckt-2 was u transformer wa kV Ckt-1 was u ped at 12:07 du t 02:54(1777/20 t 02:54(1777/20 t 02:54(1777/20 t 02:54(1777/20 t 02:54(1777/20 synchronized at nchronized at 19 ed at 18:55 due 7 T-3 transforme t 7-3 transforme t V Ckt tripped al	was under shut down fro s under shut down fro der shut down fro e to problem of ga 21). Uue to tripping of sis net 132 kV Ckt-1 v 17.08. 355. To tripping of air h r tripped at 15:13 s or tripped at 20:01 d 0.05:20(17/7/2021) shut down at 07:17	win from 09:13 to 23:46 m 09:13 to 10:53 for D/M, from 09:12 to 11:33 for (0 m 09:12 to 11:33 for (0 m 10:58 to 12:51 for D/M s valve and GT was sync urge protection. vas switched on at 16:53. eater and was synchroniz showing Gen. trip,oil purify due to shetabganj NESC(from AKSM end and was	for DW. / CM. / hronized at 22:44 and ed at 00:17(17/7/2021) y alarm and was switched O feeder fault and was		2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
a) Aminbazar-Manikgarij F b) Chandpur-Kochua 132 b) Chandpur-Kochua 132 b) Chandpur-Kochua 132 b) Ashugarij(N) CCPP trip STG was synchronized a Bhola 225 MV CCPP tri b) After maintenace Agar b) Barapukuria uni-1 was b) Barapukuria uni-1 was b) Barapukuria Uni-1 trip c) Aneinbazar 230/132 kV on at 16:22. Purbasadipur 132/33 kV on at 16:22. Purbasadipur 132/33 kV on at 16:22.	PP 132 kV Ckt-1 kV Ckt-2 was u transformer wa kV Ckt-1 was u ped at 12:07 du t 02:54(1777/20 t 02:54(1777/20 t 02:54(1777/20 t 02:54(1777/20 t 02:54(1777/20 synchronized at nchronized at 19 ed at 18:55 due 7 T-3 transforme t 7-3 transforme t V Ckt tripped al	was under shut down fro s under shut down fro der shut down fro e to problem of ga 21). Uue to tripping of sis net 132 kV Ckt-1 v 17.08. 355. To tripping of air h r tripped at 15:13 s or tripped at 20:01 d 0.05:20(17/7/2021) shut down at 07:17	win from 09:13 to 23:46 m 09:13 to 10:53 for D/M, from 09:12 to 11:33 for (0 m 09:12 to 11:33 for (0 m 10:58 to 12:51 for D/M s valve and GT was sync urge protection. vas switched on at 16:53. eater and was synchroniz showing Gen. trip,oil purify due to shetabganj NESC(from AKSM end and was	for DW. / CM. / hronized at 22:44 and ed at 00:17(17/7/2021) y alarm and was switched O feeder fault and was		2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
a) Aminbazar-Manikgarij F b) Chandpur-Kochua 132 b) Chandpur-Kochua 132 b) Chandpur-Kochua 132 b) Ashugarij(N) CCPP trip STG was synchronized a Bhola 225 MV CCPP tri b) After maintenace Agar b) Barapukuria uni-1 was b) Barapukuria uni-1 was b) Barapukuria Uni-1 trip c) Aneinbazar 230/132 kV on at 16:22. Purbasadipur 132/33 kV on at 16:22. Purbasadipur 132/33 kV on at 16:22.	PP 132 kV Ckt-1 kV Ckt-2 was u transformer wa kV Ckt-1 was u ped at 12:07 du t 02:54(1777/20 t 02:54(1777/20 t 02:54(1777/20 t 02:54(1777/20 t 02:54(1777/20 synchronized at nchronized at 19 ed at 18:55 due 7 T-3 transforme t 7-3 transforme t V Ckt tripped al	was under shut down fro s under shut down fro der shut down fro e to problem of ga 21). Uue to tripping of sis net 132 kV Ckt-1 v 17.08. 355. To tripping of air h r tripped at 15:13 s or tripped at 20:01 d 0.05:20(17/7/2021) shut down at 07:17	win from 09:13 to 23:46 m 09:13 to 10:53 for D/M, from 09:12 to 11:33 for (0 m 09:12 to 11:33 for (0 m 10:58 to 12:51 for D/M s valve and GT was sync urge protection. vas switched on at 16:53. eater and was synchroniz showing Gen. trip,oil purify due to shetabganj NESC(from AKSM end and was	for DW. / CM. / hronized at 22:44 and ed at 00:17(17/7/2021) y alarm and was switched O feeder fault and was	1	2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
a) Aminbazar-Manikgani F b) Chandpur-Kochua 132 b) Shardi 230/132 kV T02 b) Shardi 230/132 kV T02 b) Shuganj(k) CCPP trip b) Shuganj(k) CCPP trip b) ShG was synchronized a b) Bhola 225 MV CCPP tri b) After maintenace Agar b) Barapukuria uni-1 was b) Barapukuria uni-1 was b) Barapukuria Uni-1 trip c) Aneinbazar 230/132 kV on at 16:22. Purbasadipur 132/33 kV on at 16:22. Purbasadipur 132/33 kV on at 16:22.	PP 132 kV Ckt-1 kV Ckt-2 was u transformer wa kV Ckt-1 was u ped at 12:07 du t 02:54(1777/20 t 02:54(1777/20 t 02:54(1777/20 t 02:54(1777/20 t 02:54(1777/20 synchronized at nchronized at 19 ed at 18:55 due 7 T-3 transforme t 7-3 transforme t V Ckt tripped al	was under shut down fro s under shut down fro der shut down fro e to problem of ga 21). Uue to tripping of sis net 132 kV Ckt-1 v 17.08. 355. To tripping of air h r tripped at 15:13 s or tripped at 20:01 d 0.05:20(17/7/2021) shut down at 07:17	win from 09:13 to 23:46 m 09:13 to 10:53 for D/M, from 09:12 to 11:33 for (0 m 09:12 to 11:33 for (0 m 10:58 to 12:51 for D/M s valve and GT was sync urge protection. vas switched on at 16:53. eater and was synchroniz showing Gen. trip,oil purify due to shetabganj NESC(from AKSM end and was	for DW. / CM. / hronized at 22:44 and ed at 00:17(17/7/2021) y alarm and was switched O feeder fault and was	1	2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
a) Aminbazar-Manikgani F o) Chandpur-Kochua 132 o) Ishardi 230/132 kV T02 o) Ishardi 230/132 kV T02 o) Sahugani(N) CCPP trip o) Sahugani(N) CCPP trip o) Sahugani(N) CCPP trip o) Barapakunia Unit-1 was o) Barapakunia Unit-1 was o) Barapakunia Unit-1 tripp- o) Aminbazar 230/132 kV on at 16:22 Purbasadipur 132/33 kV switched on at 20:25. m) AKSM-Hathazar 230, Sahu o) Faridpur-Gonglangi 132 o) Aminbazar-Kaliyanpur 1	PP 132 kV Ckt-1 kV Ckt-2 was u transformer wa kV Ckt-1 was u ped at 12:07 du t 02:54(1777/20 t 02:54(1777/20 t 02:54(1777/20 t 02:54(1777/20 t 02:54(1777/20 synchronized at nchronized at 19 ed at 18:55 due 7 T-3 transforme t 7-3 transforme t V Ckt tripped al	was under shut down fro s under shut down fro der shut down fro e to problem of ga 21). Uue to tripping of sis net 132 kV Ckt-1 v 17.08. 355. To tripping of air h r tripped at 15:13 s or tripped at 20:01 d 0.05:20(17/7/2021) shut down at 07:17	own from 09:13 to 23:46 m 09:13 to 10:53 for DM from 09:12 to 11:33 for CM m 09:12 to 11:33 for CM m 10:58 to 12:51 for D/W s valve and GT was sync urge protection. vas switched on at 16:53. eater and was synchroniz showing Gen. trip.oil putifi due to shetabganj NESC (1777/2021) for C/M. 42(1777/2021) for C/M.	for DW. / CM. / hronized at 22:44 and ed at 00:17(17/7/2021) y alarm and was switcher O feeder fault and was	4	2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2				
a) Aminbazar-Manikgani F b) Chandpur-Kochua 132 b) Shardi 230/132 kV T02 b) Shardi 230/132 kV T02 b) Shuganj(k) CCPP trip b) Shuganj(k) CCPP trip b) ShG was synchronized a b) Bhola 225 MV CCPP tri b) After maintenace Agar b) Barapukuria uni-1 was b) Barapukuria uni-1 was b) Barapukuria Uni-1 trip c) Aneinbazar 230/132 kV on at 16:22. Purbasadipur 132/33 kV on at 16:22. Purbasadipur 132/33 kV on at 16:22.	PP 132 kV Ckt-1 was un transformer was well kV Ckt-2 was un kV Ckt-1 was un kV Ckt-1 was un kV Ckt-1 12:07 du kV Cst-1(1772) gaon-Cantomu synchronized at 12:08 c gaon-Cantomu synchronized at 18:55 due TO3 transforme 12:45 due transforme 12:45 due transforme 12:	was under shut down fro s under shut down fro der shut down fro e to problem of ga 21). Uue to tripping of sis net 132 kV Ckt-1 v 17.08. 355. To tripping of air h r tripped at 15:13 s or tripped at 20:01 d 0.05:20(17/7/2021) shut down at 07:17	win from 09:13 to 23:46 m 09:13 to 10:53 for D/M, from 09:12 to 11:33 for (0 m 09:12 to 11:33 for (0 m 10:58 to 12:51 for D/M s valve and GT was sync urge protection. vas switched on at 16:53. eater and was synchroniz showing Gen. trip,oil purify due to shetabganj NESC(from AKSM end and was	for DW. / SM. / hronized at 22:44 and ed at 00:17(17/7/2021) y alarm and was switched O feeder fault and was s switched on at 07:23.		2) Ghi 3) Ash 4) Kap 5) Rao 6) Bho	rasal-4, uganj-4 tai-2 zan #2 la 225 M	w	-2			Jent Engineer atch Circle	