			DAILY REPO						ting Date :	27-Aug-
Till now the maximu The Summary of Ye	im generation is	26-Aug-21 Generation & I	Demand			20:00	Hrs on Today's Actual	27-Apr-	-21 & Probabl	e Gen & Der
Day Peak Generation	:	11031.0 MW	Hour :		12:00		Min. Gen. at		3:00	e Gen. a Dei
Evening Peak Generation		12416.0 MW	Hour :		20:00		Available Max Ge		:	
E.P. Demand (at gen er Maximum Generation		12416.0 MW 12416.0 MW	Hour : Hour :		20:00 20:00		Max Demand (Ev Reserve(General			1
Total Gen. (MKWH)	÷	266.4	System Loa		89.41%		Load Shed	:		
Export from East grid to	oWestarid:⊾Ma		T/IMPORT THROUGH EAST-WEST INTERCON		MW	at	2:00		Energy	
mport from West grid to	to East grid :- Ma	ximum -	-		MW	at	-		Energy	
Level of Kaptai Lake a Actual :		27-Aug-21 t.(MSL),		Rule curve :	97.	35	Ft.(MSL)			
				Traic curve .						
Gas Consumed :	Total =	1103.10 MMCFD.			Oil Con:	sumed	(PDB) :	HSD :		
								FO :		
Cost of the Consumed I	Fuel (PDR+P)	Gas :	Tk141,045,408							
Soat of the Consumed I		Coal :	Tk73,493,156		0	1 :	Tk620,239,182		Total :	Tk834,777,7
	La	ad Shedding & Other Informa	ation							
Area	Yesterday		Estimated Demand (S/S end)				Today Estimated Shedd	ding (S/S e	nd)	Rates of Sh
	MW		MW					MW		(On Estimate
Dhaka Chittagong Area	0	0:00 0:00	4283 1459						0 0	0% 0%
Khulna Area	0	0:00	1307						0	0%
Rajshahi Area	0	0:00	1182						0	0%
Cumilla Area	0	0:00	1068						0	0%
Nymensingh Area Sylhet Area	0	0:00 0:00	862 479						0 0	0% 0%
Barisal Area	0	0:00	222						0	0%
Rangpur Area	0	0:00	665						ō	0%
Total	0		11525						0	
	Information of t	he Generating Units under shut	t down.							
Pla	anned Shut- Down				Forced	Shut	Down			
		•					a ST: Unit-1,2			
					2) Ghor					
					3) Ashu					
							71 MW & 100 MW			
					6) Siraj		/W GT-2			
					7) Raoz	an #2				
					8) Sylhe	t 225	MW			
					9) Shah	linozo	8&9			
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 at Kaliakoir end & Dis c) Meghnaghat 450 MW) kV Ckt-2 was un 0 MW P.P. 230 k ¹ st. E/F at P.P. end V GT-1 tripped at	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from bott I and was switched on at 11:28. 09:57 due to Gas Valve probler	th ends showing Pole discrepancy			jii iazai				
a) Bhulta-Rampura 230 c) Kaliakoir-Summit 300 at Kaliakoir end & Dis c) Meghnaghat 450 MW d) Raozan unit-2 was sy e) Khulna(C)-Khulna 22 f) Tangail-Mymensingh end & Dist. Z1, B-ph	0 kV Ckt-2 was un 0 MW P.P. 230 k ¹ st. E/F at P.P. end V GT-1 tripped at ynchronized at 12 25 MW Ckt was ur RPCL P.P. 132 k ase at P.P. end at	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from bott I and was switched on at 11:28. 09:57 due to Gas Valve probler	6:22 for C/M. th ends showing Pole discrepancy , m and was synchronized at 11:27. 12:05 for C/M. th ends showing E/F at Tangail			Jinazai				
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 c) Kaliakoir end & Dis c) Meghnaghat 450 MW d) Raozan unit-2 was sy b) Khulna(C)-Khulna 22 c) Tangail-Mymensingh 1 end & Dist. Z1, B-phe switched on at 18:16. g) Raozan unit-1 was st) kV Ckt-2 was un 0 MW P.P. 230 k ³ st. E/F at P.P. end V GT-1 tripped at 125 MW Ckt was ur RPCL P.P. 132 k ase at P.P. end at 5.	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from boll and was switched on at 11:28. 09:57 due to Gas Valve probler :30. nder shut down from 09:54 to 1. V Ckt tripped at 13:08 from boln nd was switched on at 13:29 an	6:22 for C/M. th ends showing Pole discrepancy , m and was synchronized at 11:27. 12:05 for C/M. th ends showing E/F at Tangail							
a) Bhulta-Rampura 230 b) Kaliakoir-Summi 30(at Kaliakoir end & Dis c) Meghnaghat 450 MW J) Raozan unit-2 was sy b) Khulna(C)-Khulna 22 Tangail-Mymensingh I end & Dist. Z1, B-pha switched on at 18:16 g) Raozan unit-1 was b) Sylhet 225 MW CT w	0 kV Ckt-2 was un 0 MW P.P. 230 k ¹ st. E/F at P.P. end V GT-1 tripped at ynchronized at 12 25 MW Ckt was ur RPCL P.P. 132 k ase at P.P. end at 5. hutdown at 18:51.	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from bolt and was switched on at 11:28. 09:57 due to Gas Valve proble :30. nder shut down from 09:54 to 1. V Ckt tripped at 13:08 from bolt nd was switched on at 13:29 an at 22:43.	6-22 for C/M. th ends showing Pole discrepancy k. m and was synchronized at 11:27. 12:05 for C/M. th ends showing E/F at Tangail nd again tripped at 17:59 and							
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 at Kaliakoir end & Kaliakoir end & Kaliakoir b) Meghnaghat 450 MW t) Raozan unit-2 was sy b) Khulna (2)-Khulna 22 t) Tangai-Mymensingh i b) Khula (2)-Khulna 22 g) Raozan unit-1 was at g) Raozan unit-1 was at t) Sylnet 225 MW GT w Hasnabad-Kamrangir Heanabad-Kamrangir	0 kV Ckt-2 was un 0 MW P.P. 230 ki st. E/F at P.P. end V GT-1 tripped at 2 STMV Ckt was un RPCL P.P. 132 k ase at P.P. end at i. hutdown at 18:51. was synchronized rochar 132 kV Ckt rangirchar 132 kV	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from bolt and was switched on at 11:28, 09:57 due to Gas Valve problen :30. nder shut down from 09:54 to 1: V Ckt tripped at 13:08 from bot nd was switched on at 13:29 an at 22:43. was shutdown at 05:54(27/08/2 V Ckt was shutdown at 06:362).	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail nd again tripped at 17:59 and 2021) for D/W. 2708/2021) for D/W.							
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 at Kaliakoir end & Dis b) Meghnaghat 450 MW d) Raozan unit-2 was sy b) Khulna(C)-Khulna 22 f) Tangail-Mymensingh I end & Dist. 21, B-pha switched on at 18:16. g) Raozan unit-1 was si h) Sylhet 225 MW GT w, Hasnabad-Kamrangiri) Keranigan] New-Lab) kV Ckt-2 was un 0 MW P.P. 230 k ³ tt E/F at P.P. end V GT-1 tripped at 25 MW Ckt was ur RPCL P.P. 132 k hutdown at 18:51. was synchronized rchar 132 kV Ckt irrangirchar 132 kV Ckt	der shut down from 10.44 to 16 V Ckt tripped at 10.33 from bolt 1 and was switched on at 11.32, 09:57 due to Gas Valve problet :300: and rshut down from 09:54 to 1 V Ckt tripped at 13.08 from bot nd was switched on at 13.29 an at 22:43. was shutdown at 05:54(27/08/2 / Ckt was shutdown at 06:38(21,283 were shutdown at 06:38(21,283 were shutdown at 06:38)	6:22 for C/M. th ends showing Pole discrepancy I. Im and was synchronized at 11:27. 12:05 for C/M. 12:05 for C/M. 12:05 for C/M. 12:05 for D/W. 12:021) for D/W. 12:08/0221) for D/W.							
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 at Kaliakoir-Summit 300 b) Meghnaghat 450 MW 1) Raozan unit-2 was sy 0) Khulna (2)-Khulna 22 0) Khulna (2)-Khulna 22 0) Khulna (2)-Khulna 22 0) Sknapa (2)-Khulna 24 med & Dist 21, B-phe switched on at 18:16 0) Raozan unit-1 was si 0) Sylhet 225 MW GT w 1 Hasnabad-Kamrangir 0, Keranigan J New-Lab 0, Keranigan J New-Lab 0, Keranigan J New-Lab 0, Keranigan J Mew-Kam) kV Ckt-2 was un 0 MW P.P. 230 ki st. E/F at P.P. end V GT-1 tripped at ynchronized at 12 55 MW Ckt was un RPCL P.P. 132 k ase at P.P. end at i. hutdown at 18:51. was synchronized rohar 132 kV Ckt- vrangirchar 132 kV Ckt- vrangirchar 132 kV Ckt- shutdown at 06:2	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from bolt and was switched on at 11:28, 09:57 due to Gas Valve problen :30. nder shut down from 09:54 to 1: V Ckt tripped at 13:08 from bot nd was switched on at 13:29 an at 22:43. was shutdown at 05:54(27/08/2 V Ckt was shutdown at 06:362).	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail nd again tripped at 17:59 and 2021) for D/W. 2709/2021) for D/W. 12709/2021) for D/W. lem.							
a) Bhulta-Rampura 230 b) Kaliakoir-Summi 300 at Kaliakoir end & Dis c) Meghnaghat 450 MW J) Raczan unit-2 was sy b) Khuhat(C)-Khulna 22 b) Khuhat(C)-Khulna 22 b) Roizhat 1-1 was si b) Roizhat 1-1 was si b) Roizhat 1-1 was si b) Roizhat 1-1 was si b) Racia nui-1) kV Ckt-2 was un 0 MW P.P. 230 k ³ tt E/F at P.P. end V GT-1 tripped at ynchronized at 12 25 MW Ckt was ur EPCL P.P. 132 k ase at P.P. end at b. huldown at 18:51 was synchronized rchar 132 kV Ckt- shutdown at 03:3 shutdown at 03:3	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from bolt 1 and was switched on at 11:23. 09:57 due to Gas Valve problet 30. ndar shut down from 00:54 to 1 V Ckt tripped at 13:08 from bot nd was switched on at 13:29 ar at 22:43. was shutdown at 05:54(27/08/2 V Ckt was shutdown at 06:38(21, 28.38 were shutdown at 06:38(21, 28.38 were shutdown at 05:54(27/08/2 (62(7/08/2021) due to 51 proble 57(27/08/2021) due to 51 proble	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail nd again tripped at 17:59 and 2021) for D/W. 2709/2021) for D/W. 12709/2021) for D/W. lem.				About 40 MW po			seen running (
a) Bhulta-Rampura 230 o) Kaliakoir-Summi 300 at Kaliakoir end & Dis o) Maginaghat 450 MW J Raczan unit-2 was sy and K Dist. 21, B-phr switched on at 18:16, J Raczan unit-1 was si) Sylhet 225 MW GT w Hasnabad-Kamrangin) Keranigan New-Lalb) Haripur 360 MW was o) Keranigan New-Lalb) Haripur 360 MW was n) Ashugan Yooth was o) Chowmuhuni 132/33	V C Ckt-2 was un 0 MW P.P. 230 k ³ st. E/F at P.P. end V GT-1 tripped at ynchronized at 12 5 MW Ckt was un RPCL P.P. 132 k 5 MW Ckt was un RPCL P.P. 132 k hutdown at 16:51 was synchronized rchar 132 kV Ckt- shutdown at 06:3 k V T1 transformet 0 kV T1 transformet	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from bolt 1 and was switched on at 11:23. 09:57 due to Gas Valve problet 30. nder shut down from 00:54 to 1 V Ckt tripped at 13:08 from bot nd was switched on at 13:29 ar at 22:43. was shutdown at 05:54(27/08/2 V Ckt was shutdown at 06:38(21 Z & were shutdown at 06:34(27/08/2 V Ckt was shutdown at 05:54(27/08/2 V Ckt was shutdown at 05:54(27/08/2) V Ckt was shutdown at 05:54(27/08/2) V Ckt was shutdown	6-22 for C/M. th ends showing Pole discrepancy k. It and was synchronized at 11:27. 12:05 for C/M. It and sain tripped at 17:59 and 2021) for D/W. 2021) for D/W. 2022) for D/W. 2022) for D/W. 2022) for D/W. 2022) for D/W. 2023) for D/W. 2024) for D/W. 2024) for D/W. 2024) for D/W. 2025) for D/W. 2026) for D/W. 2026) for D/W. 2027) for D/W. 2021)							been running (
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 30(at Kaliakoir end & Summit 30) b) Meghnaghat 450 MW 1) Raozan unit-2 was sy 0) Khulna (2)-Khulna 22 0) Fangail-Mymensingh 1) 9) Khul 22 (3)-Khulna 22 1) Tangail-Mymensingh 1) 9) Raozan unit-1 was at 1) Siphet 225 KMW GT w 1) Harsnabad-Kamrangin 1) Keranigan J New-Kam (3) Keranigan J New-Kam (3) Kabingan J North was 1) Chowmuhuri 132/33 5) Kabirpur-Manikgan j 1) Manikgan j 132/33 kV	V Ckt-2 was un 0 MW P.P. 230 k ³ st. E/F at P.P. end V GF-1 tripped at ynchronized at 12 5 MW Ckt was un RPCL P.P. 132 k 5 MW Ckt was un as a at P.P. end at 3. hutdown at 18:51, was synchronized rchar 132 kV Ckt-1 was synchronized s shutdown at 03:5 k kV T1 transformer 132 kV Ckt-1 was	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from bolt and was switched on at 11:28, 09:57 due to Gas Valve problem :30. dider shut down from 09:54 to 1: V Ckt tripped at 13:08 from bol nd was switched on at 13:29 an	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail nd again tripped at 17:59 and 2021) for D/W. 20201) for D/W. (27/08/2021) for D/W. lem. 13(27/08/2021) due to R/H maintenance. 1) for D/W. 27/08/2021) for D/W.				About 40 MW po			been running i
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 30(at Kaliakoir end & Summit 30) b) Meghnaghat 450 MW 1) Raozan unit-2 was sy 0) Khulna (2)-Khulna 22 0) Fangail-Mymensingh 1) 9) Khul 22 (3)-Khulna 22 1) Tangail-Mymensingh 1) 9) Raozan unit-1 was at 1) Siphet 225 KMW GT w 1) Harsnabad-Kamrangin 1) Keranigan J New-Kam (3) Keranigan J New-Kam (3) Kabingan J North was 1) Chowmuhuri 132/33 5) Kabirpur-Manikgan j 1) Manikgan j 132/33 kV	V Ckt-2 was un 0 MW P.P. 230 k ³ st. E/F at P.P. end V GF-1 tripped at ynchronized at 12 5 MW Ckt was un RPCL P.P. 132 k 5 MW Ckt was un as ea tP.P. end at 3. hutdown at 18:51, was synchronized rchar 132 kV Ckt-1 was synchronized s shutdown at 03:5 k kV T1 transformer 132 kV Ckt-1 was	der shut down from 10.44 to 16 V Ckt tripped at 10:33 from boll and was switched on at 11:28, 0957 due to Gas Valve problem :30. nder shut down from 09:54 to 1. V Ckt tripped at 13:08 from bol nd was switched on at 13:29 an at 22:43. was shutdown at 05:54(27/08/2 V Ckt was shutdown at 05:54(27/08/2 (21/28/2021) due to ST proble 57(27/08/2021) due to ST proble 57(27/08/2021) for maintenance r is under shutdown site 07:4	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail nd again tripped at 17:59 and 2021) for D/W. 20201) for D/W. (27/08/2021) for D/W. lem. 13(27/08/2021) due to R/H maintenance. 1) for D/W. 27/08/2021) for D/W.				About 40 MW po			seen running i
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 30(at Kaliakoir end & Summit 30) b) Meghnaghat 450 MW 1) Raozan unit-2 was sy 0) Khulna (2)-Khulna 22 0) Fangail-Mymensingh 1) 9) Khul 22 (3)-Khulna 22 1) Tangail-Mymensingh 1) 9) Raozan unit-1 was at 1) Siphet 225 KMW GT w 1) Harsnabad-Kamrangin 1) Keranigan J New-Kam (3) Keranigan J New-Kam (3) Kabingan J North was 1) Chowmuhuri 132/33 5) Kabirpur-Manikgan j 1) Manikgan j 132/33 kV	V Ckt-2 was un 0 MW P.P. 230 k ³ st. E/F at P.P. end V GF-1 tripped at ynchronized at 12 5 MW Ckt was un RPCL P.P. 132 k 5 MW Ckt was un as ea tP.P. end at 3. hutdown at 18:51, was synchronized rchar 132 kV Ckt-1 was synchronized s shutdown at 03:5 k kV T1 transformer 132 kV Ckt-1 was	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from bolt and was switched on at 11:28, 09:57 due to Gas Valve problem :30. dider shut down from 09:54 to 1: V Ckt tripped at 13:08 from bol nd was switched on at 13:29 an	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail nd again tripped at 17:59 and 2021) for D/W. 20201) for D/W. (27/08/2021) for D/W. lem. 13(27/08/2021) due to R/H maintenance. 1) for D/W. 27/08/2021) for D/W.				About 40 MW po			been running i
a) Bhulta-Rampura 230 o) Kaliakoir-Summi 300 at Kaliakoir end & Dis c) Maghadikakoir-Summi 300 el Kaliakoir-Suma at 450 MW Baozan unit-2 was sy b Khulna (C)-Khulna 22 J Tangail-Mymensingh 10 end & Dist C.J. B-pha end & Dist C.J. B-pha switched on at 18:16, J Roizan unit-1 was si) Sylhet 225 MW GT w Hasnabad-Kamrangin) Keranigan New-Laib) Haripur 360 MW was 1) Chowmuhuni 132/33 WOrth was 1) Chowmuhuni 132/33 2) Kabirpur-Manikganj 1 2) Manikganj 132/33 KW	V Ckt-2 was un 0 MW PP. 230 kt 1 E/F at PP. end V GT-1 tripped at ynchronized at 12 5 MW Ckt was un RPCL PP. 132 kt ase at P.P. end at hutdown at 18:51. was synchronized hutdown at 16:32 kV Ckt-1 was 132 kV Ckt-1 was V T3 transformer i shutdown at 07:2'	der shut down from 10.44 to 16 V Ckt tripped at 10:33 from boll 1 and was switched on at 11:33. 09:57 due to Gas Valve problet :30. nder shut down from 09:54 to 1 V Ckt tripped at 13:08 from bol nd was switched on at 13:29 an at 22:43. was shutdown at 05:54(27/08/2 / Ckt was shutdown at 05:54(27/08/2 / Ckt was shutdown at 05:54(27/08/2 / 62/708/2021) due to ST proble 57(27/08/2021) due to ST proble 57(27/08/2021) due to ST proble 57(27/08/2021) for maintenance et is under shutdown since 07:41 (27/08/2021) for maintenance.	6:22 for C/M. th ends showing Pole discrepancy I. Im and was synchronized at 11:27. 12:05 for C/M. 12:05 for C/M. 12:05 for C/M. 12:05 for D/W. 12:021) for D/W. 12:021) for D/W. 12:0221) for D/W. 13:027/08/2021) for D/W. 13:027/08/2021) for D/W. 27:08/2021) for D/W. 27:08/2021) for D/W.				About 40 MW po	(27/08/202	21).	-
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 30(at Kaliakoir end & Summit 30) b) Meghnaghat 450 MW 1) Raozan unit-2 was sy 0) Khulna (2)-Khulna 22 0) Fangail-Mymensingh 1) 9) Khul 22 (3)-Khulna 22 1) Tangail-Mymensingh 1) 9) Raozan unit-1 was at 1) Siphet 225 KMW GT w 1) Harsnabad-Kamrangin 1) Keranigan J New-Kam (3) Keranigan J New-Kam (3) Kabingan J North was 1) Chowmuhuri 132/33 5) Kabirpur-Manikgan j 1) Manikgan j 132/33 kV	V V Ckt-2 was un 0 MW PP. 230 kt 1 E/F at P.P. end V GT-1 tripped at ynchronized at 12 5 MW Ckt was ur RPCL PP. 132 kt se at P.P. end at is. hutdown at 18:51. was synchronized thoran 132 kV Ckt- trangirchar 132 kV Ckt- trangirchar 132 kV Ckt- transformer i shutdown at 06:2 shutdown at 06:2 shutdown at 06:2 shutdown at 07:2' hv V Ti transformer i shutdown at 07:2' hv V Ti transformer i shutdown at 07:2'	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from bolt and was switched on at 11:28, 09:57 due to Gas Valve problem :30. dider shut down from 09:54 to 1: V Ckt tripped at 13:08 from bol nd was switched on at 13:29 an	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail 14:05 for C/M. th ends showing E/F at Tangail 14:05 for D/W. 12:02(2021) for D/W. 12:03(2021) for D/W. 12:03(2021) for D/W. 13:02(2021) due to R/H maintenance. 13:02(208)/2021) due to R/H maintenance. 13:02(208)/2021) for D/W. 				About 40 MW po	(27/08/202 St	21).	ent Engineer
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 c) Kaliakoir-Summit 300 c) Majanghat 450 MW c) Meghnaghat 450 MW c) Maghnaghat 450 MW c) Raczan unit-2 was sy b) Khulna (2)-Khulna 22 c) Tangail-Mymensingh n end & Dist. 21, B-phe switched on at 18:16, c) Raczan unit-1 was st c) System 225 MW GT w Haranbad-Kamrangin () Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Kabirpur-Manikgan (c) Chowmuhuni 132/33 kV c) Sabirpur-Manikgan (c) Stajaganj unit-2 was st Sub Divisional Enginee	V V Ckt-2 was un 0 MW PP. 230 kt 1 E/F at P.P. end V GT-1 tripped at ynchronized at 12 5 MW Ckt was ur RPCL PP. 132 kt se at P.P. end at is. hutdown at 18:51. was synchronized thoran 132 kV Ckt- trangirchar 132 kV Ckt- trangirchar 132 kV Ckt- transformer i shutdown at 06:2 shutdown at 06:2 shutdown at 06:2 shutdown at 07:2' hv V Ti transformer i shutdown at 07:2' hv V Ti transformer i shutdown at 07:2'	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from boll and was switched on at 11:28, 05:7 due to Gas Valve problem :30, nder shut down from 09:54 to 1, V Ckt tripped at 13:08 from bot nd was switched on at 13:29 an at 22:43. was shutdown at 05:54(27/08/2 / Ckt was shutdown at 05:54(27/08/2 / Ckt was shutdown at 06:38(2 ;2,23 were shutdown at 06:38(2 ;(27/08/2021) for maintenance r is under shutdown since 07:41(1(27/08/2021) for maintenance.	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail 14:05 for C/M. th ends showing E/F at Tangail 14:05 for D/W. 12:02(2021) for D/W. 12:03(2021) for D/W. 12:03(2021) for D/W. 13:02(2021) due to R/H maintenance. 13:02(208)/2021) due to R/H maintenance. 13:02(208)/2021) for D/W. 				About 40 MW po	(27/08/202 St	21). uperintende	ent Engineer
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 c) Kaliakoir-Summit 300 c) Majanghat 450 MW c) Meghnaghat 450 MW c) Maghnaghat 450 MW c) Raczan unit-2 was sy b) Khulna (2)-Khulna 22 c) Tangail-Mymensingh n end & Dist. 21, B-phe switched on at 18:16, c) Raczan unit-1 was st c) System 225 MW GT w Haranbad-Kamrangin () Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Kabirpur-Manikgan (c) Chowmuhuni 132/33 kV c) Sabirpur-Manikgan (c) Stajaganj unit-2 was st Sub Divisional Enginee	V V Ckt-2 was un 0 MW PP. 230 kt 1 E/F at P.P. end V GT-1 tripped at ynchronized at 12 5 MW Ckt was ur RPCL PP. 132 kt se at P.P. end at is. hutdown at 18:51. was synchronized thoran 132 kV Ckt- trangirchar 132 kV Ckt- trangirchar 132 kV Ckt- transformer i shutdown at 06:2 shutdown at 06:2 shutdown at 06:2 shutdown at 07:2' hv V Ti transformer i shutdown at 07:2' hv V Ti transformer i shutdown at 07:2'	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from boll and was switched on at 11:28, 05:7 due to Gas Valve problem :30, nder shut down from 09:54 to 1, V Ckt tripped at 13:08 from bot nd was switched on at 13:29 an at 22:43. was shutdown at 05:54(27/08/2 / Ckt was shutdown at 05:54(27/08/2 / Ckt was shutdown at 06:38(2 ;2,23 were shutdown at 06:38(2 ;(27/08/2021) for maintenance r is under shutdown since 07:41(1(27/08/2021) for maintenance.	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail 14:05 for C/M. th ends showing E/F at Tangail 14:05 for D/W. 12:02(2021) for D/W. 12:03(2021) for D/W. 12:03(2021) for D/W. 13:02(2021) due to R/H maintenance. 13:02(208)/2021) due to R/H maintenance. 13:02(208)/2021) for D/W. 				About 40 MW po	(27/08/202 St	21). uperintende	ent Engineer
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 c) Kaliakoir-Summit 300 c) Majanghat 450 MW c) Meghnaghat 450 MW c) Maghnaghat 450 MW c) Raczan unit-2 was sy b) Khulna (2)-Khulna 22 c) Tangail-Mymensingh n end & Dist. 21, B-phe switched on at 18:16, c) Raczan unit-1 was st c) System 225 MW GT w Haranbad-Kamrangin c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Kabirpur-Manikgan 1 c) Chowmuhuni 132/33 kV c) Sabirpur-Manikgan 1 c) Manikganj 132/33 kV c) Sirajganj unit-2 was st Sub Divisional Enginee	V V Ckt-2 was un 0 MW PP. 230 kt 1 E/F at P.P. end V GT-1 tripped at ynchronized at 12 5 MW Ckt was ur RPCL PP. 132 kt se at P.P. end at is. hutdown at 18:51. was synchronized thoran 132 kV Ckt- trangirchar 132 kV Ckt- trangirchar 132 kV Ckt- transformer i shutdown at 06:2 shutdown at 06:2 shutdown at 06:2 shutdown at 07:2' hv V Ti transformer i shutdown at 07:2' hv V Ti transformer i shutdown at 07:2'	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from boll and was switched on at 11:28, 09:57 due to Gas Valve problem :30, nder shut down from 09:54 to 1, V Ckt tripped at 13:08 from bot nd was switched on at 13:29 an at 22:43. was shutdown at 05:54(27/08/2 / Ckt was shutdown at 05:54(27/08/2 / Ckt was shutdown at 06:38(2 ;2,23 were shutdown at 06:38(2 ;(27/08/2021) for maintenance r is under shutdown since 07:41(1(27/08/2021) for maintenance.	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail 14:05 for C/M. th ends showing E/F at Tangail 14:05 for D/W. 12:02(2021) for D/W. 12:03(2021) for D/W. 12:03(2021) for D/W. 13:02(2021) due to R/H maintenance. 13:02(208)/2021) due to R/H maintenance. 13:02(208)/2021) for D/W. 				About 40 MW po	(27/08/202 St	21). uperintende	ent Engineer
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 c) Kaliakoir-Summit 300 c) Majanghat 450 MW c) Meghnaghat 450 MW c) Maghnaghat 450 MW c) Raczan unit-2 was sy b) Khulna (2)-Khulna 22 c) Tangail-Mymensingh n end & Dist. 21, B-phe switched on at 18:16, c) Raczan unit-1 was st c) System 225 MW GT w Haranbad-Kamrangin c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Kabirpur-Manikgan 1 c) Chowmuhuni 132/33 kV c) Sabirpur-Manikgan 1 c) Manikganj 132/33 kV c) Sirajganj unit-2 was st Sub Divisional Enginee	V V Ckt-2 was un 0 MW PP. 230 kt 1 E/F at P.P. end V GT-1 tripped at ynchronized at 12 5 MW Ckt was ur RPCL PP. 132 kt se at P.P. end at is. hutdown at 18:51. was synchronized thoran 132 kV Ckt- trangirchar 132 kV Ckt- trangirchar 132 kV Ckt- transformer i shutdown at 06:2 shutdown at 06:2 shutdown at 06:2 shutdown at 07:2' hv V Ti transformer i shutdown at 07:2' hv V Ti transformer i shutdown at 07:2'	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from boll and was switched on at 11:28, 09:57 due to Gas Valve problem :30, nder shut down from 09:54 to 1, V Ckt tripped at 13:08 from bot nd was switched on at 13:29 an at 22:43. was shutdown at 05:54(27/08/2 / Ckt was shutdown at 05:54(27/08/2 / Ckt was shutdown at 06:38(2 ;2,23 were shutdown at 06:38(2 ;(27/08/2021) for maintenance r is under shutdown since 07:41(1(27/08/2021) for maintenance.	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail 14:05 for C/M. th ends showing E/F at Tangail 14:05 for D/W. 12:02(2021) for D/W. 12:03(2021) for D/W. 12:03(2021) for D/W. 13:02(2021) due to R/H maintenance. 13:02(208)/2021) due to R/H maintenance. 13:02(208)/2021) for D/W. 				About 40 MW po	(27/08/202 St	21). uperintende	ent Engineer
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 c) Kaliakoir-Summit 300 c) Majanghat 450 MW c) Meghnaghat 450 MW c) Maghnaghat 450 MW c) Raczan unit-2 was sy b) Khulna (2)-Khulna 22 c) Tangail-Mymensingh n end & Dist. 21, B-phe switched on at 18:16, c) Raczan unit-1 was st c) System 225 MW GT w Haranbad-Kamrangin c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Kabirpur-Manikgan 1 c) Chowmuhuni 132/33 kV c) Sabirpur-Manikgan 1 c) Manikganj 132/33 kV c) Sirajganj unit-2 was st Sub Divisional Enginee	V V Ckt-2 was un 0 MW PP. 230 kt 1 E/F at P.P. end V GT-1 tripped at ynchronized at 12 5 MW Ckt was ur RPCL PP. 132 kt se at P.P. end at is. hutdown at 18:51. was synchronized thoran 132 kV Ckt- trangirchar 132 kV Ckt- trangirchar 132 kV Ckt- transformer i shutdown at 06:2 shutdown at 06:2 shutdown at 06:2 shutdown at 07:2' hv V Ti transformer i shutdown at 07:2' hv V Ti transformer i shutdown at 07:2'	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from boll and was switched on at 11:28, 09:57 due to Gas Valve problem :30, nder shut down from 09:54 to 1, V Ckt tripped at 13:08 from bot nd was switched on at 13:29 an at 22:43. was shutdown at 05:54(27/08/2 / Ckt was shutdown at 05:54(27/08/2 / Ckt was shutdown at 06:38(2 ;2,23 were shutdown at 06:38(2 ;(27/08/2021) for maintenance r is under shutdown since 07:41(1(27/08/2021) for maintenance.	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail 14:05 for C/M. th ends showing E/F at Tangail 14:05 for D/W. 12:02(2021) for D/W. 12:03(2021) for D/W. 12:03(2021) for D/W. 13:02(2021) due to R/H maintenance. 13:02(208)/2021) due to R/H maintenance. 13:02(208)/2021) for D/W. 				About 40 MW po	(27/08/202 St	21). uperintende	ent Engineer
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 c) Kaliakoir-Summit 300 c) Majanghat 450 MW c) Meghnaghat 450 MW c) Maghnaghat 450 MW c) Raczan unit-2 was sy b) Khulna (2)-Khulna 22 c) Tangail-Mymensingh n end & Dist. 21, B-phe switched on at 18:16, c) Raczan unit-1 was st c) System 225 MW GT w Haranbad-Kamrangin c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Kabirpur-Manikgan 1 c) Chowmuhuni 132/33 kV c) Sabirpur-Manikgan 1 c) Manikganj 132/33 kV c) Sirajganj unit-2 was st Sub Divisional Enginee	V V Ckt-2 was un 0 MW PP. 230 kt 1 E/F at P.P. end V GT-1 tripped at ynchronized at 12 5 MW Ckt was ur RPCL PP. 132 kt se at P.P. end at is. hutdown at 18:51. was synchronized thoran 132 kV Ckt- trangirchar 132 kV Ckt- trangirchar 132 kV Ckt- transformer i shutdown at 06:2 shutdown at 06:2 shutdown at 06:2 shutdown at 07:2' hv V Ti transformer i shutdown at 07:2' hv V Ti transformer i shutdown at 07:2'	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from boll and was switched on at 11:28, 09:57 due to Gas Valve problem :30, nder shut down from 09:54 to 1, V Ckt tripped at 13:08 from bot nd was switched on at 13:29 an at 22:43. was shutdown at 05:54(27/08/2 / Ckt was shutdown at 05:54(27/08/2 / Ckt was shutdown at 06:38(2 ;2,23 were shutdown at 06:38(2 ;(27/08/2021) for maintenance r is under shutdown since 07:41(1(27/08/2021) for maintenance.	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail 14:05 for C/M. th ends showing E/F at Tangail 14:05 for D/W. 12:02(2021) for D/W. 12:03(2021) for D/W. 12:03(2021) for D/W. 13:02(2021) due to R/H maintenance. 13:02(208)/2021) due to R/H maintenance. 13:02(208)/2021) for D/W. 				About 40 MW po	(27/08/202 St	21). uperintende	ent Engineer
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 c) Kaliakoir-Summit 300 c) Majanghat 450 MW c) Meghnaghat 450 MW c) Maghnaghat 450 MW c) Raczan unit-2 was sy b) Khulna (2)-Khulna 22 c) Tangail-Mymensingh n end & Dist. 21, B-phe switched on at 18:16, c) Raczan unit-1 was st c) System 225 MW GT w Haranbad-Kamrangin c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Kabirpur-Manikgan 1 c) Chowmuhuni 132/33 kV c) Sabirpur-Manikgan 1 c) Manikganj 132/33 kV c) Sirajganj unit-2 was st Sub Divisional Enginee	V V Ckt-2 was un 0 MW PP. 230 kt 1 E/F at P.P. end V GT-1 tripped at ynchronized at 12 5 MW Ckt was ur RPCL PP. 132 kt se at P.P. end at is. hutdown at 18:51. was synchronized thoran 132 kV Ckt- trangirchar 132 kV Ckt- trangirchar 132 kV Ckt- transformer i shutdown at 06:2 shutdown at 06:2 shutdown at 06:2 shutdown at 07:2' hv V Ti transformer i shutdown at 07:2' hv V Ti transformer i shutdown at 07:2'	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from boll and was switched on at 11:28, 09:57 due to Gas Valve problem :30, nder shut down from 09:54 to 1, V Ckt tripped at 13:08 from bot nd was switched on at 13:29 an at 22:43. was shutdown at 05:54(27/08/2 / Ckt was shutdown at 05:54(27/08/2 / Ckt was shutdown at 06:38(2 ;2,23 were shutdown at 06:38(2 ;(27/08/2021) for maintenance r is under shutdown since 07:41(1(27/08/2021) for maintenance.	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail 14:05 for C/M. th ends showing E/F at Tangail 14:05 for D/W. 12:02(2021) for D/W. 12:03(2021) for D/W. 12:03(2021) for D/W. 13:02(2021) due to R/H maintenance. 13:02(208)/2021) due to R/H maintenance. 13:02(208)/2021) for D/W. 				About 40 MW po	(27/08/202 St	21). uperintende	ent Engineer
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 c) Kaliakoir-Summit 300 c) Majanghat 450 MW c) Meghnaghat 450 MW c) Maghnaghat 450 MW c) Raczan unit-2 was sy b) Khulna (2)-Khulna 22 c) Tangail-Mymensingh n end & Dist. 21, B-phe switched on at 18:16, c) Raczan unit-1 was st c) System 225 MW GT w Haranbad-Kamrangin c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Kabirpur-Manikgan 1 c) Chowmuhuni 132/33 kV c) Sabirpur-Manikgan 1 c) Manikganj 132/33 kV c) Sirajganj unit-2 was st Sub Divisional Enginee	V V Ckt-2 was un 0 MW PP. 230 kt 1 E/F at P.P. end V GT-1 tripped at ynchronized at 12 5 MW Ckt was ur RPCL PP. 132 kt se at P.P. end at is. hutdown at 18:51. was synchronized thoran 132 kV Ckt- trangirchar 132 kV Ckt- trangirchar 132 kV Ckt- transformer i shutdown at 06:2 shutdown at 06:2 shutdown at 06:2 shutdown at 07:2' hv V Ti transformer i shutdown at 07:2' hv V Ti transformer i shutdown at 07:2'	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from boll and was switched on at 11:28, 09:57 due to Gas Valve problem :30, nder shut down from 09:54 to 1, V Ckt tripped at 13:08 from bot nd was switched on at 13:29 an at 22:43. was shutdown at 05:54(27/08/2 / Ckt was shutdown at 05:54(27/08/2 / Ckt was shutdown at 06:38(2 ;2,23 were shutdown at 06:38(2 ;(27/08/2021) for maintenance r is under shutdown since 07:41(1(27/08/2021) for maintenance.	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail 14:05 for C/M. th ends showing E/F at Tangail 14:05 for D/W. 12:02(2021) for D/W. 12:03(2021) for D/W. 12:03(2021) for D/W. 13:02(2021) due to R/H maintenance. 13:02(208)/2021) due to R/H maintenance. 13:02(208)/2021) for D/W. 				About 40 MW po	(27/08/202 St	21). uperintende	ent Engineer
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 c) Kaliakoir-Summit 300 c) Majanghat 450 MW c) Meghnaghat 450 MW c) Maghnaghat 450 MW c) Raczan unit-2 was sy b) Khulna (2)-Khulna 22 c) Tangail-Mymensingh n end & Dist. 21, B-phe switched on at 18:16, c) Raczan unit-1 was st c) System 225 MW GT w Haranbad-Kamrangin c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Kabirpur-Manikgan 1 c) Chowmuhuni 132/33 kV c) Sabirpur-Manikgan 1 c) Manikganj 132/33 kV c) Sirajganj unit-2 was st Sub Divisional Enginee	V V Ckt-2 was un 0 MW PP. 230 kt 1 E/F at P.P. end V GT-1 tripped at ynchronized at 12 5 MW Ckt was ur RPCL PP. 132 kt se at P.P. end at is. hutdown at 18:51. was synchronized thoran 132 kV Ckt- trangirchar 132 kV Ckt- trangirchar 132 kV Ckt- transformer i shutdown at 06:2 shutdown at 06:2 shutdown at 06:2 shutdown at 07:2' hv V Ti transformer i shutdown at 07:2' hv V Ti transformer i shutdown at 07:2'	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from boll and was switched on at 11:28, 09:57 due to Gas Valve problem :30, nder shut down from 09:54 to 1, V Ckt tripped at 13:08 from bot nd was switched on at 13:29 an at 22:43. was shutdown at 05:54(27/08/2 / Ckt was shutdown at 05:54(27/08/2 / Ckt was shutdown at 06:38(2 ;2,23 were shutdown at 06:38(2 ;(27/08/2021) for maintenance r is under shutdown since 07:41(1(27/08/2021) for maintenance.	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail 14:05 for C/M. th ends showing E/F at Tangail 14:05 for D/W. 12:02(2021) for D/W. 12:03(2021) for D/W. 12:03(2021) for D/W. 13:02'708/2021) due to R/H maintenance. 13:02'708/2021) due to R/H maintenance. 13:02'708/2021) for D/W. 				About 40 MW po	(27/08/202 St	21). uperintende	ent Engineer
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 c) Kaliakoir-Summit 300 c) Majanghat 450 MW c) Meghnaghat 450 MW c) Maghnaghat 450 MW c) Raczan unit-2 was sy b) Khulna (2)-Khulna 22 c) Tangail-Mymensingh n end & Dist. 21, B-phe switched on at 18:16, c) Raczan unit-1 was st c) System 225 MW GT w Haranbad-Kamrangin c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Kabirpur-Manikgan 1 c) Chowmuhuni 132/33 kV c) Sabirpur-Manikgan 1 c) Manikganj 132/33 kV c) Sirajganj unit-2 was st Sub Divisional Enginee	V V Ckt-2 was un 0 MW PP. 230 kt 1 E/F at P.P. end V GT-1 tripped at ynchronized at 12 5 MW Ckt was ur RPCL PP. 132 kt se at P.P. end at is. hutdown at 18:51. was synchronized tripped at 18:51. was synchronized tripped at 18:51. was synchronized tripped at 18:51. was synchronized is. hutdown at 18:51. S shutdown at 06:2 s shutdown at 06:2 s shutdown at 06:2 s shutdown at 07:2' shutdown at 07:2' shutdown at 07:2' shutdown at 07:2'	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from boll and was switched on at 11:28, 09:57 due to Gas Valve problem :30, nder shut down from 09:54 to 1, V Ckt tripped at 13:08 from bot nd was switched on at 13:29 an at 22:43. was shutdown at 05:54(27/08/2 / Ckt was shutdown at 05:54(27/08/2 / Ckt was shutdown at 06:38(2 ;2,23 were shutdown at 06:38(2 ;(27/08/2021) for maintenance r is under shutdown since 07:41(1(27/08/2021) for maintenance.	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail 14:05 for C/M. th ends showing E/F at Tangail 14:05 for D/W. 12:02(2021) for D/W. 12:03(2021) for D/W. 12:03(2021) for D/W. 13:02'708/2021) due to R/H maintenance. 13:02'708/2021) due to R/H maintenance. 13:02'708/2021) for D/W. 				About 40 MW po	(27/08/202 St	21). uperintende	ent Engineer
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 c) Kaliakoir-Summit 300 c) Majanghat 450 MW c) Meghnaghat 450 MW c) Maghnaghat 450 MW c) Raczan unit-2 was sy b) Khulna (2)-Khulna 22 c) Tangail-Mymensingh n end & Dist. 21, B-phe switched on at 18:16, c) Raczan unit-1 was st c) System 225 MW GT w Haranbad-Kamrangin c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Kabirpur-Manikgan 1 c) Chowmuhuni 132/33 kV c) Sabirpur-Manikgan 1 c) Manikganj 132/33 kV c) Sirajganj unit-2 was st Sub Divisional Enginee	V V Ckt-2 was un 0 MW PP. 230 kt 1 E/F at P.P. end V GT-1 tripped at ynchronized at 12 5 MW Ckt was ur RPCL PP. 132 kt se at P.P. end at is. hutdown at 18:51. was synchronized tripped at 18:51. was synchronized tripped at 18:51. was synchronized tripped at 18:51. was synchronized is. hutdown at 18:51. S shutdown at 06:2 s shutdown at 06:2 s shutdown at 06:2 s shutdown at 07:2' shutdown at 07:2' shutdown at 07:2' shutdown at 07:2'	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from boll and was switched on at 11:28, 09:57 due to Gas Valve problem :30, nder shut down from 09:54 to 1, V Ckt tripped at 13:08 from bot nd was switched on at 13:29 an at 22:43. was shutdown at 05:54(27/08/2 / Ckt was shutdown at 05:54(27/08/2 / Ckt was shutdown at 06:38(2 ;2,23 were shutdown at 06:38(2 ;(27/08/2021) for maintenance r is under shutdown since 07:41(1(27/08/2021) for maintenance.	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail 14:05 for C/M. th ends showing E/F at Tangail 14:05 for D/W. 12:02(2021) for D/W. 12:03(2021) for D/W. 12:03(2021) for D/W. 13:02'708/2021) due to R/H maintenance. 13:02'708/2021) due to R/H maintenance. 13:02'708/2021) for D/W. 				About 40 MW po	(27/08/202 St	21). uperintende	ent Engineer
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 c) Kaliakoir-Summit 300 c) Majanghat 450 MW c) Meghnaghat 450 MW c) Maghnaghat 450 MW c) Raczan unit-2 was sy b) Khulna (2)-Khulna 22 c) Tangail-Mymensingh n end & Dist. 21, B-phe switched on at 18:16, c) Raczan unit-1 was st c) System 225 MW GT w Haranbad-Kamrangin c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Keraniganj New-Kam c) Kabirpur-Manikgan 1 c) Chowmuhuni 132/33 kV c) Sabirpur-Manikgan 1 c) Manikganj 132/33 kV c) Sirajganj unit-2 was st Sub Divisional Enginee	V V Ckt-2 was un 0 MW PP. 230 kt 1 E/F at P.P. end V GT-1 tripped at ynchronized at 12 5 MW Ckt was ur RPCL PP. 132 kt se at P.P. end at is. hutdown at 18:51. was synchronized tripped at 18:51. was synchronized tripped at 18:51. was synchronized tripped at 18:51. was synchronized is. hutdown at 18:51. S shutdown at 06:2 s shutdown at 06:2 s shutdown at 06:2 s shutdown at 07:2' shutdown at 07:2' shutdown at 07:2' shutdown at 07:2'	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from boll and was switched on at 11:28, 09:57 due to Gas Valve problem :30, nder shut down from 09:54 to 1, V Ckt tripped at 13:08 from bot nd was switched on at 13:29 an at 22:43. was shutdown at 05:54(27/08/2 / Ckt was shutdown at 05:54(27/08/2 / Ckt was shutdown at 06:38(2 ;2,23 were shutdown at 06:38(2 ;(27/08/2021) for maintenance r is under shutdown since 07:41(1(27/08/2021) for maintenance.	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail 14:05 for C/M. th ends showing E/F at Tangail 14:05 for D/W. 12:02(2021) for D/W. 12:03(2021) for D/W. 12:03(2021) for D/W. 13:02'708/2021) due to R/H maintenance. 13:02'708/2021) due to R/H maintenance. 13:02'708/2021) for D/W. 				About 40 MW po	(27/08/202 St	21). uperintende	ent Engineer
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 c) Kaliakoir-Summit 300 c) Majahadi 450 MW c) Meghnaphat 450 MW c) Maghnaphat 450 MW c) Raczan unit-2 was sy b) Khulna (2)-Khulna 22) Tangail-Mymensingh n end & Dist. 21, B-phe switched on at 18:16, c) Raczan unit-1 was st) Sythet 225 MW GT w Harabad-Kamrangin) Keraniganj New-Kam c) Keraniganj New-Kam n) Ashuganj New-Kam New-Manikaganj) Kabirpur-Manikaganj at 2000 New Man Sub Divisional Enginee	V V Ckt-2 was un 0 MW PP. 230 kt 1 E/F at P.P. end V GT-1 tripped at ynchronized at 12 5 MW Ckt was ur RPCL PP. 132 kt se at P.P. end at is. hutdown at 18:51. was synchronized tripped at 18:51. was synchronized tripped at 18:51. was synchronized tripped at 18:51. was synchronized is. hutdown at 18:51. S shutdown at 06:2 s shutdown at 06:2 s shutdown at 06:2 s shutdown at 07:2' shutdown at 07:2' shutdown at 07:2' shutdown at 07:2'	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from boll and was switched on at 11:28, 09:57 due to Gas Valve problem :30, nder shut down from 09:54 to 1, V Ckt tripped at 13:08 from bot nd was switched on at 13:29 an at 22:43. was shutdown at 05:54(27/08/2 / Ckt was shutdown at 05:54(27/08/2 / Ckt was shutdown at 06:38(2 ;2,23 were shutdown at 06:38(2 ;(27/08/2021) for maintenance r is under shutdown since 07:41(1(27/08/2021) for maintenance.	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail 14:05 for C/M. th ends showing E/F at Tangail 14:05 for D/W. 12:02(2021) for D/W. 12:03(2021) for D/W. 12:03(2021) for D/W. 13:02'708/2021) due to R/H maintenance. 13:02'708/2021) due to R/H maintenance. 13:02'708/2021) for D/W. 				About 40 MW po	(27/08/202 St	21). uperintende	ent Engineer
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 c) Kaliakoir-Summit 300 c) Majahadi 450 MW c) Meghnaphat 450 MW c) Maghnaphat 450 MW c) Raczan unit-2 was sy b) Khulna (2)-Khulna 22) Tangail-Mymensingh n end & Dist. 21, B-phe switched on at 18:16, c) Raczan unit-1 was st) Sythet 225 MW GT w Harabad-Kamrangin) Keraniganj New-Kam c) Keraniganj New-Kam n) Ashuganj New-Kam New-Manikaganj) Kabirpur-Manikaganj at 2000 New Man Sub Divisional Enginee	V V Ckt-2 was un 0 MW PP. 230 kt 1 E/F at P.P. end V GT-1 tripped at ynchronized at 12 5 MW Ckt was ur RPCL PP. 132 kt se at P.P. end at is. hutdown at 18:51. was synchronized tripped at 18:51. was synchronized tripped at 18:51. was synchronized tripped at 18:51. was synchronized is. hutdown at 18:51. S shutdown at 06:2 s shutdown at 06:2 s shutdown at 06:2 s shutdown at 07:2' shutdown at 07:2' shutdown at 07:2' shutdown at 07:2'	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from boll and was switched on at 11:28, 05:7 due to Gas Valve problem :30, nder shut down from 09:54 to 1, V Ckt tripped at 13:08 from bot nd was switched on at 13:29 an at 22:43. was shutdown at 05:54(27/08/2 / Ckt was shutdown at 05:54(27/08/2 / Ckt was shutdown at 06:38(2 ;2,23 were shutdown at 06:38(2 ;(27/08/2021) for maintenance r is under shutdown since 07:41(1(27/08/2021) for maintenance.	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail 14:05 for C/M. th ends showing E/F at Tangail 14:05 for D/W. 12:02(2021) for D/W. 12:03(2021) for D/W. 12:03(2021) for D/W. 13:02'708/2021) due to R/H maintenance. 13:02'708/2021) due to R/H maintenance. 13:02'708/2021) for D/W. 				About 40 MW po	(27/08/202 St	21). uperintende	ent Engineer
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 c) Kaliakoir-Summit 300 c) Majahadi 450 MW c) Meghnaphat 450 MW c) Maghnaphat 450 MW c) Raczan unit-2 was sy b) Khulna (2)-Khulna 22) Tangail-Mymensingh n end & Dist. 21, B-phe switched on at 18:16, c) Raczan unit-1 was st) Sythet 225 MW GT w Harabad-Kamrangin) Keraniganj New-Kam c) Keraniganj New-Kam n) Ashuganj New-Kam New-Manikaganj) Kabirpur-Manikaganj at 2000 New Man Sub Divisional Enginee	V V Ckt-2 was un 0 MW PP. 230 kt 1 E/F at P.P. end V GT-1 tripped at ynchronized at 12 5 MW Ckt was ur RPCL PP. 132 kt se at P.P. end at is. hutdown at 18:51. was synchronized tripped at 18:51. was synchronized tripped at 18:51. was synchronized tripped at 18:51. was synchronized is. hutdown at 18:51. S shutdown at 06:2 s shutdown at 06:2 s shutdown at 06:2 s shutdown at 07:2' shutdown at 07:2' shutdown at 07:2' shutdown at 07:2'	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from boll and was switched on at 11:28, 05:7 due to Gas Valve problem :30, nder shut down from 09:54 to 1, V Ckt tripped at 13:08 from bot nd was switched on at 13:29 an at 22:43. was shutdown at 05:54(27/08/2 / Ckt was shutdown at 05:54(27/08/2 / Ckt was shutdown at 06:38(2 ;2,23 were shutdown at 06:38(2 ;(27/08/2021) for maintenance r is under shutdown since 07:41(1(27/08/2021) for maintenance.	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail 14:05 for C/M. th ends showing E/F at Tangail 14:05 for D/W. 12:02(2021) for D/W. 12:03(2021) for D/W. 12:03(2021) for D/W. 13:02'708/2021) due to R/H maintenance. 13:02'708/2021) due to R/H maintenance. 13:02'708/2021) for D/W. 				About 40 MW po	(27/08/202 St	21). uperintende	ent Engineer
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 c) Kaliakoir-Summit 300 c) Majahadi 450 MW c) Meghnaphat 450 MW c) Maghnaphat 450 MW c) Raczan unit-2 was sy b) Khulna (2)-Khulna 22) Tangail-Mymensingh n end & Dist. 21, B-phe switched on at 18:16, c) Raczan unit-1 was st) Sythet 225 MW GT w Harabad-Kamrangin) Keraniganj New-Kam c) Keraniganj New-Kam n) Ashuganj New-Kam New-Manikaganj) Kabirpur-Manikaganj at 2000 New Man Sub Divisional Enginee	V V Ckt-2 was un 0 MW PP. 230 kt 1 E/F at P.P. end V GT-1 tripped at ynchronized at 12 5 MW Ckt was ur RPCL PP. 132 kt se at P.P. end at is. hutdown at 18:51. was synchronized tripped at 18:51. was synchronized tripped at 18:51. was synchronized tripped at 18:51. was synchronized is. hutdown at 18:51. S shutdown at 06:2 s shutdown at 06:2 s shutdown at 06:2 s shutdown at 07:2' shutdown at 07:2' shutdown at 07:2' shutdown at 07:2'	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from boll and was switched on at 11:28, 05:7 due to Gas Valve problem :30, nder shut down from 09:54 to 1, V Ckt tripped at 13:08 from bot nd was switched on at 13:29 an at 22:43. was shutdown at 05:54(27/08/2 / Ckt was shutdown at 05:54(27/08/2 / Ckt was shutdown at 06:38(2 ;2,23 were shutdown at 06:38(2 ;(27/08/2021) for maintenance r is under shutdown since 07:41(1(27/08/2021) for maintenance.	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail 14:05 for C/M. th ends showing E/F at Tangail 14:05 for D/W. 12:02(2021) for D/W. 12:03(2021) for D/W. 12:03(2021) for D/W. 13:02'708/2021) due to R/H maintenance. 13:02'708/2021) due to R/H maintenance. 13:02'708/2021) for D/W. 				About 40 MW po	(27/08/202 St	21). uperintende	ent Engineer
a) Bhulta-Rampura 230 b) Kaliakoir-Summit 300 c) Kaliakoir-Summit 300 c) Majahadi 450 MW c) Meghnaphat 450 MW c) Maghnaphat 450 MW c) Raczan unit-2 was sy b) Khulna (2)-Khulna 22) Tangail-Mymensingh n end & Dist. 21, B-phe switched on at 18:16, c) Raczan unit-1 was st) Sythet 225 MW GT w Harabad-Kamrangin) Keraniganj New-Kam c) Keraniganj New-Kam n) Ashuganj New-Kam New-Manikaganj) Kabirpur-Manikaganj at 2000 New Man Sub Divisional Enginee	V V Ckt-2 was un 0 MW PP. 230 kt 1 E/F at P.P. end V GT-1 tripped at ynchronized at 12 5 MW Ckt was ur RPCL PP. 132 kt se at P.P. end at is. hutdown at 18:51. was synchronized tripped at 18:51. was synchronized tripped at 18:51. was synchronized tripped at 18:51. was synchronized is. hutdown at 18:51. S shutdown at 06:2 s shutdown at 06:2 s shutdown at 06:2 s shutdown at 07:2' shutdown at 07:2' shutdown at 07:2' shutdown at 07:2'	der shut down from 10:44 to 16 V Ckt tripped at 10:33 from boll and was switched on at 11:28, 05:7 due to Gas Valve problem :30, nder shut down from 09:54 to 1, V Ckt tripped at 13:08 from bot nd was switched on at 13:29 an at 22:43. was shutdown at 05:54(27/08/2 / Ckt was shutdown at 05:54(27/08/2 / Ckt was shutdown at 06:38(2 ;2,23 were shutdown at 06:38(2 ;(27/08/2021) for maintenance r is under shutdown since 07:41(1(27/08/2021) for maintenance.	6-22 for C/M. th ends showing Pole discrepancy 12:05 for C/M. th ends showing E/F at Tangail 14:05 for C/M. th ends showing E/F at Tangail 14:05 for D/W. 12:02(2021) for D/W. 12:03(2021) for D/W. 12:03(2021) for D/W. 13:02'708/2021) due to R/H maintenance. 13:02'708/2021) due to R/H maintenance. 13:02'708/2021) for D/W. 				About 40 MW po	(27/08/202 St	21). uperintende	ent Engineer

QF-LDC-08 Page -1

MW MW MW MW MW

MKWHR. MKWHR.

Liter Liter

g nand)

Chowmuhuni S/S