

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month September, 2021		Day: Sunday				Date: 26.09.21					
Probable Maximum Demand :		13300 MW		Probable Maximum Generation :		14930 MW		Rule Curve = 104.80 ft.			
Sl. No.	Name of Power Station	Yesterday = 106.56 ft	Installed Capacity (MW)	Derailed/ Present Capacity (MW)	Today = 106.45 ft.		26.09.21 (Today)		25.09.21 (Yesterday)	Status of Machines under shut-down/ Maintenance	
					Actual Generation (MW)		Probable Peak Generation (MW)				
					Day	Evening	Day	Evening			
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	285	310	310	310	126	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem
6	Harijpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage
7	Harijpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	312	326	325	325	34	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	280	280	280	280	170	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Harijpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	350	353	412	412	59	
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	290	280	280	290		
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	275	317	305	305		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55		
15	Keeraniganj 100 MW PP (Powerpac)	HFO (ORPP)	8x13.45	100	100	12	61	63	63		
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	64	102	102	102		
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	21	19	22	22		
18	Summit Power, (Madhab+Ashulla)	Gas (SIPP, REB)	6x3.7+1x6.73	80	80	49	53	53	53		
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33		
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	33	51	51	51		
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	100	100		
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	16	150	149	149		
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	54	54	54		
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	275	298	250	300		
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	114	130	149	149		
27	Keeraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	100	300		
28	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100		
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	25	50	100		
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	17	35	55	55		
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	35	55	55		
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	89	94	94	94		
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	108	162	162	162		
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	26	0	30	0		
Dhaka Zone Total			5717	5560	2886	3381	3672	3952	732	845	
35	Karnaphuli Hydro PP Unit-1,2,3,4,5	Hydro (PDB)	2x40, 3x50	230	230	169	115	115	165	40	Unit 2 under overhauling
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	115	120	115	120	60	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
37	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0		
38	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25		
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0		
40	Patanga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	18	50	50	50		
41	Sikalbaha 105 MW PP (Baraka Sikalib)	HFO (IPP)	6x18.415	105	105	80	105	90	90		
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting for purchase committee approval
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.94	300	300	305	305	300	300		
45	Juldah 100 MW Unit-1 (Accorn)	HFO (ORPP)	8x13.45	100	100	40	100	100	100		
46	Juldah 100 MW PP Unit-3 (Accorn)	HFO (IPP)	8x13.45	100	100	100	100	100	100		
47	Dohazari-Kalishah 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	0	68		
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0		
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21		Environment Issue
	* Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			2	7	10	30		
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	87	85	86		
51	Sikalbaha 54 MW PP(Jodac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
52	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	65	110	110	110		
53	Juldah unit-2 (Accorn)	HFO (IPP)	8x13.6	100	100	100	100	100	100		
54	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	108	108	116	116		
Chattogram Zone Total			2442	2382	1182	1475	1416	1535	240	415	
55	a) Ashuganj TPP Unit- 3	Gas (APSCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
56	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	23	23	23	23		
57	Ashuganj 225 MW CCPP	Gas (APSCL)	1x142+175	221	221	180	210	210	210		
58	Ashuganj 450 MW CCPP(South)	Gas (APSCL)	1x360	360	360	300	275	300	300		
59	Ashuganj 450 MW CCPP(North)	Gas (APSCL)	1x361	360	360	295	270	300	300		
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	51	51	51	51		
61	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	36	63	63	63	132	Gas shortage
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	35	43	43	43		
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	133	133	135	135		
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	0	50		
65	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	142	140	140	140		
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	155	193	200	200		
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	22	22	22		
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11		
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	52	52		
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	20	20	20		
72	Daudkandi 200 MW PP (B.Trac)	HFO (IPP)	19x11.44+1x15+15x1.059	200	200	0	30	150	200		
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	52	114	114	114		
74	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	49	96	90	94		
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
**	Impoprt (Tripura)	India		160	160	130	134	138	164		
Cumilla Zone Total			3094	3034	1678	1936	2112	2242	530	0	
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	151	167	160	170	35	Gas Shortage
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	22	22		
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	95	0	8	8	8		Dependable cap. :8MW
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	115	115	115	115		
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	100	182	175	180		
81	Sarisabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
82	Sutikhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	54	0	50	0		
83	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	0	22	22		
Mymensingh Zone Total			717	709	443	485	554	517	35	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.09.21 (Yesterday)		26.09.21 (Today)		25.09.21 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)				
84	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT1 Load gear problem		
85	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	Under maint.		
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	47	47	47					
87	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163					
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	30	25	30	30	41		Gas Shortage		
90	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	160	160	160	160	170		Gas Shortage		
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2.90	86	86	76	78	78	78					
92	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	152	220	220	220					
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18	2		Gas Shortage		
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	0	0					
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	22	24	24	24					
96	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	290	341	341					
97	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	316	315	316	316					
98	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	320	320	320	320					
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100		Under project work		
Sylhet Zone Total					2422	2377	1658	1714	1771	1771	213	117		
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
101	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+ 1 x 132	410	410	355	400	400	410					
102	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	25	0	32			Line Overload		
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload		
104	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	120	225	225	225					
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	50	50	100					
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	80	88	88	88					
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	100	100	100			Line Overload		
**	Bheramara (HVDC)	India		1000	1000	712	719	728	728					
Khulna Zone Total					2133	2129	1267	1507	1591	1723	0	0		
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	110	110			Line Overload		
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	22	35	33	33					
110	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	88	87	87	87	107		Arrival of GT2 HGPI experts delayed due to covid 19		
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	86	91	81	81					
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	370	530	622	622	714		Line Overload		
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	72	0	150					
114	Bhola 220MW CAPP (Nutan Bidyut BC	Gas/HSD (IPP)	2x75+1x70	220	220	89	106	220	220					
Barishal Zone Total					2046	2046	655	937	1153	1303	0	821		
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50					
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200					
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	36	34	36					
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	27	27	27					
121	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	90	94					
122	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	35					
123	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	0	43					
124	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	0	33					
125	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
126	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	191	188	200	220	32		Gas Shortage		
127	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	192	189	200	220					
128	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	396	420	400	400					
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	21	22	22					
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11					
131	Natore 52 MW PP (Rajanka)	HFO (IPP)	6x8.92	52	52	2	52	52	52					
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	95	113	113	113					
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	113	113	113					
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0					
Rajshahi Zone Total					2179	2179	1001	1428	1518	1669	413	0		
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	79	80	80	6		Coal Shortage		
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling		
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0	274		Under maint.		
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	15					
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	104	110	113	113					
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	10					
141	Majpara, Tabala 8 MW Solar PP (Sympa Powe	Solar (IPP)	1 x 8	8	8	7	0	8	0					
Rangpur Zone Total					685	605	191	189	201	218	6	359		
Sub-total: Plants in operation					21435	21021	10961.0	13052	13988	14930	2169	2557		
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss							10504	12508	13405	14308				
(B) Plants under long term maintenance/ contract expired														
142	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	0	0					
143	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	108	0	0	0	0					
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired		
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
147	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
148	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
Sub-Total: Plants under long term maintenance/ contract expired					596	159	0	0	0	0	0	0		
Gross Total					22031	21180	10961	13052	13988	14930	2169	2557		
(C) Actual data of 25.09.21 (Yesterday) Saturday :														
01.	Max. Demand at eve. peak (Generation end)	:	13052.00	MW, at = 20:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
02.	Max. Demand at eve. peak (Sub-station end)	:	12508.00	MW, at = 20:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	:	13052.00	MW, at = 20:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW		
04.	Minimum Generation (Generation end)	:	9880.00	MW, at = 7:00 hrs	Dhaka	4387	4387	0	Mymensingh	1018	1018	0		
05.	Day-peak Generation (Generation end)	:	10961.00	MW, at = 12:00 hrs	Chatogram	1290	1290	0	Sylhet	580	580	0		
06.	Evening-peak Generation (Generation end)	:	13052.00	MW, at = 20:00 hrs	Khulna	1566	1566	0	Barishal	384	384	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0.00	MW, at = 20:00 hrs	Rajshahi	1307	1307	0	Rangpur	753	753	0		
08.	Minimum Generation Forecast up to 8:00 hrs.	:	10085.00	MW, at = 5:00 hrs	Cumilla	1223	1223	0						
09.	Generation shortfall at evening peak due to :	:			Total							12508	12508	0
a)	Gas limitation	:	2163	MW	13.	Fuel cost: (a) Gas = 157306279 Taka		(c) Coal = 60831534 Taka						
b)	Coal supply Limitation	:	6	MW	(b) Oil = 626794153 Taka		Total = 844931967 Taka							
c)	Low water level in Kaptai lake	:	0	MW										
d)	Plants under shut down/ maintenance	:	2557	MW										
10.	Total Energy (Generation + India Import)	:	275.52	MKWh	14.	Maximum Temperature in Dhaka was : 35° C								
	By Gas = 151.734	MKWh	By Oil = 86.334	MKWh	15.	Export through East-West interconnections :								
	By Coal = 13.159	MKWh	By Hydro = 3.328	MKWh	At evening peak-hour : -174 MW, at 20:00 hrs									
	By Solar= 0.631	MKWh			Maximum : -316 MW, at 1:00 hrs									
11.	Total Gas Supplied	:	1160.69	MMCFD	Energy : 2.9265 MKWh									
(D) Forecast of 26.09.21 (Today) Sunday :														
01.	Maximum Demand	:	13300	MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	:	14930	MW (Generation end)	05.	Total Generation : 280.76 MKWh								
03.	Maximum Shortage	:	-1630	MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 34.8° C								

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Fazoul Islam Shaker)
Deputy Secretary, Generation