				L LOAD D	OF BANGLADES ESPATCH CENTE				· · · · · ·	QF-LDC-08
				DAILY R			_	Danastina Data	7-Oct-21	Page -1
Till now the maximum gene	eration is : -	13792.	0			20:00		Reporting Date : pr-21	7-Oct-21	
The Summary of Yesterday	's		ation & Demand				Today's Actual Min Gen. 8		Demand	
Day Peak Generation :		10784.0 MW		Hour :	12:00		Min. Gen. at	7:00		43 MW
Evening Peak Generation :		12829.0 MW		Hour :	19:30		Available Max Generation	:		51 MW
E.P. Demand (at gen end) : Maximum Generation :		12829.0 MW 12829.0 MW		Hour : Hour :	19:30 19:30		Max Demand (Evening) : Reserve(Generation end)			00 MW 51 MW
Total Gen. (MKWH) :		267.5	System Load		: 86.87%		Load Shed :		13	0 MW
			T THROUGH EAST-WE	ST INTER						
Export from East grid to West g				-4-	44 MW at		21:00	Energy		MKWHR.
Import from West grid to East g		7-Oct-2	-		MW at		•	Energy		- MKWHR.
Water Level of Kaptai I Actual:		7-Oct-2 Ft.(MSL) ,	21	Rule curve	: 106.54		Ft.( MSL )			
/ioidai .	100.00	u(MOL) ,		rtaio ourre	. 100.01		T L.( MOL )			
Gas Consumed :	Total =	1104.60 MMCF	D.		Oil Consumed	(PDB):				
							HSD			Liter
							FO	:		Liter
Cost of the Consumed Fuel (PD	IR+Pvt)	Gas :	Tk145,517,971							
:	511 11).	Coal :	Tk64,511,114			Oil	: Tk674,803,551	Total : Tk	884,832,636	
	1.						. ,,			
	LC	oad Shedding & Other Inform	nation							
Area	Yesterday						Today			
			Estimated Demand (S/	S end)			Estimated Shedding (S/S e		ates of Shedding	
Dhaka	MW 0	0:00	MW 4642				MW	0 (0	n Estimated Den 0%	nand)
Chittagong Area	0	0:00	4642 1583					0	0%	
Khulna Area	0	0:00	1420					0	0%	
Rajshahi Area	0	0:00	1283					0	0%	
Cumilla Area	0	0:00	1159					0	0%	
Mymensingh Area	0	0:00	936					0	0%	
Sylhet Area	0	0:00	517					0	0%	
Barisal Area	0	0:00	241					0	0%	
Rangpur Area Total	0	0:00	722 12502					0	0%	
Total	· ·		12302							
	Information of the G	enerating Units under shut dov	vn.							
Pli	anned Shut- Down				Forced Shut-I	Down				
					1) Barapukuria		-2 ,3			
					2) Ghorasal-3,4					
					<ol><li>Ashuganj-4,5</li></ol>		1			
					<ol> <li>Baghabari-7</li> <li>Bhola 225 M</li> </ol>	I MW &	100 MW			
					6) Sylhet-225 M		•			
					7) Raozan #02	ivv				
					8) Shajibazar 3	30 Mw G	T-2			
					o, chajibazar o	00 11111 0				
Ad	ditional Information o	f Machines, lines, Interruptio	on / Forced Load shed et	tc.						
a) Kulshi-Bakulia 132 kV Ckt wa	is under shut down from	08:54 to 14:39 for C/M								
b) HVDC 400 kV 10CF15 filter v	was shut down at 08:32	for A/M.								
c) Rangamati-Khagrachori 132 l			r A/M.							
d) Sikalbaha old-Sikalbaha new 132 kV Ckt-1 was under shut down from 09:02 to 17:12 for D/W.										
e) Cumilla(S) 132/33 kV T3 & T4 transformer tripped at 08:57 showing 50/51N,O/C,B phase relay							About 36 MW power interru	ption occurred unde	er Cumilla(s) S/S	area
due to 33 kV Y-phase PT bur							from 08:57 to 09:41.			
f) Haripur-Fatulla 132 kV Ckt wa										
g) Mithapukur 132/33 kV T2 tran	nsformer was under shu	t down from 13:07 to 13:25 di	ue to 33 kV maint							
by NESCO.	shut down at 11:59 for	CT aunobranizina								
h) Siddhirganj 335 MW GT was shut down at 11:58 for ST synchronizing. i) Siddhirganj peaking GT-1 was synchronized at 12:13 and shut down at 18:37 due to gas pressure low.										
By Studming and peaking G 1-1 was synchronized at 12:13 and shut down at 16:37 due to gas pressure low.   BYDC pole-2 cooling pump-2 was under shut down from 13:40 to 13:48 for C/M.										
I) Trube poles cooling points was under shut down from 08:22 to 15:26 for A/M.  k) Polashbari 132/33 kV T1 transformer was under shut down from 08:22 to 15:26 for A/M.										
I) Bogura 230/132 kV T2 transformer was under shut down from 08:27 to 15:33 for A/M.										
m) Siddhirganj 335 MW GT & ST were synchronized at 14:04,16:45 respectively.										
n) Mymensing 132/33 kV T1 & T2 transformer were under shut down from 17:59 to 18:08 due to loop										
burst of 33 kV ishwarganj fee										
o) Dohazari-Cox's Bazar 132 kV										
p) Hathazari-Baraulia 132 kV Cl	kt-2 tripped at 06:23 fro	m Hathazari end showing dist	R,Y phase and							
was switched on at 07:18(07-		1 at 02:14 due to fine non	at connector beet				About 45 MM	ntion occurred	or Durbonnelle	C/C area
<ul> <li>q) Purbasadipur 132/33 kV T2 &amp; T3 transformer tripped at 02:14 due to fire occ and were switched on at 03:20,03:55(07-10-2021) respectively.</li> </ul>			ccurred at capacitor bank			About 45 MW power interruption occurred under Purbasadipur S/S area from 02:14 to 03:20.				
r) Mymensing S/S-RPCL 132 kV Ckt-2 was under shut down since 07:28 for C/M.							110111 02:14 t0 03:20.			
, ,	under struct									
Sub Divisional Engineer		F	cutive Engineer					Superintendent En	nineer	
Network Operation Division Network Operation Division						Load Despatch Circle				