

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel: 954667, 9551095

Month October, 2021		Day : Wednesday				Date : 13.10.21						
Probable Maximum Demand :		13700 MW		Probable Maximum Generation :		14215 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 105.45 ft		Today = 105.40 ft		Rule Curve = 107.10 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.10.21 (Yesterday)		13.10.21 (Today)		12.10.21 (Yesterday) Gen. shortfall for : Gas/Water/Coal limitation MW	Machines shut down	Status of Machines under shut-down/ Maintenance	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under project work	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	280	270	280	300	126		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	CB Problem	
6	Hariপুর GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Hariপুর 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	143	156	200	200	204	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	250	250	250	250	200	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under overhauling	
10	Hariপুর 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	310	151	250	250	261		
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	280	260	280	280			
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	305	305	275	290	305	305			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.06+1x11.3	55	55	40	40	40	55			
15	Karaniganj 100 MW PP (Powerpac)	HFO (ORPP)	8x13.45	100	100	37	50	50	50			
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102			
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	20	20	20	20			
18	Summit Power (Madhaboli+Ashulia)	Gas (SIPP, REB)	6x3.67+3x7.9	80	80	35	53	55	55			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	33	33	33			
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	17	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	50	50	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	105	105			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	133	150	149	149			
24	Kanailahat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	286	300	250	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	155	304	100	300			
28	Branhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	100	100	100	100			
29	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	95	97	50	100			
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	35	55	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	33	0	30	0				
Dhaka Zone Total				5717	5560	3296	3377	3312	3617	932	1047	
35	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	158	159	160	160		40	Unit 2 under overhauling
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	110	115	115	115	65		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0			
38	Razcan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	8	0	20	0			
40	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	50	50	50	50			
41	Sikalbaha 105 MW PP (Baraka Sikalb)	HFO (IPP)	6x18.415	105	105	89	105	105	105			
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.
43	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		HGPI awaiting for purchase committee approval
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	286	304	300	300			
45	Juldah 100 MW Unit-1 (Accom)	HFO (ORPP)	8x13.45	100	100	70	100	80	100			
46	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	90	90	100	100			
47	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	102	51	102			
48	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0			
49	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	16	17	16	16			Environment issue
*	Malancha, Ctg.EPZ (United)	Gas	5x8.73+3x9.34			2	27	5	20			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	79	89	92	92			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36			
52	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	94	110	110	110			
53	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
54	Chattogram 116 MW PP (Anlima Ener)	HFO (IPP)	6x21.06	116	116	108	116	116	116			
Chattogram Zone Total				2442	2382	1324	1545	1486	1547	245	415	
55	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	80	80	80	80	55		Gas Shortage
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
56	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	23	23	20	23			
57	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1175	221	221	135	132	140	140			
58	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	305	305	310	330			
59	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	310	330	310	330			
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	25	40	55	55			
61	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+11*6	195	195	8	8	8	8	187		Gas shortage
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	123	140	135	135			
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	48	50	50			
65	Chandpur 150 MW CCPP	Gas (PDB)	1x106+1x57	163	163	139	0	0	0			
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	179	178	200	200			
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11			
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	33	33	33			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	52	52	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	16	21	21	21			
72	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+4x1.915+1x1.995	200	200	125	200	150	200			
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	80	98	50	100			
74	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	48	95	95	96			
75	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
**	Impopt (Tripura)	India		160	160	120	142	138	164			
Cumilla Zone Total				3094	3034	1880	2020	1948	2118	505	0	
76	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	85	107	107	107	95		Gas Shortage
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	21	21	21			
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	8	8	8	8			Dependable cap. :8MW
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	96	115	115	115			
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	179	190	170	190			
81	Sanshabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
82	Sutakali 50 MW Solar PP	Solar (IPP)	1x50	50	50	39	0	50	0			
83	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	22	23	22	22			
Mymensingh Zone Total				717	622	449	464	495	463	95	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12.10.21 (Yesterday)		13.10.21 (Today)		12.10.21 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
84	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	44	43	43		26	GT1 Load gear problem	
85	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	41	42	42	42		48		
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	47	50	50	50				
87	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
88	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	54	55	60	62	11		Gas Shortage	
90	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	155	160	160	160	170		Gas Shortage	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	77	81	81	81				
92	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	85	219	170	225				
93	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18	2		Gas Shortage	
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	9	10	10				
95	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	23	24	24	24				
96	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	295	341	341				
97	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	322	321	322	322				
98	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	320	320	320	320				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
Sylhet Zone Total					2422	2377	1666	1812	1815	1872	183	74	
100	Bheramara GTPP Unit-3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	305	280	300	300				
102	Fairpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	4	33	5	33			Line Overload	
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			Line Overload	
104	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	219	210	225	225				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	100	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	89	89	89	89				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	32	0	100			Line Overload	
**	Bheramara (HVDC)	India	1000	1000	1000	704	703	709	709				
Khulna Zone Total					2133	2129	1321	1447	1378	1596	0	0	
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			Line Overload	
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	21	34	33	33				
110	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	63	65	65	65		129	Gas Shortage	
111	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	17	17	17	17				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	460	622	622	622		622	Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	72	0	150				
114	Bhola 220MW CAPP (Nutan Bidyut BC)	Gas/HSD (IPP)	2x75+1x70	220	220	215	217	220	220				
Barishal Zone Total					2046	2046	776	1027	1067	1217	0	751	
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
116	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
117	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
118	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	169	200	200				
119	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	38	30	38				
120	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0				
121	Chapsainwabarjanj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	94	90	94				
122	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	38				
123	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	43	0	43				
124	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	33	17	35				
125	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
126	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	159	171	150	171	49		Gas Shortage	
127	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	197	196	200	210				
128	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	410	396	400	400				
129	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	22	22				
130	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
131	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
132	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113				
133	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	94	113	113	113				
134	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total					2179	2179	1060	1535	1454	1590	430	0	
135	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	81	80	82	82	5		Coal Shortage	
136	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.	
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	113	113	113	113				
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
141	Malpara, Tabala 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
Rangpur Zone Total					685	605	201	193	203	195	5	359	
Sub-total: Plants in operation					21435	20934	11973.0	13420	13158	14215	2395	2646	
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss					11523	12916	12663	13681					
(B) Plants under long term maintenance/ contract expired													
142	Kalpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
143	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
144	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
145	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
146	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
147	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
148	Khulna 115 MW PP (KPL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
Sub-Total: Plants under long term maintenance/ contract expired					596	0	0	0	0	0	0	0	
Gross Total					22031	20934	11973	13420	13158	14215	2395	2646	
(C) Actual data of 12.10.21 (Yesterday) Tuesday :													
01.	Max. Demand at eve. peak (Generation end)	: 13420.00 MW, at = 21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 12916.00 MW, at = 21:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 13420.00 MW, at = 21:00 hrs		Dhaka	4653	4653	0	Mymensingh	937	937	0		
04.	Minimum Generation (Generation end)	: 9960.00 MW, at = 8:00 hrs		Chattogram	1346	1346	0	Sylhet	581	581	0		
05.	Day-peak Generation (Generation end)	: 11973.00 MW, at = 12:00 hrs		Khulna	1599	1599	0	Barishal	406	406	0		
06.	Evening-peak Generation (Generation end)	: 13420.00 MW, at = 21:00 hrs		Rajshahi	1384	1384	0	Rangpur	730	730	0		
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 21:00 hrs		Cumilla	1280	1280	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 9867.00 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
a)	Gas limitation	: 2390 MW	13.	Fuel cost :	(a) Gas = 151022747 Taka	(c) Coal = 71988975 Taka							
d)	Coal supply Limitation	: 5 MW		(b) Oil = 901690689 Taka	Total = 1124702410 Taka								
b)	Low water level in Kaptai lake	: 0 MW											
c)	Plants under shut down/ maintenance	: 2646 MW	14.	Maximum Temperature in Dhaka was :	35.2° C								
10.	Total Energy (Generation + India Import)	: 291.63 MKWh		15.	Export through East-West interconnections :								
	By Gas = 147.733 MKWh	By Oil = 103.791 MKWh		At evening peak-hour	: -122 MW, at 21:00 hrs								
	By Coal = 15.690 MKWh	By Hydro = 3.735 MKWh		Maximum	: -196 MW, at 4:00 hrs								
	By Solar = 0.714 MKWh			Energy	: 1.2955 MKWh								
11.	Total Gas Supplied	: 1124.92 MMCFD											
(D) Forecast of 13.10.21 (Today) Wednesday :													
01.	Maximum Demand	: 13700 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	: 14215 MW (Generation end)	05.	Total Generation	: 297.72 MKWh								
03.	Maximum Shortage	: -515 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	36.6° C								

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faouzul Islam Shaker)
Deputy Secretary, Generation