

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month January, 2022		Day : Sunday				Date : 09.01.22						
Probable Maximum Demand :		9800 MW		Probable Maximum Generation :		11677 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 97.25 ft		Today = 97.12 ft		Rule Curve = 101.48 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.01.22 (Yesterday)		09.01.22 (Today)		08.01.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	200	250	180	180			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.	
6	Harijpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage	
7	Harijpur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	229	190	200	200	170	Gas Shortage	
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	180	180	180	180	270	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Harijpur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Gas Shortage	
11	Siddhirgonj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	305	305	0	0	0	0	305	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	42	55	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	0	37	35	40			
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102			
17	Narshingi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	19	19	19			
18	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	0	31	35	35			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	25	20	20			
20	Ruggan 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	33	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	51	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	78	105	105	105			
23	Kodda 150MW PP	HFO (BPD-RPCL)	9x17.06	149	149	16	150	149	149			
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	35	35			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	278	290	300	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	20	127	149	149			
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300			
28	Bramhangon 100 MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100			
29	Aurahi 100MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
30	Nababganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	25	35	35	35			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	78	104	104	104			
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
34	Manikganj 33MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	30	0	30	0			
	Kanchan Purbachal Power Generation	HFO (IPP)				0	55	55	55			On test
Dhaka Zone Total				5717	5560	1570	2091	2539	2564	1902	963	
35	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	80	73	80	80	157		Low water level & maint.
36	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
37	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
38	Raccan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25			
39	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
40	Patenga 50MW PP (Baraka)	HFO (IPP)	6x6.89	50	50	0	0	0	0			
41	Sikalbaha 105 MW PP (Baraka Sikalbah)	HFO (IPP)	6x18.415	105	105	41	105	105	105			
42	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
43	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting	
44	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	25	300	300	300			
45	Juldah 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	0	100	100	100			
46	Juldah 100 MW PP Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	90	90	90	90			
47	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	36	52	70			
48	Hafzazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98	Environment issue	
49	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21			
*	Malanchar, Cig EPZ (United)	Gas	5x8.73+3x9.34			4	11	5	10			
50	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	6	6	90	90			
51	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54			
52	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	74	110	110	110			
53	Juldah unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	100	100	100	100			
54	Chattogram 116 MW PP (Anilma Ener)	HFO (IPP)	6x21.06	116	116	116	116	116	116			
Chattogram Zone Total				2442	2382	634	1122	1273	1271	157	833	
55	a) Ashuganj TPP Unit- 3	Gas (APSCCL)	1 x 150	150	135	0	0	0	0	135	Gas Shortage	
	b) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage	
	c) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	80	80	80	80	54	Gas Shortage	
56	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	5	5	5	5	40	Gas Shortage	
57	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1x75	221	221	134	159	170	170	62	Gas Shortage	
58	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	280	275	300	300			
59	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	150	140	150	150	220	Gas Shortage	
60	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15x4	55	55	5	5	5	5			
61	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20x9.73+1x16	195	195	8	8	8	8	187	Gas Shortage	
62	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
63	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	148	150	150	150			
64	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	50	50			
65	Chandpur 150 MW CCGP	Gas (PDB)	1x106+1x57	163	163	138	125	137	137			
66	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	50	200	200			
67	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	22	22			
68	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
69	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	33	33	33			
70	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	20	52	52	52			
71	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	9	9	9			
72	Daukandi 200 MW PP (B. Trac)	HSD (IPP)	95x1.4+6x1.915+15x1.258	200	200	0	0	0	0	200		
73	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7x18.415+1x9.78	114	114	0	50	114	114			
74	Chowmuhani 113 MW	HFO (IPP)	12x9.78+1x3.1	113	113	82	113	113	113			
75	Bhiarob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
	Chandpur 115(Doreen)	HFO (IPP)				0	0	0	0			On Test
**	Import (Tripura)	India		160	160	66	101	138	163			
Cumilla Zone Total				3094	3034	1225	1505	1815	2040	827	0	
76	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	50	52	52	52	150		Gas Shortage
77	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
78	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. 8MW
79	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	18	112	115	115			
80	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	158	182	200	200			
81	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
82	Sutakahi 50 MW Solar PP	Solar (IPP)	1x50	50	50	45	0	50	0			
83	Tangail 22 MW PP(MPGL)	HFO (IPP)	4x6.7	22	22	22	22	22	22			
Mymensingh Zone Total				717	622	317	290	463	411	150	0	

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.01.22 (Yesterday)		09.01.22 (Today)		08.01.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
84	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	42	42		27	GT 1 Under maint.	
85	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	0	0		90	Under maint.	
86	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	45	48	51	51				
87	Kushara 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	163	163	163	163				
88	Hobgani 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11				
89	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	66	64	72	72				
90	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	78	81	81				
92	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	190	185	190	190				
93	Sylhet 20 MW GTPP	Gas (PDB)	1x20	20	20	18	18	18	18				
94	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
95	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	24	24	24				
96	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	295	330	330				
97	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
98	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	370	401	400	400				
99	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0				
Sylhet Zone Total				2422	2377	1312	1340	1392	1392	0	447		
100	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
101	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
102	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	35				
103	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	3	0	40				
104	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
105	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	50	100				
106	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	105	105	105				
107	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	100				
	Mongla Orion 100 MW Solar PP	Solar (IPP)				73	0	11	0				
**	Bheramara (HVDC)	India		1000	1000	655	702	479	479				
Khulna Zone Total				2133	2129	745	810	645	1079	410	0		
108	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
109	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	12	25	24	24				
110	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	91	91	91	91				
111	Bhola 95 MW PP (Agreko)	Gas (QRPP)	1,1x96	95	95	0	11	11	11				
112	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	250	480	620	620		764	Line Overload	
113	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150				
114	Bhola 220MW CCPP (Nutan Bidyut BL)	Gas/HSD (IPP)	2x75+1x70	220	220	160	220	200	220				
Barishal Zone Total				2046	2046	513	827	1056	1226	0	764		
115	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
116	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	50	50	50				
117	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
118	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	27	30	30				
119	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0				
120	Chapainawabganj 100 MW Peaking PI	HFO (PDB)	12x8.924	104	104	0	100	90	100				
121	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	32	32				
122	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	34	34				
123	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	0				
124	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
125	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
126	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	173	188	200	200				
127	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	389	378	400	400				
128	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22				
129	Ullaspara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
130	Natore 52 MW PP (Rajtanika)	HFO (IPP)	6x8.92	52	52	16	16	25	25				
131	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	35	113	113	113				
132	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	35	113	113	113				
133	Sirajgonj 5.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0				
Rajshahi Zone Total				2179	2179	677	1081	1326	1330	601	0		
134	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
135	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	199	200	200	75		Coal shortage	
136	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
137	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	72	112	113	113				
138	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
139	Majpara, Tatala 8 MW Solar PP (Sympa Powe)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
	Energypac Power Ventures Thakurgaon Ltd.	HFO (IPP)				11	0	0	0				
Rangpur Zone Total				655	605	287	311	321	313	160	85		
Sub-total: Plants in operation				21435	20934	7280.0	9477	10830	11626	4207	3092		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss						7132	9319	10659	11439				
(B) Plants under long term maintenance/ contract expired													
140	Katpali 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	36	51	51				Running for test purpose
141	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				Contract Expired
142	Siddhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired
143	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				Contract Expired on 12/11/2020
144	Bogura 20 MW PP (Energypima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 07/05/2021
145	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0				Contract Expired on 31/05/2021
146	Khulna 115 MW PP (KPCL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0				Contract Expired on 31/05/2021
Sub-Total: Plants under long term maintenance/ contract expired				596	0	0	36	51	51				
Gross Total				22031	20934	7280	9513	10881	11677	4207	3092		
(C) Actual data of 08.01.22 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	: 9513.00 MW, at = 19:30 hrs											
02.	Max. Demand at eve. peak (Sub-station end)	: 9319.00 MW, at = 19:30 hrs											
03.	Highest Generation (Generation end)	: 9513.00 MW, at = 19:30 hrs											
04.	Minimum Generation (Generation end)	: 5475.00 MW, at = 5:00 hrs											
05.	Day-peak Generation (Generation end)	: 7280.00 MW, at = 12:00 hrs											
06.	Evening-peak Generation (Generation end)	: 9513.00 MW, at = 19:30 hrs											
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:30 hrs											
08.	Minimum Generation Forecast up to 8:00 hrs.	: 6018.00 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
	a) Gas limitation	: 3890 MW											
	d) Coal supply Limitation	: 160 MW											
	b) Low water level in Kaplai lake	: 157 MW											
	c) Plants under shut down/ maintenance	: 3092 MW											
10.	Total Energy (Generation + India Import)	: 176.97 MKWh											
	By Gas = 94.322 MKWh	By Oil = 50.674 MKWh											
	By Coal = 13.038 MKWh	By Hydro = 1.840 MKWh											
	By Solar = 1.143 MKWh												
11.	Total Gas Supplied	: 719.45 MMCFD											
			12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
				Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
				Dhaka	3495	3495	0	Mymensingh	788	788	0		
				Chattogram	998	998	0	Sylhet	348	348	0		
				Khulna	1117	1117	0	Barishal	254	254	0		
				Rajshahi	924	924	0	Rangpur	610	610	0		
				Cumilla	785	785	0						
				Total	9319	9319	0						
			13.	Fuel cost :									
				(a) Gas =	95476309 Taka	(c) Coal =	62239920 Taka						
				(b) Oil =	345885859 Taka	Total =	503602088 Taka						
			14.	Maximum Temperature in Dhaka was :			28.5° C						
			15.	Export through East-West interconnections :									
				At evening peak-hour			-68 MW, at 19:30 hrs						
				Maximum			-176 MW, at 20:00 hrs						