

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel.: 9564667, 9551095

Month January, 2022				Day : Monday				Date : 24.01.22				
Probable Maximum Demand : 9800 MW				Probable Maximum Generation : 12107 MW				Rule Curve = 98.60 ft				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 95.09 ft				Today = 94.88 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.01.22 (Yesterday)		24.01.22 (Today)		23.01.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	200	200	200	200			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365		Gas Shortage
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.
6	Harijpur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage
7	Harijpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	160	120	180	180	240		Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	180	150	200	200	300		Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Harijpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412		Gas Shortage
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	40	40	55	55			
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	36	60	60	60			
16	Gagragar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102			
17	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22			
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+6x3.73	80	80	33	34	35	35			
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	22	22			
20	Ruggan 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33			
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	43	50	51	51			
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105			
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	150	150	150	150			
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35			
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	273	281	300	300			
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149			
27	Keeraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	125	205	200	300			
28	Beranangan 100 MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	100	100	100	100			
29	Auraha 100MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	100	100	100	100			
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55			
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104			
33	Manikganj 162MW PPI(MPGL)	HFO (IPP)	9x18	162	162	162	162	162	162			
34	Manikganj 33MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	4	0	30	0			
35	Kanchan Purbachal Power Generation	HFO (IPP)		55	55	55	55	55	55			
36	Katpoti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	48	48	51	51			
Dhaka Zone Total				5853	5696	2387	2432	2611	2681	2397	598	
37	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	76	78	78	154		Low water level & maint.
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
40	Racoon 25 MW PP	HFO (RPCL)	3x8.9	25	25	3	17	25	25			
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
42	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.89	50	50	0	26	50	50			
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	101	105	105	105			
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		HQPI awaiting
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	80	130	260	260			
47	Julda 100 MW Unit-1 (Accom)	HFO (QRPP)	8x13.45	100	100	20	80	100	100			
48	Julda 100 MW Unit-3 (Accom)	HFO (IPP)	8x13.45	100	100	90	90	90	90			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51			
50	Hafzazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98		Environment issue
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19			
	* Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			4	10	15	15			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	75	90	90	90			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	42	54	54	54			
54	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	110	110	110	110			
55	Julda unit-2 (Accom)	HFO (IPP)	8x13.6	100	100	90	100	100	100			
56	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	116	116	116	116			
Chattogram Zone Total				2442	2382	819	1074	1288	1263	514	473	
57	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage
	b) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	100	100	100	100	34		Gas Shortage
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	29	29	30	30			
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+175	221	221	197	191	210	210			
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	325	300	360	360	60		Gas Shortage
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	255	260	265	260	100		Gas Shortage
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	53	56	55	55			
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	26	26	26	26	169		Gas Shortage
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	51	51	51	51			
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	147	150	150	150			
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	50	50	48	50			
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	48	50	80	115		Gas Shortage
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	4	200	200			
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21			
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	8	11	11			
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	15	17	33	33			
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	38	52	52	52			
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	6	9	9			
74	Daukandi 200 MW PP (B. Trac)	HSD (IPP)	99x1.4+8x1.915+15x1.999	200	200	0	50	100	200			
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	114	114			
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	116	113	113	113			
77	Bhiarob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
	Chandpur 115(Doreen)	HFO (IPP)				0	0	0	0			On Test
**	Impopr (Tripura)	India		160	160	0	93	138	163			
Cumilla Zone Total				2944	2899	1456	1642	2153	2305	607	0	
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	33	45	50	50	157		Gas Shortage
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. 8MW
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	97	90	115	115			
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	200	200	200	200			
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	0	0	1.6	0			
84	Suitakali 50 MW Solar PP	Solar (IPP)	1x50	50	0	0	0	50	0			
85	Tangail 22 MW PP(PGGL)	HFO (IPP)	4x6.7	22	22	22	22	22	22			
Mymensingh Zone Total				717	622	374	229	461	409	157	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	23.01.22 (Yesterday)		24.01.22 (Today)		23.01.22 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:		Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	Gas/Water/Coal limitation MW	Machines shut down (MW)				
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32-1x33	97	70	43	43	42	43			GT 1 Under maint.		
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35-1x35	104	90	30	30	30	30			GT-4 Under maint.		
88	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	53	53	51	51					
89	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	130	130	130	130					
90	Hobganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	66	68	70	70					
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	160	160	160	160	170		Gas Shortage		
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	78	80	81					
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	177	177	180	180	54		Gas Shortage		
95	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage		
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	0	10	10	10		Gas Shortage		
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage		
98	Bibianna-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	300	330	330					
99	Bibianna-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0					
100	Bibianna South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	260	260	260	260			123 ST Under maint.		
101	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work		
Sylhet Zone Total					2422	2377	1334	1326	1388	1390	263	27		
102	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278-1 x 132	410	410	0	0	0	0	410		Gas Shortage		
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	29	0	35					
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	17	0	40					
106	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 159+1x75	230	230	0	0	0	220					
107	Neopara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.516	100	100	29	93	80	100					
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	90	90	105	105					
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100					
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	34	0	50	0					
**	Bheramara (HVDC)	India		1000	1000	717	716	730	730					
Khulna Zone Total					2233	2229	870	945	1015	1330	410	0		
111	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110					
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	18	25	25	25					
113	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	90	91	91	91					
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	11	11					
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	280	370	620	620			874 Line Overload		
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150					
117	Bhola 220MW CAPP (Nutan Bidyut BC Gas/HSD)	HSD (IPP)	2x75+1x70	220	220	220	220	220	220					
Barishal Zone Total					2046	2046	619	717	1077	1227	0	874		
118	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	50	50	50	50					
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	55	120	200	200					
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	53	53	53					
122	Chapaiwanawaganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	33	100	90	100					
123	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	40	40					
124	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50					
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	0			50 Under maint.		
126	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage		
127	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage		
128	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	120	112	120	120	108		Gas Shortage		
129	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	157	125	235	250	289		Gas Shortage		
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	14	21	22	22					
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11					
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	35	52	52	52					
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113					
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113					
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0					
Rajshahi Zone Total					2129	2129	698	907	1155	1174	998	50		
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage		
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	200	200	200	200	200	74		Coal shortage		
138	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	15			Condenser mode		
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	108	113	113	113					
140	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode		
141	Majpara, Talula 8 MW Solar PP (Sympha Power Energypac Power Venture Thakurgonj Ltd)	Solar (IPP)	1 x 8	8	8	1	0	8	0					
Rangpur Zone Total					685	605	326	313	321	328	159	85		
Sub-total: Plants in operation					21471	20985	8883.0	9735	11469	12107	5505	2107		
Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss							8680	9512	11206	11830				
(B) Plants under long term maintenance/contract expired														
142	Bosila 106MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage		
143	Idherganj 100 PP (Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired		
144	Madanganj 102 PP (Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0					
145	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
146	Meghnaghat 100 MW (IEL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021		
147	Khulna 115 MW PP (KPLC-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021		
148	Annura 50 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0			Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/contract expired					595	0	0	0	0					
Gross Total					22066	21035	8883	9735	11469	12107	5505	2107		
(C) Actual data of 23.01.22 (Yesterday) Sunday :														
01.	Max. Demand at eve. peak (Generation end)	: 9735.00 MW, at = 19:00 hrs												
02.	Max. Demand at eve. peak (Sub-station end)	: 9512.00 MW, at = 19:00 hrs												
03.	Highest Generation (Generation end)	: 9735.00 MW, at = 19:00 hrs												
04.	Minimum Generation (Generation end)	: 6205.00 MW, at = 4:00 hrs												
05.	Day-peak Generation (Generation end)	: 8883.00 MW, at = 12:00 hrs												
06.	Evening-peak Generation (Generation end)	: 9735.00 MW, at = 19:00 hrs												
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 19:00 hrs												
08.	Minimum Generation Forecast up to 8:00 hrs.	: 5596.00 MW, at = 5:00 hrs												
09.	Generation shortfall at evening peak due to :													
a)	Gas Limitation	: 5192 MW												
d)	Coal supply Limitation	: 159 MW												
b)	Low water level in Kaptai lake	: 154 MW												
c)	Plants under shut down/ maintenance	: 2107 MW												
10.	Total Energy (Generation + India Import)	: 196.67 MKWh												
	By Gas = 91.456 MKWh	By Oil = 71.389 MKWh												
	By Coal = 13.175 MKWh	By Hydro = 1.765 MKWh												
	By Solar= 0.458 MKWh													
11.	Total Gas Supplied	: 756.69 MMCFD												
			12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
				Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
				Dhaka	3587	3587	0	Mymensingh	824	824	0			
				Chattoagram	998	998	0	Sylhet	336	336	0			
				Khulna	1090	1090	0	Barishal	243	243	0			
				Rajshahi	976	976	0	Rangpur	678	678	0			
				Cumilla	780	780	0							
				Total								9512	9512	0
			13.	Fuel cost :	(a) Gas = 94009074 Taka	(c) Coal = 62865626 Taka								
					(b) Oil = 535864774 Taka	Total = 692739474 Taka								
			14.	Maximum Temperature in Dhaka was :	24.4° C									
			15.	Export through East-West interconnections :										
				At evening peak-hour	: -306 MW, at 19:00 hrs									
				Maximum	: -364 MW, at 18:30 hrs									
				Energy	: 1.012 MKWh									
(D) Forecast of 24.01.22 (Today) Monday :														
01.	Maximum Demand	: 9800 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)									
02.	Maximum Generation	: 12107 MW (Generation end)	05.	Total Generation	: 197.99 MKWh									
03.	Maximum Shortage	: -2307 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	23.5° C									

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Faoual Islam Shaker)
Deputy Secretary, Generation