

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel - 9564667, 9551095

Month February, 2022		Day : Sunday				Date : 06.02.22							
Probable Maximum Demand :		10000 MW				Probable Maximum Generation : 12677 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 93.21 ft		Today = 93.09 ft		Rule Curve = 96.30 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.02.22 (Yesterday)		06.02.22 (Today)		05.02.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for :				
						Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
<b>(A) Plants in operation:</b>													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	150	150	150			Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365		Gas Shortage	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	100	100	100				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Under maint.	
6	Harijpur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20		Gas Shortage	
7	Harijpur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	334	344	360	360	16		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	200	200	200	200	250		Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Harijpur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412		Gas Shortage	
11	Siddhirgonj 2120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage	
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	40	40	40				
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	10	42	60	60				
16	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	64	102	102	102				
17	Narshingi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	16	16	22				
18	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+1x8.73	80	80	34	31	35	35				
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	20	25				
20	Rugganji 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	6	0	15	33				
21	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	34	51	51				
22	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	105	105				
23	Kodda 150MW PP	HFO (BPDB-RPCL)	9x17.06	149	149	16	0	150	150				
24	Kamalghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	54	54	54	54				
25	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	185	300	300	300				
26	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	62	134	149	149				
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	200	300				
28	Branhanganj 100 MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
29	Aurath 100MW PP (Agrako)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	100	100				
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	17	35	55	55				
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55				
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104				
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	126	144	162	162				
34	Manikganj 33MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	0	0	30	0				
35	Kanchan Purbachal Power Generation	HFO (IPP)		55	55	55	55	55	55				
36	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	0	51	51				
<b>Dhaka Zone Total</b>				<b>5853</b>	<b>5696</b>	<b>1476</b>	<b>2070</b>	<b>2819</b>	<b>2918</b>	<b>2015</b>	<b>598</b>		
37	Kamaphul Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46	184		Low water level & maint.	
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
39	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	3	0	5	0				
40	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	17	17				
41	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0				
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	25	40	40	40				
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	105	105	105				
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
45	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225		HQPI awaiting	
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	200	283	260	300				
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	0	100	100				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	10	90	90	90				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51				
50	Hafazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98		Environment issue	
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	18	18	18				
	* Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	10	5	10				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	77	96	97	97				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	54	54				
54	Kamaphul Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	81	110	110				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	10	50	100	100				
56	Chattogram 116 MW PP (Anima Ener)	HFO (IPP)	6x21.06	116	116	116	105	116	116				
<b>Chattogram Zone Total</b>				<b>2442</b>	<b>2382</b>	<b>555</b>	<b>1009</b>	<b>1234</b>	<b>1254</b>	<b>544</b>	<b>473</b>		
57	a) Ashuganj TPP Unit- 4	Gas (APSCCL)	1 x 150	150	129	0	0	0	0	129		Gas Shortage	
	b) Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	26	29	30	30	16		Gas Shortage	
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1x75	221	221	198	142	220	220				
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	100	100	360	360	260		Gas Shortage	
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	0	240	150	260	120		Gas Shortage	
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	53	56	56	56				
63	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	102	8	8	8	187		Gas Shortage	
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'9.34	51	51	51	51	51	51				
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	137	10	150	150				
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	50	50				
67	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	137	134	135	135				
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	100	200	200				
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21				
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	25	25	25				
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	52	52	52	52				
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	8	9	9				
74	Daukandi 200 MW PP (B. Trac)	HSD (IPP)	95x1.4+6x1.915+15x1.056	200	200	0	0	100	200				
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	51	114	114	114				
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	8	107	113	113				
77	Bhiarob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	13	17	17				
	Chandpur 115(Doreen)	HFO (IPP)				0	0	0	0			On Test	
**	Impopr (Tripura)	India		160	160	80	104	138	163				
<b>Cumilla Zone Total</b>				<b>2944</b>	<b>2899</b>	<b>1084</b>	<b>1322</b>	<b>2010</b>	<b>2245</b>	<b>846</b>	<b>0</b>		
78	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	158	134	135	135	68		Gas Shortage	
79	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22				
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	8	0	0	0	0			Dependable cap. 8MW	
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	8	80	110	110				
82	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	110	191	200	200				
83	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.02.22 (Yesterday)		06.02.22 (Today)		05.02.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)		
86	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32-1x33	97	70	30	30	30	30		40	GT 1 Under main.
87	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	32	30	30			GT-4 Under main.
88	Fenchugonj 51 MW PP (Barakatalah)	Gas (RPP)	19x2.90	51	51	45	51	51	51			
89	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53		Gas Shortage
90	Hobganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11			
91	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	66	69	70	70			
92	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	231	162	162	162	168		Gas Shortage
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	56	75	80			
94	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	164	177	180	180	54		Gas Shortage
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage
98	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	300	330	330			
99	Bibiyan-II 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0			
100	Bibiyan South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	390	400	400	400			
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work
<b>Sylhet Zone Total</b>					<b>2422</b>	<b>2377</b>	<b>1367</b>	<b>1424</b>	<b>1493</b>	<b>304</b>	<b>40</b>	
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
103	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278-1 x 132	410	410	0	0	0	0	410		Gas Shortage
104	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	35			
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			
106	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 159+1x75	230	230	0	0	0	220			
107	Neopara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.516	100	100	0	0	80	100			
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	63	105	105	105			
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100			
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	87	0	50	0			
**	Bheramara (HVDC)	India		1000	1000	736	735	752	752			
<b>Khulna Zone Total</b>					<b>2233</b>	<b>2229</b>	<b>886</b>	<b>840</b>	<b>1037</b>	<b>1352</b>	<b>410</b>	<b>0</b>
111	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	17	22	20	24			
113	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	73	91	90	92	103		Gas Shortage
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	76	76			
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	280	380	620	620		864	Line Overload
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	150			
117	Bhola 220MW CAPP (Nutan Bidyut BC Gas/HSD)	Gas/HSD (IPP)	2x75+1x70	220	220	188	189	220	220			
<b>Barishal Zone Total</b>					<b>2046</b>	<b>2046</b>	<b>969</b>	<b>693</b>	<b>1136</b>	<b>1292</b>	<b>103</b>	<b>864</b>
118	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	34	34			
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200			
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	5	0	50	50			
122	Chapaiwawaganj 100 MW Peaking PI	HFO (PDB)	12x8.524	104	104	50	100	90	100			
123	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	40			
124	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50			
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	27	30	31			
126	Siraggonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage
127	Siraggonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220		Gas Shortage
128	Siraggonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	120	127	140	140	93		Gas Shortage
129	Siraggonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	386	361	350	360	53		Gas Shortage
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	22	22	22	22			
131	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	11	11			
132	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	52	52	52	52			
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6*18.55	113	113	113	113	113	113			
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	113	113	113	113			
135	Siraggonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0			
<b>Rajshahi Zone Total</b>					<b>2129</b>	<b>2129</b>	<b>866</b>	<b>954</b>	<b>1261</b>	<b>1316</b>	<b>747</b>	<b>0</b>
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	199	200	200	75		Coal shortage
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	113	113	113	113			
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode
141	Majpara, Talula 8 MW Solar PP (Sympa Power Energypac Power Venture Thakurgonj Ltd)	Solar (IPP)	1 x 8	8	8	1	0	8	0			
<b>Rangpur Zone Total</b>					<b>685</b>	<b>605</b>	<b>314</b>	<b>312</b>	<b>321</b>	<b>313</b>	<b>160</b>	<b>85</b>
<b>Sub-total: Plants in operation</b>					<b>21471</b>	<b>20985</b>	<b>7466.0</b>	<b>9073</b>	<b>11852</b>	<b>12677</b>	<b>5197</b>	<b>2060</b>
<b>Available Power at Sub-station end excluding P/S auxiliary use and Transmission loss</b>					<b>7431</b>	<b>9031</b>	<b>11797</b>	<b>12618</b>				
<b>(B) Plants under long term maintenance/contract expired</b>												
142	Bosila 106MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage
143	108Riganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0			
145	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
146	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021
147	Khulna 115 MW PP (KPLC-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021
148	Annura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	50	0	0	0	0			Contract Expired on 11/01/2022
<b>Sub-Total: Plants under long term maintenance/contract expired</b>					<b>595</b>	<b>50</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>Gross Total</b>					<b>22066</b>	<b>21035</b>	<b>7466</b>	<b>9073</b>	<b>11852</b>	<b>12677</b>	<b>5197</b>	<b>2060</b>
<b>(C) Actual data of 05.02.22 (Yesterday) Saturday :</b>												
01.	Max. Demand at eve. peak (Generation end)	: 9073.00 MW, at = 20:00 hrs	12.	<b>Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :</b>								
02.	Max. Demand at eve. peak (Sub-station end)	: 9031.00 MW, at = 20:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 9073.00 MW, at = 20:00 hrs	Dhaka	3347	3347	0	Mymensingh	772	772	0		
04.	Minimum Generation (Generation end)	: 4663.00 MW, at = 5:00 hrs	Chattoagram	1043	1043	0	Sylhet	336	336	0		
05.	Day-peak Generation (Generation end)	: 7466.00 MW, at = 12:00 hrs	Khulna	1060	1060	0	Barishal	273	273	0		
06.	Evening-peak Generation (Generation end)	: 9073.00 MW, at = 20:00 hrs	Rajshahi	883	883	0	Rangpur	576	576	0		
07.	Evening Peak Load-shed (Sub-station end)	: 0.00 MW, at = 20:00 hrs	Cumilla	741	741	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 5797.00 MW, at = 5:00 hrs					<b>Total</b>	<b>9031</b>	<b>9031</b>	<b>0</b>		
09.	Generation shortfall at evening peak due to :											
a)	Gas limitation	: 4853 MW	13.	Fuel cost :	(a) Gas = 91393997 Taka	(c) Coal = 61578781 Taka						
d)	Coal supply Limitation	: 160 MW		(b) Oil = 305540800 Taka	Total = 458513578 Taka							
b)	Low water level in Kaptai lake	: 184 MW										
c)	Plants under shut down/ maintenance	: 2060 MW	14.	Maximum Temperature in Dhaka was :	24.0° C							
10.	Total Energy (Generation + India Import)	: 170.28 MKWh	15.	Export through East-West interconnections :								
	By Gas = 92.561 MKWh	By Oil = 45.007 MKWh		At evening peak-hour :	-76 MW, at 20:00 hrs							
	By Coal = 12.867 MKWh	By Hydro = 1.094 MKWh		Maximum :	-76 MW, at 20:00 hrs							
	By Solar= 1.029 MKWh		11.	Energy :	0.037 MKWh							
11.	Total Gas Supplied	: 749.66 MMCFD										
<b>(D) Forecast of 06.02.22 (Today) Sunday :</b>												
01.	Maximum Demand	: 10000 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	: 12677 MW (Generation end)	05.	Total Generation	: 187.67 MKWh							
03.	Maximum Shortage	: -2677 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	22.3° C							

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)  
Deputy Secretary, Generation