

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month February, 2022										Day: Monday		Date: 07.02.22			
Probable Maximum Demand: 9700 MW				Probable Maximum Generation: 12267 MW				Rule Curve = 96.16 ft.							
Water Level of Kaptai Lake at 06:00 AM										Yesterday = 93.09 ft.		Today = 92.97 ft.		Rule Curve = 96.16 ft.	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.02.22 (Yesterday)		07.02.22 (Today)		06.02.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	Probable start-up date			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for:						
					Day	Evening	Day	Evening	Gas/water/Coal limitation (MW)	Machines shut down (MW)			Description/ Remarks		
(A) Plants in operation:															
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work				
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	200	200	200	200						
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage				
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Gas Shortage				
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	53	0	0	0	108	Gas Shortage				
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Under maint.				
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0	20	Gas Shortage				
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	344	176	0	0						
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	200	200	200	200	250	Gas Shortage				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling				
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Gas Shortage				
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage				
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage			
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	38	40	40						
15	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	100	12	47	60	60						
16	Gangagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.524	102	102	102	102	102	102						
17	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	0	22	22						
18	Summit Power (Madhabd+Ashulia)	Gas (SIPP, REB)	6x3.67+8x7.3	80	80	31	34	35	35						
19	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.7	33	33	17	25	25	25						
20	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.7	33	33	0	25	33	33						
21	Gasipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	51	51	51						
22	Gasipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	90	105	100	100						
23	Kooda 150MW PP	HFO (B/PDB-RPCL)	9x17.06	149	149	20	82	150	150						
24	Kamalghat 54 MW PP (Banso Energy)	HFO (IPP)	3x18.69	54	54	17	54	54	54						
25	Kooda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	278	294	300	300						
26	Kooda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	71	149	149	149						
27	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	124	200	300						
28	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100						
29	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	100	100	100						
30	Nabaganj 55 MW PP (Southern powe)	HFO (IPP)	3x19.3	55	55	17	35	55	55						
31	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	55	55	55	55						
32	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	104	104	104	104						
33	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	90	154	162	162						
34	Manikganj 35MW Solar PP (Inspectra)	Solar (IPP)	1x35	35	35	36	0	30	0						
35	Kanchan Purbachal Power Generation	HFO (IPP)	55	55	55	55	55	55	55						
36	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	51	0	51	51	51						
Dhaka Zone Total				5853	5696	1846	2309	2433	2503	2107	598				
37	Kamaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46	184	Low water level & maint.				
38	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage				
39	Kapali 7 MW Solar PP	Solar (PDB)	7	7	5	0	5	0	0						
40	Razzan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	14	17	17						
41	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	20	0	20	0						
42	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	37	40	40	40						
43	Sikalbaha 105 MW PP (Baraka Sikalab)	HFO (IPP)	6x18.415	105	105	19	87	105	105						
44	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.				
45	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	225	HGPI awaiting				
46	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	210	283	260	300						
47	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	100	100	100						
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	76	90	90	90						
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51						
50	Halhazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	0	98	Environment Issue				
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18						
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	22	10	25						
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	67	90	97	97						
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	9	17	54	54						
54	Kamaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	18	100	110	110						
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	20	50	100	100						
56	Chattogram 116 MW PP (Anlima Ene)	HFO (IPP)	6x21.06	116	116	116	116	116	116						
Chattogram Zone Total				2442	2382	663	1024	1239	1269	544	473				
57	a) Ashuganj TPP Unit-4	Gas (APSCL)	1 x 150	150	129	0	0	0	0	129	Gas Shortage				
	b) Ashuganj TPP Unit-5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage				
58	Ashuganj 50 MW PP	Gas (APSCL)	14x3.668	53	45	29	29	30	30	16	Gas Shortage				
59	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1175	221	221	178	184	220	220						
60	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	320	265	360	360	95	Gas Shortage				
61	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	110	20	150	260	340	Gas Shortage				
62	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	56	56	56	56						
63	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas Shortage				
64	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	29	51	51	51						
65	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	130	150	150						
66	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	50	50	50						
67	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	137	136	135	135						
68	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	17	200	200						
69	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	18	21	21						
70	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11						
71	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	25	25	25	25						
72	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	25	46	52	52						
73	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	9	9						
74	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+66x1.515+15x1.058	200	200	0	0	100	200						
75	Feni 114 MW Power Plant(Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	114	114	114						
76	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	8	108	113	113						
77	Bharob 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17						
	Chandpur 115(Doreen)	HFO (IPP)				106	120	0	0						
**	Impoort (Tijura)	India		160	160	92	100	138	164			On Test			
Cumilla Zone Total				2944	2899	1189	1511	2010	2246	901	0				
78	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	87	96	135	135	106	Gas Shortage				
79	Tangal 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22						
80	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.524	95	8	0	0	0	0			Dependable cap.: 8MW			
81	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	66	80	110	110						
82	Myensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	194	194	200	200						
83	Sarisahabi 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0						
84	Sutahaili 50 MW Solar PP	Solar (IPP)	1x50	50	50	31	0	50	0						
85	Tangal 22 MW PP(PPL)	HFO (IPP)	4x6.7	22	22	22	22	22	22						
Myensingh Zone Total				717	622	423	414	541	489	106	0				

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.02.22 (Yesterday)		07.02.22 (Today)		06.02.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/water/Coal limitation MW	Machines shut down (MW)			
86	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
87	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	32	32	30	30		58	GT-4 Under maint.	
88	Fenchugonj 51 MW PP (Barakattullah)	Gas (RPP)	19x2.90	51	51	48	50	51	51				
89	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	110	110	110	110	53		Gas Shortage	
90	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
91	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	67	68	70	70				
92	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	161	161	162	162	169		Gas Shortage	
93	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	53	53	75	80				
94	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	177	177	180	180	54		Gas Shortage	
95	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	0	18	18	20		Gas Shortage	
96	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
97	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x8.34	25	25	16	16	16	16	9		Gas Shortage	
98	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	300	330	330				
99	Bibyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0				
100	Bibyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
101	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			Under project work	
Sylhet Zone Total				2422	2377	1414	1418	1493	1498	305	98		
102	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
103	Bheramara 410 MW CCPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage	
104	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	34	0	35				
105	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	3	0	40				
106	Khulna 225 MW CCPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	220				
107	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	80	100				
108	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	105	105	105	105				
109	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	50	100				
110	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	91	0	50	0				
**	Bheramara (HVDC)	India		1000	1000	726	725	741	741				
Khulna Zone Total				2233	2229	922	867	1026	1341	410	0		
111	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
112	Bhola 33 MW PP (Venture)	Gas (RPP)	1x34.50	33	33	15	20	20	24				
113	Bhola 225 MW CCPP	Gas (PDB)	2x83+1x68	194	194	92	91	90	92	103		Gas Shortage	
114	Bhola 95 MW PP (Aggreko)	Gas (QRPP)	1.1x96	95	95	11	11	76	76				
115	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	290	390	620	620			854	
116	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	150	150				
117	Bhola 220MW CCPP (Nutan Bidyt BE)	Gas/HSD (IPP)	2x75+1x70	220	220	150	218	220	220				
Barishal Zone Total				2046	2046	558	730	1136	1292	103	854		
118	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
119	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	25	25	34	34				
120	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	200	200				
121	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	36	51	50	50				
122	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.524	104	104	50	100	90	100				
123	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	12	40	0	40				
124	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	50	50				
125	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	30	31				
126	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
127	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
128	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	116	123	140	140	97		Gas Shortage	
129	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	206	188	350	360	226		Gas Shortage	
130	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	14	20	22	22				
131	Ullaspara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	11	11				
132	Natore 52 MW PP (Rajjanka)	HFO (IPP)	6x8.92	52	52	43	52	52	52				
133	Bagura 113 MW PP (Confidence) Unit-1	HFO (IPP)	6'18.55	113	113	80	113	113	113				
134	Bagura 113 MW PP (Confidence) Unit-2	HFO (IPP)	6x18.55	113	113	75	112	113	113				
135	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Rajshahi Zone Total				2129	2129	669	862	1261	1316	924	0		
136	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
137	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal shortage	
138	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
139	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	113	113	113	113				
140	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0			Condenser mode	
141	Maipara, Tabula 8 MW Solar PP (Sympa Power Energypac Power Venture Thakurgaon Ltd.)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
Rangpur Zone Total				695	605	339	313	321	313	159	85		
Sub-total: Plants in operation				21471	20985	8023.0	9448	11460	12267	5559	2108		
Available Power at Sub-station end excluding PIS auxiliary use and Transmission loss				7974	9390	11389	12192						
(B) Plants under long term maintenance/ contract expired													
142	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			Forced Outage	
143	Sidhirganj 100 PP(Dutch Bangla)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired	
144	Madanganj 102 PP(Summit)	HFO (QRPP)	6x17	102	0	0	0	0	0				
145	Bogra 20 MW PP (Energyprima)	Gas (RPP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
146	Meghnaghat 100 MW(EL)	HFO (QRPP)	12x8.9	100	0	0	0	0	0			Contract Expired on 07/05/2021	
147	Khulna 115 MW PP (KPL-2)	HFO (QRPP)	7x17	115	0	0	0	0	0			Contract Expired on 31/05/2021	
148	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.9	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired				595	50	0	0	0	0				
Gross Total				22066	21035	8023	9448	11460	12267	5559	2108		
(C) Actual data of 06.02.22 (Yesterday) Sunday :													
01.	Max. Demand at eve. peak (Generation end)			9448.00	MW, at = 19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)			9390.00	MW, at = 19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)			9448.00	MW, at = 19:00 hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)			5797.00	MW, at = 5:00 hrs	Dhaka	3565	3565	0	Mymensingh	782	782	0
05.	Day-peak Generation (Generation end)			8023.00	MW, at = 12:00 hrs	Chattogram	1095	1095	0	Sylhet	330	330	0
06.	Evening-peak Generation (Generation end)			9448.00	MW, at = 19:00 hrs	Khulna	1104	1104	0	Barishal	224	224	0
07.	Evening Peak Load-shed (Sub-station end)			0.00	MW, at = 19:00 hrs	Rajshahi	913	913	0	Rangpur	636	636	0
08.	Minimum Generation Forecast up to 8:00 hrs.			5871.00	MW, at = 5:00 hrs	Cumilla	741	741	0				
09.	Generation shortfall at evening peak due to :					Total				Total			
	a) Gas limitation			5216	MW								
	d) Coal supply Limitation			159	MW								
	b) Low water level in Kaptai lake			184	MW								
	c) Plants under shut down/ maintenance			2108	MW								
10.	Total Energy (Generation + India Import)			182.73	MKWh								
	By Gas =	94.369	MKWh	By Oil =	53.463	MKWh							
	By Coal =	13.308	MKWh	By Hydro =	1.053	MKWh							
	By Solar =	1.347	MKWh										
11.	Total Gas Supplied			728.88	MMCFD								
(D) Forecast of 07.02.22 (Today) Monday :													
01.	Maximum Demand			9700	MW (Generation end)	04.	Maximum Load-shed		0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation			12267	MW (Generation end)	05.	Total Generation		187.60	MKWh			
03.	Maximum Shortage			-2567	MW (Generation end)	06.	Probable Max. Temperature in Dhaka		23.1°	C			

* Captive Power ** Imported Power

#Remarks: Highest Generation 13792 MW on 27-04-2021 at 20:00

(Md. Helalur Rahman)
Deputy Secretary, Generation