

QF-LDC-08
Page -1

Page -1

5-Apr-22

Cost of the Consumed Fuel (PDB+Pvt) :	Gas :	Tk115,477,897		
:	Coal :	Tk103,131,667	Oil : Tk1,020,389,931	Total : Tk1,238,999,495

Area	Yesterday		Estimated Demand (S/S end)	Today	
	MW			Estimated Shedding (S/S end)	Rates of Shedding (On Estimated Demand)
Dhaka	0	0:00	5494	44	0%
Chittagong Area	0	0:00	1880	30	0%
Khulna Area	0	0:00	1686	105	0%
Rajshahi Area	0	0:00	1524	124	0%
Cumilla Area	0	0:00	1377	27	0%
Mymensingh Area	0	0:00	1111	211	0%
Sylhet Area	0	0:00	607	7	0%
Barisal Area	0	0:00	286	6	0%
Rangpur Area	0	0:00	857	7	0%
Total	0		14822	561	

Planned Shut- Down	Forced Shut-Down 1) Barapukuria ST: Unit-2 2) Ghorasat-3,5 3) Ashuganj-4,5 4) Baghabari-71,100 MW 5) Raozan unit- 1 6) Siddhirganj 210 MW . 7) Siddhirganj 335 MW CAPP	
--------------------	--	--

<p>a) Cumilla(N) 132/33 kV T-3,T-4 transformer tripped at 10:10 showing O/C relay and were switched on at 10:29.</p> <p>b) Keraniganj 230/132 kV ATR-2 transformer was under shut down from 10:02 to 15:40 for DFDR connection.</p> <p>c) Siddhirganj-Siddhirganj peaking 132 kV Ckt was under shut down from 10:53 to 15:32 for maintenance by P/S end.</p> <p>d) Barisal-Bhandaria 132 kV Ckt was under shut down from 11:22 to 17:13 for C/M at Bhandaria end.</p> <p>e) Ashuganj-Siraganj 230 kV Ckt-2 tripped at 11:33 showing dist RST,SOTF and was switched on at 12:12.</p> <p>f) Siddhirganj-Haripur 230 kV Ckt-2 was under shut down from 13:21 to 14:54 for C/M by Haripur end.</p> <p>g) Ashuganj-Siraganj 230 kV Ckt-1 tripped at 17:18 showing dist RST from both end and was switched on at 17:51.</p> <p>h) Ghorasal #07 ST was under shut down 21:11 due to all boiler control card problem and was sync at 03:10(05-04-22).</p> <p>i) Naogaon 132/33 kV T-3 transformer under 33 kV bus section was shut down from 20:35 to 21:27 due to red hot maintenance at 33 kV Santahar feeder.</p> <p>j) Meghnaghat Summit tripped at 15:27 due to low gas pressure.</p> <p>k) Tongi-Kabirpur 132 kV Ckt-2 was under shut down from 06:18 to 07:21(05-04-22) for C/M .</p> <p>l) Aminbazar-Mirpur 132 kV Ckt-1 was under shut down from 06:34 to 12:40(05-04-22) for C/M .</p> <p>m) Madunaghat 132/33 kV T-1 transformer tripped at 06:45 from 33 kV side showing O/C,IDMT relay due to 33 kV feeder fault.</p>	<p>About 52 MW power interruption occurred under Cumilla(N) S/S area from 10:10 to 10:29.</p> <p>About 20 MW power interruption occurred under Kabirpur S/S area from 06:18 to 07:21.</p>
--	--

Superintendent Engineer
Load Despatch Circle