

Reporting Date : 6-Apr-22

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Rule curve :

HSD

Gas

Load Shedding & Other Information

Estimated Demand (S/S end)

Information of the Generating Units under shut down.

Planned Shut- Down

Forced Shut-Down

- | Forced Shut-Down |
|----------------------------|
| 1) Barapukuria ST: Unit-2 |
| 2) Ghorasal-3,5 |
| 3) Ashuganj-4,5 |
| 4) Baghabari-71,100 MW |
| 5) Raozan unit- 1 |
| 6) Siddhirganj 210 MW . |
| 7) Siddhirgani 335 MW CAPP |

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

- a) Payra-Gopalganj(P) 132 kV Ckt-1 was switched on at 09:01.
- b) Mirsharai 230/132 kV T02 transformer was under shut down from 10:01 to 13:48 for D/W.
- c) Keraniganj 230/132 kV ATR-3 transformer was under shut down from 10:00 to 15:39 for D/W.
- d) Baghabari-Bhangura 132 kV Ckt-2 was switched on at 09:59.
- e) Sreenagar 132/63 kV T-2 transformer was under shut down from 10:27 to 12:05 for C/M.
- f) Aminbazar 132 kV Main Bus was under shut down from 09:16 to 13:08 for C/M.
- g) Chandpur CCPP ST was synchronized at 12:30.
- h) Bhola CCPP ST was synchronized at 10:08.
- i) Hasnabad-Brammangao 132 kV Ckt was shut down at 14:12.
- j) Haripur-Madanganj 132 kV Ckt was switched on at 16:45.
- k) Gopalganj-Rampal 400 kV Ckt-1 charge at 16:34 from Gopalganj end.
- l) Fenchuganj EPL was shut down at 00:14/06/04/2022.
- m) Dohazari-Cox'sbazar 132 kV Ckt2 tripped at 04:32/06-04-2022) from both end showing Dist. Z1, 3-phase relays.
- n) Ashuganj 132 kV Bus-2 is shut down since 07:05/06-04-2022) for C/M.

Sub Divisional Engineer
Network Operation Division

Executive Engineer
Network Operation Division

Superintendent Engineer
Load Despatch Circle