

21:00 Hrs on 16-Apr-22

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Cost of the Consumed Fuel (PDI)	<b>Gas</b>	:	Tk182,984,998		
:	<b>Coal</b>	:	Tk224,347,611	Oil	: Tk841,379,645
				Total	: Tk1,248,712,254

Area	Yesterday		Estimated Demand (S/S end)	Today	
	MW			Estimated Shedding (S/S end)	Rates of Shedding (On Estimated Demand)
			MW	MW	
Dhaka	0	0:00	4527	0	0%
Chittagong Area	0	0:00	1211	0	0%
Khulna Area	0	0:00	1599	0	0%
Rajshahi Area	0	0:00	1432	0	0%
Cumilla Area	0	0:00	1270	0	0%
Mymensingh Area	0	0:00	935	0	0%
Sylhet Area	0	0:00	516	0	0%
Barisal Area	0	0:00	343	0	0%
Rangpur Area	0	0:00	713	0	0%
<b>Total</b>	<b>0</b>		<b>12547</b>	<b>0</b>	

Planned Shut- Down	<b>Forced Shut- Down</b> 1) Barapukuria ST: Unit-1,2 2) Ghorasal-3,4 3) Ashuganj-5 4) Baghabari-71,100 MW 5) Raozan unit-2 6) Siddhirganj 210 MW , 7) Sikalbaha 225 MW 8) Shajibazar 330 MW 9) Bibiyana-2
--------------------	--

<p>a) Haripur-Bhulta 230 kV Ckt-2 was under shut down from 08:29 to 13:27 for C/M.</p> <p>b) Ponchagarh 132/33 kV T-2 transformer was under shut down from 10:01 to 11:25 for R/h maintenance at DS, 33 kV PBS feeder.</p> <p>c) GPH 230/33 kV T01 transformer was under shut down from 10:54 to 12:13 for oil leakage.</p> <p>d) Ghorashal-Narshingdi 132 kV Ckt-2 was under shut down from 11:40 to 13:27 for C/M.</p> <p>e) Savar 132/33 kV T-3 transformer was under shut down from 11:46 to 13:36 for C/M.</p> <p>f) Rangpur 132/33 kV T-3 transformer was under shut down from 13:05 to 13:30 for 33 kV CB gas filling.</p> <p>g) Faridpur 132/33 kV T-3 transformer tripped at 08:55 due to Y-g, 33 kV cable burst and was switched on at 14:34.</p> <p>h) Rampal-Gopalganj 400 kV Ckt-1 tripped at 15:23 showing Dist Z1, C at Rampal end and Dist Z1, C at Gopalganj end and was switched on at 17:40.</p> <p>i) Payra 400/132 kV ATR-1 transformer tripped at 15:26 due to over fluxing and was switched on at 17:17.</p> <p>j) Payra unit-1 under went house-load at 15:26 and was synchronized at 16:57.</p> <p>k) Ashuganj(S) 450 MW tripped at 20:42 due to problem with GBC and GT was synchronized at 22:45 and STG was synchronized at 04:23(14/7/2022).</p> <p>l) Haripur 360 MW-Haripur 230 kV Ckt-2 was shut down at 07:08(14/7/2022) for C/M.</p> <p>m) Savar 132/33 kV T-2 transformer was under shut down from 07:32(14/7/2022) to 09:26 for C/M.</p>	<p>About 10 MW power interruption occurred under Ponchagarh S/S area from 10:01 to 11:25.</p>
--	---

**Superintendent Engineer  
Load Despatch Circle**