POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER QF-LDC-08 DAILY REPORT Page -1 Reporting Date : 11-Aug-22 Hrs 14782.0 Till now the maximum generation is: 21:00 16-Apr-22 The Summary of Yesterday's Day Peak Generation : Evening Peak Generation : Today's Actual Min Gen. & Probable Gen. & Demand Min. Gen. at 7:00 10280 MW Available Max Generation : 13246 MW 10-Aug-22 **Generation & Demand** 10291.0 MW Hour 10:00 12397.0 MW Hour 21:00 E.P. Demand (at gen end) 13700.0 MW Hour 21:00 Max Demand (Evening) : Reserve(Generation end) 13800 MW Maximum Generation 12397.0 MW Hour 21:00 - MW Total Gen. (MKWH) Load Shed 512 MW 262.7 88.31% System Load Factor EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 504 MW 23:00 Energy MKWHR Import from West grid to East grid :- Maximum Level of Kaptai Lake at 6:00 A M on MKWHR MW Energy 11-Aug-22 Ft.(MSL) Actual : 95.69 Rule curve : 92.20 Ft.(MSL) Gas Consumed : Total = 986.20 MMCFD Oil Consumed (PDB): HSD Cost of the Consumed Fuel (PDB+P) Gas Tk144 319 181 : Tk1,359,081,685 Total : Tk1,657,610,827 Coal Load Shedding & Other Information Area Yesterday Today Rates of Shedding Estimated Shedding (S/S end) MW Estimated Demand (S/S end) MW MW (On Estimated Demand) Dhaka 4419 Chittagong Area Khulna Area Rajshahi Area 0 0:00 1251 57 82 81 65 6% 0:00 1652 1466 6% 6% 160 202 7% 10% 7% 0% Cumilla Area 230 0:00 1248 59 21 Mymensingh Area 290 0.00 1031 Sylhet Area 22 0:00 460 Barisal Area 0 0:00 375 0 Rangpur Are Total 0:00 814 1201 12718 Information of the Generating Units under shut down Planned Shut- Down Forced Shut-Down 1) Barapukuria ST: Unit-2 2) Ghorasal-3,4 10) Payra unit-2 3) Ashugani-5 4) Baghabari-71,100 MW 5) Raozan unit-2 6) Siddhirganj 210 MW . 7) Sikalhaha 225 MW Shajibazar 330 MW 9) Siddhirganj 335 MW Additional Information of Machines, lines, Interruption / Forced Load shed etc. a) Joydevpur 132/33 kV T-3 transformer was under shut down from 11:36 to 12:46 for C/M. b) Kishoreganj 132/33 kV T-3 transformers A& B were under shut down from 08:33 to 21:25 for D/W. c) Haripur-Sonargaon 132 kV Ckt was under shut down from 08:58 to 13:06 for C/M. d) Ramganj 132/33 kV T-2 transformer was under shut down from 08:42 to 10:01 for R/H maintenance. About 25 MW power interruption occurred under Ramganj S/S area from 08:42 to 10:01. e) Ashuganj-Ghorashal 132 kV Ckt-1 was shut down at 09:01 for C/M and was switched on at 23:49 from Ghorashal end. f) Bhaluka-Mymensingh 132 kV Ckt-1 was under shut down from 09:18 to 16:52 for D/W. g) Bhaluka 132/33 kV T-1 transformer was under shut down from 09:19 to 17:10 for D/W. h) Bhaluka 132 kV Bus-1 was under shut down from 09:22 to 14:31 for D/W. In Dislance 152 AV Diservises using smit down into 3c2 to 173 No DIV. j) Mithapukur-Confidence 132 kV Ckt-1 was under shut down from 11:14 to 14:16 for R/H maintenance. k) Mithapukur 132 kV Bus-1 was under shut down from 11:45 to 14:16 for R/H maintenance. in Fairdput 132/33 kV T-2 transformer was under shut down from 09:48 to 11:46 for C/M. m) Bheramara GK 132/33 kV T-2 transformer along with 33 kV Bus-2 were under shut down from 10:31 to 11:35 for C/M. n) Ashuganj 132/33 kV OAT-12 transformer tripped at 13:17 and was switched on at 13:31. o) Norail 132/33 kV T-2 transformer was under shut down from 14:14 to 15:07 for C/M. About 10 MW power interruption occurred under Norail S/S area from 14:14 to 15:07. p) Bhaluka 132 kV Bus-2 was under shut down from 14:50 to 16:27 for C/M. q) Naogaon 132/33 kV T-2 transformer along with 33 kV Bus were under shut down from 15:14 to 16:28 for C/M. About 12 MW power interruption occurred under About 12 MW power interruption occurred under Naogaon S/S area from 15:14 to 16:28. About 100 MW power interruption occurred under Kabirpur S/S area from 15:15 to 17:07. r) Kabirpur 132/33 kV T-2 transformer along with 33 kV Bus were under shut down from 15:15 to 17:07 for R/H maintenance by PBS. s) Bibiyana south ST was synchronized at 17:01. t) Polashbari 132/33 kV T-3 transformer was under shut down from 16:29 to 18:25 for C/M. u) Sonargaon-Daudkandi 132 kV Ckt-1 was under shut down from 13:54 to 16:44 for C/M. y) Sonargaon-Daudkandi 132 kV Ckt-2 was under shut down from 16:48 to 18:03 for C/M. w) Barapukuria unit-1 was shut down at 22:02 due to boiler tube leakage. x) Kabirpur-Kodda 132 kV Ckt-2 was shut down at 06:25(11/8/2022) for C/M.